



Thermal Overloads

ID	Overloaded Facility	Worst Contingency	Category	Category Description	Loading (%)			Potential Mitigation Solutions
					2015 Summer Peak	2018 Summer Peak	2023 Summer Peak	

No thermal overload concerns were identified.

San Onofre Nuclear Generation Station was retired on June 7, 2013 and therefore was removed from the base cases used for the 2013/14 ISO transmission planning process.

Study Area: **SCE Tehachapi & Big Creek Corridor - Summer Off-Peak & Summer Light Load**



Thermal Overloads

ID	Overloaded Facility	Worst Contingency	Category	Category Description	Loading (%)			Potential Mitigation Solutions
					2015 Summer Off-Peak	2018 Summer Light Load	N/A	

No thermal overload concerns were identified.



Voltage Deviations

ID	Substation	Worst Contingency	Category	Category Description	Post Cont. Voltage Deviation %			Potential Mitigation Solutions
					2015 Summer Peak	2018 Summer Peak	2023 Summer Peak	

No voltage deviation concerns were identified.



Voltage Deviations

ID	Substation	Worst Contingency	Category	Category Description	Post Cont. Voltage Deviation %			Potential Mitigation Solutions
					2015 Summer Off-Peak	2018 Summer Light Load	N/A	

No voltage deviation concerns were identified.



High/Low Voltage

ID	Substation	Worst Contingency	Category	Category Description	Voltage (PU)			Potential Mitigation Solutions
					2015 Summer Peak	2018 Summer Peak	2023 Summer Peak	

No high/low voltage concerns were identified.



High/Low Voltage

ID	Substation	Worst Contingency	Category	Category Description	Voltage (PU)			Potential Mitigation Solutions
					2015 Summer Off-Peak	2018 Summer Light Load	N/A	

No high/low voltage concerns were identified.



Transient Stability

ID	Contingency	Category	Category Description	Transient Stability Performance			Potential Mitigation Solutions
				2015 Summer Peak	2018 Summer Peak	2023 Summer Peak	

No transient stability concerns were identified.



Transient Stability

ID	Contingency	Category	Category Description	Transient Stability Performance			Potential Mitigation Solutions
				2015 Summer Off-Peak	2018 Summer Light Load	N/A	

No transient stability concerns were identified.

2013/2014 ISO Reliability Assessment - Preliminary Study Results

Study Area: **SCE Tehachapi & Big Creek Corridor - Summer Peak**

Single Contingency Load Drop



ID	Worst Contingency	Category	Category Description	Amount of Load Drop (MW)			Potential Mitigation Solutions
				2015 Summer Peak	2018 Summer Peak	2023 Summer Peak	

No single contingency resulted in total load drop of more than 250 MW.

2013/2014 ISO Reliability Assessment - Preliminary Study Results

Study Area: **SCE Tehachapi & Big Creek Corridor - Summer Off-Peak & Summer Light Load**



Single Contingency Load Drop

ID	Worst Contingency	Category	Category Description	Amount of Load Drop (MW)			Potential Mitigation Solutions
				2015 Summer Off-Peak	2018 Summer Light Load	N/A	

No single contingency resulted in total load drop of more than 250 MW.

2013/2014 ISO Reliability Assessment - Preliminary Study Results

Study Area: **SCE Tehachapi & Big Creek Corridor - Summer Peak**

Single Source Substation with more than 100 MW Load



ID	Substation	Load Served (MW)			Potential Mitigation Solutions
		2015 Summer Peak	2018 Summer Peak	2023 Summer Peak	

No single source substation with more than 100 MW Load.

2013/2014 ISO Reliability Assessment - Preliminary Study Results

Study Area: **SCE Tehachapi & Big Creek Corridor - Summer Off-Peak & Summer Light Load**



Single Source Substation with more than 100 MW Load

ID	Substation	Load Served (MW)			Potential Mitigation Solutions
		2015 Summer Off-Peak	2018 Summer Light Load	N/A	

No single source substation with more than 100 MW Load.