

## **APPENDIX J: 2034 AND SELECTED 2039 LOCAL CAPACITY TECHNICAL STUDY**

**Intentionally left blank**

## Executive Summary

This report documents the results of the 2034 Long-Term Local Capacity Technical (LCT) Study and 2039 Long-Term Local Capacity Technical (LCT) Study for selected areas. The LCT Study objectives, inputs, methodologies and assumptions are the same as those discussed in the 2025 LCT Study to be adopted by the CAISO and submitted to the CPUC for adoption in its 2025 Local Resource Adequacy process.

Overall, the 2034 Local Capacity area resource Requirements (LCR) trend compared with 2029, is up by about 1344 MW or about 6.1% (1.2%/year). It is worth mentioning the following areas: (1) Humboldt where LCR has increased mostly due to load forecast increase, new transmission project and change in limiting constraint; (4) North Coast/North Bay, Sierra, Stockton, Bay Area, Fresno, Kern and Big Creek/Ventura where LCR has increased mainly due to load forecast increase; (6) LA Basin and San Diego-Imperial Valley, where LCR needs have decreased due to new transmission projects.

The 2034 study includes the CPUC main portfolio whereas the selected 2039 study includes the high retirement portfolio in order to better estimate needs due to such retirements, given the load and transmission are the same with the main portfolio.

The load forecast used in this study is based on the final adopted California Energy Demand 2023-2040 Forecast developed by the CEC; namely the CED 2023 Local Reliability LSE and BAA tables: <https://efiling.energy.ca.gov/GetDocument.aspx?tn=254424>.

The 2034, selected 2039 and 2029 total LCR needs are provided below for comparison:

### 2034 Local Capacity Needs

|                            | Qualifying Capacity |                |            |              | Capacity Available at Peak | 2034 LCR Need Category C |
|----------------------------|---------------------|----------------|------------|--------------|----------------------------|--------------------------|
| Local Area Name            | QF/ Muni (MW)       | Non-Solar (MW) | Solar (MW) | Total (MW)   | Total (MW)                 | Capacity Needed          |
| Humboldt                   | 0                   | 178            | 0          | 178          | 178                        | 178*                     |
| North Coast/ North Bay     | 136                 | 1030           | 4          | 1170         | 1166                       | 812*                     |
| Sierra                     | 1221                | 769            | 0          | 1990         | 1990                       | 1865*                    |
| Stockton                   | 101                 | 811            | 5          | 917          | 912                        | 864*                     |
| Greater Bay                | 598                 | 8758           | 6          | 9362         | 9356                       | 8554*                    |
| Greater Fresno             | 227                 | 3873           | 302        | 4402         | 4100                       | 2695*                    |
| Kern                       | 0                   | 78             | 43         | 121          | 78                         | 121*                     |
| Big Creek/ Ventura         | 399                 | 4066           | 343        | 4808         | 4465                       | 1462                     |
| LA Basin                   | 1049                | 10189          | 64         | 11302        | 11302                      | 4900                     |
| San Diego/ Imperial Valley | 3                   | 6234           | 169        | 6406         | 6406                       | 1902                     |
| <b>Total</b>               | <b>3734</b>         | <b>35986</b>   | <b>936</b> | <b>40656</b> | <b>39953</b>               | <b>23353</b>             |

**2039 Selected Local Capacity Needs**

|                            | Qualifying Capacity |                |            |            | Capacity Available at Peak | 2039 LCR Need Category C |
|----------------------------|---------------------|----------------|------------|------------|----------------------------|--------------------------|
| Local Area Name            | QF/ Muni (MW)       | Non-Solar (MW) | Solar (MW) | Total (MW) | Total (MW)                 | Capacity Needed          |
| Greater Bay                | 132                 | 7909           | 30         | 8071       | 8041                       | 8071*                    |
| LA Basin                   | 486                 | 9117           | 115        | 9718       | 9718                       | 5377                     |
| San Diego/ Imperial Valley | 3                   | 6326           | 169        | 6498       | 6498                       | 2563                     |

**2029 Local Capacity Needs**

|                            | Qualifying Capacity |                |            |              | Capacity Available at Peak | 2029 LCR Need Category C |
|----------------------------|---------------------|----------------|------------|--------------|----------------------------|--------------------------|
| Local Area Name            | QF/ Muni (MW)       | Non-Solar (MW) | Solar (MW) | Total (MW)   | Total (MW)                 | Capacity Needed          |
| Humboldt                   | 0                   | 175            | 0          | 175          | 175                        | 173                      |
| North Coast/ North Bay     | 136                 | 849            | 0          | 985          | 985                        | 650                      |
| Sierra                     | 1221                | 704            | 0          | 1925         | 1925                       | 1885*                    |
| Stockton                   | 101                 | 655            | 7          | 763          | 756                        | 763*                     |
| Greater Bay                | 604                 | 7781           | 4          | 8389         | 8385                       | 6259                     |
| Greater Fresno             | 229                 | 2839           | 199        | 3267         | 3068                       | 2512*                    |
| Kern                       | 9                   | 397            | 43         | 449          | 406                        | 241                      |
| Big Creek/ Ventura         | 399                 | 3702           | 249        | 4350         | 4350                       | 1329                     |
| LA Basin                   | 1157                | 9129           | 10         | 10296        | 10296                      | 5076                     |
| San Diego/ Imperial Valley | 3                   | 5637           | 169        | 5809         | 5809                       | 3121                     |
| <b>Total</b>               | <b>3859</b>         | <b>31868</b>   | <b>681</b> | <b>36408</b> | <b>36155</b>               | <b>22009</b>             |

\* Details about magnitude of deficiencies can be found in the applicable section below. Resource deficient sub-area implies that in order to comply with the criteria, at summer peak, load may be shed immediately after the first contingency.

The narrative for each Local Capacity Area lists important new projects included in the base cases as well as a description of reason for changes between the 2029 Long-Term LCT study and this 2034 and selected 2039 Long-Term LCT study.

This 2034 and selected 2039 Long-Term Local Capacity Technical (LCT) Study was prepared in keeping with the ISO's current commitment to prepare biennial 10-year local capacity technical studies on an informational basis, to assist with the CPUC's Integrated Resource Planning process.

## Table of Contents

|   |     |
|---|-----|
| Executive Summary.....  | 3   |
| J.1 Overview of the Study: Inputs, Outputs and Options.....                     | 7   |
| J.1.1 Objectives.....   | 7   |
| J.1.2 Key Study Assumptions.....  | 7   |
| J.1.2.1 Inputs and Methodology.....   | 7   |
| J.1.3 Grid Reliability.....   | 9   |
| J.1.4 Application of N-1, N-1-1, and N-2 Criteria.....                          | 10  |
| J.1.5 Performance Criteria.....   | 10  |
| J.1.5.1 Performance Criteria.....   | 10  |
| J.1.5.2 CAISO Statutory Obligation Regarding Safe Operation.....                | 11  |
| J.2 Assumption Details: How the Study was Conducted.....                        | 15  |
| J.2.1 System Planning Criteria.....   | 15  |
| J.2.1.1 Power Flow Assessment.....  | 18  |
| J.2.1.2 Post Transient Load Flow Assessment.....                                | 19  |
| J.2.1.3 Stability Assessment.....   | 19  |
| J.2.2 Load Forecast.....  | 19  |
| J.2.2.1 System Forecast.....  | 19  |
| J.2.2.2 Base Case Load Development Method.....                                  | 20  |
| J.2.3 Power Flow Program Used in the LCR analysis.....                          | 21  |
| J.2.4 Estimate of Battery Storage Needs due to Charging Constraints.....        | 21  |
| J.3 Locational Capacity Requirement Study Results.....                          | 23  |
| J.3.1 Summary of Study Results.....   | 23  |
| J.3.2 Summary of 2034 Results by Local Area.....                                | 27  |
| J.3.2.1 Humboldt Area.....  | 27  |
| J.3.2.2 North Coast / North Bay Area.....                                       | 30  |
| J.3.2.3 Sierra Area.....  | 38  |
| J.3.2.4 Stockton Area.....  | 45  |
| J.3.2.5 Greater Bay Area.....   | 52  |
| J.3.2.6 Greater Fresno Area.....  | 68  |
| J.3.2.7 Kern Area.....  | 85  |
| J.3.2.8 Big Creek/Ventura Area.....   | 95  |
| J.3.2.9 LA Basin Area.....  | 103 |
| J.3.2.10 San Diego-Imperial Valley Area.....                                    | 115 |
| J.3.2.11 Valley Electric Area.....  | 124 |
| J.3.3 Summary of 2039 Results by Local Area.....                                | 125 |
| J.3.3.1 Greater Bay Area.....   | 125 |
| J.3.3.2 LA Basin Area.....  | 141 |
| J.3.3.3 San Diego-Imperial Valley Area.....                                     | 153 |
| Attachment A – List of physical resources by PTO, local area and market ID..... | 160 |
| Attachment B – Effectiveness factors for procurement guidance.....              | 237 |

**Intentionally left blank**

## J.1 Overview of the Study: Inputs, Outputs and Options

### J.1.1 Objectives

The intent of the 2034 and selected 2039 Long-Term LCT Study is to identify specific areas within the CAISO Balancing Authority Area that have limited import capability and determine the minimum generation capacity (MW) necessary to mitigate the local reliability problems in those areas, as was the objective of all previous Local Capacity Technical Studies.

This 2034 and selected 2039 Long-Term Local Capacity Technical (LCT) Study was prepared in keeping with the ISO's current commitment to prepare biennial 10-year local capacity technical studies on an informational basis, to assist with the CPUC's Integrated Resource Planning processes.

This 10-year study goes beyond the scope of previous 10-year local capacity technical studies and is the first prepared by the ISO that provides stakeholders with comprehensive load profile and transmission capacity profile information to provide additional insight into the nature of the local capacity needs additional information to understand the nature.

### J.1.2 Key Study Assumptions

#### J.1.2.1 Inputs and Methodology

The CAISO used the same Inputs and Methodology as agreed upon by interested parties and previously incorporated into the 2025 LCT Study. The following table sets forth a summary of the approved inputs and methodology that have been used in the 2025 LCT Study as well as this 2034 and selected 2039 LCT Study:

Table J.1.2-1 Summary Table of Inputs and Methodology Used in this LCT Study:

| Issue                             | How Incorporated into THIS LCT Study:   |
|-----------------------------------|---|
| Input Assumptions:                |   |
| Transmission System Configuration | The existing transmission system has been modeled, including all projects operational on or before June 1, of the study year and all other feasible operational solutions brought forth by the PTOs and as agreed to by the CAISO.  |
| Generation Modeled                | The existing generation resources has been modeled and also includes all projects that will be on-line and commercial on or before June 1, of the study year  |
| Load Forecast                     | Uses a 1-in-10 year summer peak load forecast   |
| Methodology:                      |   |
| Maximize Import Capability        | Import capability into the load pocket has been maximized, thus minimizing the generation required in the load pocket to meet applicable reliability requirements.  |
| QF/Nuclear/State/Federal Units    | Regulatory Must-take and similarly situated units like QF/Nuclear/State/Federal resources have been modeled on-line at qualifying capacity output values for purposes of this LCT Study.  |
| Maintaining Path Flows            | Path flows have been maintained below all established path ratings into the load pockets, including the 500 kV. For clarification, given the existing transmission system configuration, the only 500 kV path that flows directly into a load pocket and will, therefore, be considered in this LCT Study is the South of Lugo transfer path flowing into the LA Basin. |

| Performance Criteria:  |   |
|--|---|
| All Performance Levels, including incorporation of PTO operational solutions   | This LCT Study is being published based on the most stringent of all mandatory reliability standards. In addition, the CAISO will incorporate all new projects and other feasible and CAISO-approved operational solutions brought forth by the PTOs that can be operational on or before June 1, of the study year. Any such solutions that can reduce the need for procurement to meet the mandatory standards will be incorporated into the LCT Study. |
| Load Pocket:   |   |
| Fixed Boundary, including limited reference to published effectiveness factors | This LCT Study has been produced based on load pockets defined by a fixed boundary. The CAISO only publishes effectiveness factors where they are useful in facilitating procurement where excess capacity exists within a load pocket.   |

Further details regarding the 2025 as well as 2034 and selected 2039 LCT Study methodology and assumptions are provided in Section III, below.

### J.1.3 Grid Reliability

Service reliability builds from grid reliability because grid reliability is reflected in the Reliability Standards of the North American Electric Reliability Council (NERC) and the Western Electricity Coordinating Council (“WECC”) Regional Criteria (collectively “Reliability Standards”). The Reliability Standards apply to the interconnected electric system in the United States and are intended to address the reality that within an integrated network, whatever one Balancing Authority Area does can affect the reliability of other Balancing Authority Areas. Consistent with the mandatory nature of the Reliability Standards, the CAISO is under a statutory obligation to ensure efficient use and reliable operation of the transmission grid consistent with achievement of the Reliability Standards.<sup>1</sup> The CAISO is further under an obligation, pursuant to its FERC-approved Transmission Control Agreement, to secure compliance with all “Applicable Reliability Criteria.” Applicable Reliability Criteria consists of the Reliability Standards as well as reliability criteria adopted by the CAISO (Grid Planning Standards).

The Reliability Standards define reliability on interconnected electric systems using the terms “adequacy” and “security.” “Adequacy” is the ability of the electric systems to supply the aggregate electrical demand and energy requirements of their customers at all times, taking into

---

<sup>1</sup> Pub. Utilities Code § 345

account physical characteristics of the transmission system such as transmission ratings and scheduled and reasonably expected unscheduled outages of system elements. “Security” is the ability of the electric systems to withstand sudden disturbances such as electric short circuits or unanticipated loss of system elements. The Reliability Standards are organized by Performance Categories. Certain categories require that the grid operator not only ensure that grid integrity is maintained under certain adverse system conditions (e.g., security), but also that all customers continue to receive electric supply to meet demand (e.g., adequacy). In that case, grid reliability and service reliability would overlap. But there are other levels of performance where security can be maintained without ensuring adequacy.

### **J.1.4 Application of N-1, N-1-1, and N-2 Criteria**

The CAISO will maintain the system in a safe operating mode at all times. This obligation translates into respecting the Reliability Criteria at all times, for example during normal operating conditions (N-0) the CAISO must protect for all single contingencies (N-1) and common mode (N-2) double line outages. Also, after a single contingency, the CAISO must re-adjust the system to support the loss of the next most stringent contingency. This is referred to as the N-1-1 condition.

The N-1-1 vs N-2 terminology was introduced only as a temporal differentiation between two existing NERC Category P6 and P7 events. N-1-1 represents NERC Category C6 (“category P1 contingency, manual system adjustment, followed by another category P1 contingency”). The N-2 represents NERC Category P7 (“any two circuits of a multiple circuit tower line”) as well as WECC-S2 (for 500 kV only) (“any two circuits in the same right-of-way”) with no manual system adjustment between the two contingencies.

### **J.1.5 Performance Criteria**

As set forth on the Summary Table of Inputs and Methodology, this LCR Report is based on the most stringent mandatory standard (NERC, WECC or CAISO). The CAISO tests the electric system in regards to thermal overloads as well as dynamic and reactive margin compliance with the existing standards.

#### **J.1.5.1 Performance Criteria**

Category P0, P1 & P3 system performance requires that all thermal and voltage limits must be within their “Applicable Rating,” which, in this case, are the emergency ratings as generally determined by the PTO or facility owner. Applicable Rating includes a temporal element such that emergency ratings can only be maintained for certain duration. Under this category, load cannot be shed in order to assure the Applicable Ratings are met however there is no guarantee that facilities are returned to within normal ratings or to a state where it is safe to continue to operate the system in a reliable manner such that the next element out will not cause a violation of the Applicable Ratings.

The NERC Planning Standards require system operators to “look forward” to make sure they safely prepare for the “next” N-1 following the loss of the “first” N-1 (stay within Applicable Ratings after the “next” N-1). This is commonly referred to as N-1-1. Because it is assumed that some

time exists between the “first” and “next” element losses, operating personnel may make any reasonable and feasible adjustments to the system to prepare for the loss of the second element, including, operating procedures, dispatching generation, moving load from one substation to another to reduce equipment loading, dispatching operating personnel to specific station locations to manually adjust load from the substation site, or installing a “Special Protection Scheme” that would remove pre-identified load from service upon the loss of the “next” element.<sup>2</sup> All Category P2, P4, P5, P6, P7 and extreme event requirements in this report refer to situations when in real time (N-0) or after the first contingency (N-1) the system requires additional readjustment in order to prepare for the next worst contingency. In this time frame, load drop is not allowed per existing planning criteria.

Generally, Category P2, P4, P5, P6, P7 and extreme event describes system performance that is expected following the loss of two or more system elements. This loss of two elements is generally expected to happen simultaneously, referred to as N-2. It should be noted that once the “next” element is lost after the first contingency, as discussed above under the Performance Criteria P1, the event is effectively a Category P6 or N-1-1 scenario. As noted above, depending on system design and expected system impacts, the **planned and controlled** interruption of supply to customers (load shedding), the removal from service of certain generators and curtailment of exports may be utilized to maintain grid “security.”


#### J.1.5.2 CAISO Statutory Obligation Regarding Safe Operation

The ISO must maintain the system in a safe operating mode at all times. This obligation translates into respecting the Reliability Criteria at all times. For example, during normal operating conditions (8760 hours per year), the ISO must protect for all single contingencies (P1, P2) and multiple contingencies (P4, P5) as well as common mode double line outages (P7). As a further example, after a single contingency, the ISO must readjust the system in order to be able to support the loss of the next most stringent contingency (P3, P6 and P1+P7 resulting in potential voltage collapse or dynamic instability).

---

<sup>2</sup> A Special Protection Scheme is typically proposed as an operational solution that does not require additional generation and permits operators to effectively prepare for the next event as well as ensure security should the next event occur. However, these systems have their own risks, which limit the extent to which they could be deployed as a solution for grid reliability augmentation. While they provide the value of protecting against the next event without the need for pre-contingency load shedding, they add points of potential failure to the transmission network. This increases the potential for load interruptions because sometimes these systems will operate when not required and other times they will not operate when needed.

Figure J.1.5-1 Temporal graph of LCR Category P0-P7



The following definitions guide the CAISO's interpretation of the Reliability Criteria governing safe mode operation and are used in this LCT Study:

### **Applicable Rating:**

This represents the equipment rating that will be used under certain contingency conditions.

Normal rating is to be used under normal conditions.

Long-term emergency ratings, if available, will be used in all emergency conditions as long as "system readjustment" is provided in the amount of time given (specific to each element) to reduce the flow to within the normal ratings. If not available, the normal rating is to be used.

Short-term emergency ratings, if available, can be used as long as "system readjustment" is provided in the "short-time" available in order to reduce the flow to within the long-term emergency ratings where the element can be kept for another length of time (specific to each element) before the flow needs to be reduced below the normal ratings. If not available long-term emergency rating should be used.

Temperature-adjusted ratings shall not be used because this is a year-ahead study, not a real-time tool, and as such the worst-case scenario must be covered. In case temperature-adjusted ratings are the only ratings available then the minimum rating (highest temperature) given the study conditions shall be used.

CAISO Transmission Register is the only official keeper of all existing ratings mentioned above.

Ratings for future projects provided by PTO and agreed upon by the CAISO shall be used.

Other short-term ratings not included in the CAISO Transmission Register may be used as long as they are engineered, studied and enforced through clear operating procedures that can be followed by real-time operators.

Path Ratings need to be maintained within their limits in order to assure that proper capacity is available in order to operate the system in real-time in a safe operating zone.

### **Controlled load drop:**

This is achieved with the use of a Special Protection Scheme.

### **Planned load drop:**

This is achieved when the most limiting equipment has short-term emergency ratings AND the operators have an operating procedure that clearly describes the actions that need to be taken in order to shed load.

### **Special Protection Scheme:**

All known SPS shall be assumed. New SPS must be verified and approved by the CAISO and must comply with the new SPS guideline described in the CAISO Planning Standards.

### **System Readjustment:**

This represents the actions taken by operators in order to bring the system within a safe operating zone after any given contingency in the system.

Actions that can be taken as system readjustment after a Category P1, P2.1, P2.2(EHV), P2.3(EHV), P3, P4.1-5(EHV), P5.1-5(EHV), P6(high density area)&P7(high density area) contingency:

1. System configuration change – based on validated and approved operating procedures
2. Generation re-dispatch
  - a. Decrease generation (up to 1150 MW) – limit given by single contingency SPS as part of the ISO Grid Planning standards (ISO SPS3)
  - b. Increase generation – this generation will become part of the LCR need

Actions, which shall not be taken as system readjustment after a Category P1, P2.1, P2.2(EHV), P2.3(EHV), P3, P4.1-5(EHV), P5.1-5(EHV), P6(high density area)&P7(high density area) contingency:

1. Load drop – based on the intent of the ISO/WECC and NERC criteria for category P1 contingencies.

An objective of the planning process is to minimize the likelihood and magnitude of Non-Consequential Load Loss following Contingency events. NERC and ISO Planning standards mandate that no load shedding should be done immediately after a Category P1, P2.1.

P2.2(EHV), P2.3(EHV), P3, P4.1-5(EHV), P5.1-5(EHV), P6(high density area)&P7(high density area) contingency. The system should be planned with no load shedding regardless of when it may occur (immediately or within 15-30 minutes after the first contingency). It follows that load shedding may not be utilized as part of the system readjustment period – in order to protect for the next most limiting contingency. Therefore, if there are available resources in the local area, such resources should be used during the manual adjustment period (and included in the LCR need) before resorting to shedding firm load.

Firm load shedding is allowed in a planned and controlled manner after the first contingency in P2.2(HV), P2.3(HV), P2.4, P4.1-5(HV), P4.6, P5.1-5(HV) and after the second contingency in P6(non-high density area), P7(non-high density area) & P1 system adjusted followed by P7 category events.

This interpretation tends to guarantee that firm load shedding is used to address Category P1, P2.1, P2.2(EHV), P2.3(EHV), P3, P4.1-5(EHV), P5.1-5(EHV), P6(high density area)&P7(high density area) conditions only under the limited circumstances where no other resource or validated operational measure is available. A contrary interpretation would constitute a departure from existing practice and degrade current service expectations by increasing load's exposure to service interruptions.

#### **Time allowed for manual readjustment:**

Tariff Section 40.3.1.1, requires the CAISO, in performing the Local Capacity Technical Study, to apply the following reliability criterion:

Time Allowed for Manual Adjustment: This is the amount of time required for the Operator to take all actions necessary to prepare the system for the next Contingency. The time should not be more than thirty (30) minutes.

The CAISO Planning Standards also impose this manual readjustment requirement. As a parameter of the Local Capacity Technical Study, the CAISO must assume that as the system operator the CAISO will have sufficient time to:

- (1) make an informed assessment of system conditions after a contingency has occurred;
- (2) identify available resources and make prudent decisions about the most effective system redispatch;
- (3) manually readjust the system within safe operating limits after a first contingency to be prepared for the next contingency; and
- (4) allow sufficient time for resources to ramp and respond according to the operator's redispatch instructions. This all must be accomplished within 30 minutes.

Local capacity resources can meet this requirement by either (1) responding with sufficient speed, allowing the operator the necessary time to assess and redispatch resources to effectively reposition the system within 30 minutes after the first contingency, or (2) have sufficient energy available for frequent dispatch on a pre-contingency basis to ensure the operator can meet minimum online commitment constraints or reposition the system within 30 minutes after the first contingency occurs. Accordingly, when evaluating resources that satisfy the requirements of the CAISO Local Capacity Technical Study, the CAISO assumes that local capacity resources need to be available in no longer than 20 minutes so the CAISO and demand response providers have a reasonable opportunity to perform their respective and necessary tasks and enable the CAISO to reposition the system within the 30 minutes in accordance with applicable reliability criteria.

## J.2 Assumption Details: How the Study was Conducted

### J.2.1 System Planning Criteria

The following table provides a comparison of system planning criteria, based on the NERC performance standards, used in the study:

Table J.2.1-1: Criteria Comparison for Bulk Electric System contingencies

| Contingency Component(s)   | Mandatory Reliability Standards | Old Local Capacity Criteria | Local Capacity Criteria |
|--|---------------------------------|-----------------------------|-------------------------|
| <b><u>P0 – No Contingencies</u></b>                                    | X                               | X                           | X                       |
| <b><u>P1 – Single Contingency</u></b>                                  |                                 |                             |                         |
| 1. Generator (G-1)   | X                               | X <sup>1</sup>              | X <sup>1</sup>          |
| 2. Transmission Circuit (L-1)  | X                               | X <sup>1</sup>              | X <sup>1</sup>          |
| 3. Transformer (T-1)   | X                               | X <sup>1,2</sup>            | X <sup>1</sup>          |
| 4. Shunt Device  | X                               |                             | X <sup>1</sup>          |
| 5. Single Pole (dc) Line   | X                               | X <sup>1</sup>              | X <sup>1</sup>          |
| <b><u>P2 – Single contingency</u></b>                                  |                                 |                             |                         |
| 1. Opening a line section w/o a fault                                  | X                               |                             | X                       |
| 2. Bus Section fault   | X                               |                             | X                       |
| 3. Internal Breaker fault (non-Bus-tie Breaker)                        | X                               |                             | X                       |
| 4. Internal Breaker fault (Bus-tie Breaker)                            | X                               |                             | X                       |
| <b><u>P3 – Multiple Contingency – G-1 + system adjustment and:</u></b> |                                 |                             |                         |
| 1. Generator (G-1)   | X                               | X                           | X                       |
| 2. Transmission Circuit (L-1)  | X                               | X                           | X                       |
| 3. Transformer (T-1)   | X                               | X <sup>2</sup>              | X                       |
| 4. Shunt Device  | X                               |                             | X                       |
| 5. Single Pole (dc) Line   | X                               | X                           | X                       |

|   |                |                |                |
|---|----------------|----------------|----------------|
| <b><u>P4 – Multiple Contingency - Fault plus stuck breaker</u></b>  |                |                |                |
| 1. Generator (G-1)  | X              |                | X              |
| 2. Transmission Circuit (L-1)   | X              |                | X              |
| 3. Transformer (T-1)  | X              |                | X              |
| 4. Shunt Device   | X              |                | X              |
| 5. Bus section  | X              |                | X              |
| 6. Bus-tie breaker  | X              |                | X              |
| <b><u>P5 – Multiple Contingency – Relay failure (delayed clearing)</u></b>  |                |                |                |
| 1. Generator (G-1)  | X              |                | X              |
| 2. Transmission Circuit (L-1)   | X              |                | X              |
| 3. Transformer (T-1)  | X              |                | X              |
| 4. Shunt Device   | X              |                | X              |
| 5. Bus section  | X              |                | X              |
| <b><u>P6 – Multiple Contingency – P1.2-P1.5 system adjustment and:</u></b>  |                |                |                |
| 1. Transmission Circuit (L-1)   | X              | x              | X              |
| 2. Transformer (T-1)  | X              | x              | X              |
| 3. Shunt Device   | X              |                | X              |
| 4. Bus section  | X              |                | X              |
| <b><u>P7 – Multiple Contingency - Fault plus stuck breaker</u></b>  |                |                |                |
| 1. Two circuits on common structure (L-2)   | X              | X              | X              |
| 2. Bipolar DC line  | X              | X              | X              |
| <b><u>Extreme event – loss of two or more elements</u></b>  |                |                |                |
| Two generators (Common Mode) G-2  | X <sup>4</sup> | X              | X <sup>4</sup> |
| Any P1.1-P1.3 & P1.5 system readjusted (Common Mode) L-2  | X <sup>4</sup> | X <sup>3</sup> | X <sup>5</sup> |
| All other extreme combinations.   | X <sup>4</sup> |                | X <sup>4</sup> |
| <sup>1</sup> System must be able to readjust to a safe operating zone in order to be able to support the loss of the next contingency.<br><sup>2</sup> A thermal or voltage criterion violation resulting from a transformer outage may not be cause for a local area reliability requirement if the violation is considered marginal (e.g. acceptable loss of facility life or low voltage), otherwise, such a violation will necessitate creation of a requirement.<br><sup>3</sup> Evaluate for risks and consequence, per NERC standards. No voltage collapse or dynamic instability allowed.<br><sup>4</sup> Evaluate for risks and consequence, per NERC standards.<br><sup>5</sup> Expanded to include any P1 system readjustment followed by any P7 without stuck breaker. For voltage collapse or dynamic instability situations mitigation is required "if there is a risk of cascading" beyond a relatively small predetermined area – less than 250 MW - directly affected by the outage. |                |                |                |

Table J.2.1-2: Criteria Comparison for non-Bulk Electric System contingencies

| Contingency Component(s)   | Mandatory Reliability Standards | Old Local Capacity Criteria | Local Capacity Criteria |
|--|---------------------------------|-----------------------------|-------------------------|
| <b><u>P0 – No Contingencies</u></b>  | X                               | X                           | X                       |
| <b><u>P1 – Single Contingency</u></b>                                      |                                 |                             |                         |
| 1. Generator (G-1)   | X                               | X <sup>1</sup>              | X                       |
| 2. Transmission Circuit (L-1)  | X                               | X <sup>1</sup>              | X                       |
| 3. Transformer (T-1)   | X                               | X <sup>1,2</sup>            | X                       |
| 4. Shunt Device  | X                               |                             | X                       |
| 5. Single Pole (dc) Line   | X                               | X <sup>1</sup>              | X                       |
| <b><u>P2 – Single contingency</u></b>                                      |                                 |                             |                         |
| 1. Opening a line section w/o a fault                                      |                                 |                             |                         |
| 2. Bus Section fault   |                                 |                             |                         |
| 3. Internal Breaker fault (non-Bus-tie Breaker)                            |                                 |                             |                         |
| 4. Internal Breaker fault (Bus-tie Breaker)                                |                                 |                             |                         |
| <b><u>P3 – Multiple Contingency – G-1 + system adjustment and:</u></b>     |                                 |                             |                         |
| 1. Generator (G-1)   | X                               | X                           | X                       |
| 2. Transmission Circuit (L-1)  | X                               | X                           | X                       |
| 3. Transformer (T-1)   | X                               | X <sup>2</sup>              | X                       |
| 4. Shunt Device  | X                               |                             | X                       |
| 5. Single Pole (dc) Line   | X                               | X                           | X                       |
| <b><u>P4 – Multiple Contingency - Fault plus stuck breaker</u></b>         |                                 |                             |                         |
| 1. Generator (G-1)   |                                 |                             |                         |
| 2. Transmission Circuit (L-1)  |                                 |                             |                         |
| 3. Transformer (T-1)   |                                 |                             |                         |
| 4. Shunt Device  |                                 |                             |                         |
| 5. Bus section   |                                 |                             |                         |
| 6. Bus-tie breaker   |                                 |                             |                         |
| <b><u>P5 – Multiple Contingency – Relay failure (delayed clearing)</u></b> |                                 |                             |                         |
| 1. Generator (G-1)   |                                 |                             |                         |
| 2. Transmission Circuit (L-1)  |                                 |                             |                         |
| 3. Transformer (T-1)   |                                 |                             |                         |
| 4. Shunt Device  |                                 |                             |                         |
| 5. Bus section   |                                 |                             |                         |
| <b><u>P6 – Multiple Contingency – P1.2-P1.5 system adjustment and:</u></b> |                                 |                             |                         |
| 1. Transmission Circuit (L-1)  |                                 | x                           |                         |
| 2. Transformer (T-1)   |                                 | x                           |                         |
| 3. Shunt Device  |                                 |                             |                         |
| 4. Bus section   |                                 |                             |                         |
| <b><u>P7 – Multiple Contingency - Fault plus stuck breaker</u></b>         |                                 |                             |                         |
| 1. Two circuits on common structure (L-2)                                  |                                 | X                           |                         |
| 2. Bipolar DC line   |                                 | X                           |                         |

|   |  |                     |  |
|---|--|---------------------|--|
| <b>Extreme event – loss of two or more elements</b><br>Two generators (Common Mode) G-2<br>Any P1.1-P1.3 & P1.5 system readjusted (Common Mode) L-2<br>All other extreme combinations.  |  | X<br>X <sup>3</sup> |  |
| <sup>1</sup> System must be able to readjust to a safe operating zone in order to be able to support the loss of the next contingency.<br><sup>2</sup> A thermal or voltage criterion violation resulting from a transformer outage may not be cause for a local area reliability requirement if the violation is considered marginal (e.g. acceptable loss of facility life or low voltage), otherwise, such a violation will necessitate creation of a requirement.<br><sup>3</sup> Evaluate for risks and consequence, per NERC standards. No voltage collapse or dynamic instability allowed. |  |                     |  |

A significant number of simulations were run to determine the most critical contingencies within each local area. Using power flow, post-transient load flow, and stability assessment tools, the system performance results of all tested contingencies were measured against the system performance requirements defined by the criteria shown in Tables 1 and 2. Where the specific system performance requirements were not met, generation was adjusted until performance requirements were met for the local area. The adjusted generation constitutes the minimum generation needed in the local area. The following describes how the criteria were tested for the specific type of analysis performed.

### J.2.1.1 Power Flow Assessment:

Table J.2.1-3 Power flow criteria

| Contingencies        | Thermal Criteria <sup>1</sup> | Voltage Criteria <sup>2</sup> |
|----------------------|-------------------------------|-------------------------------|
| P0                   | Applicable Rating             | Applicable Rating             |
| P1 <sup>3</sup>      | Applicable Rating             | Applicable Rating             |
| P2                   | Applicable Rating             | Applicable Rating             |
| P3                   | Applicable Rating             | Applicable Rating             |
| P4                   | Applicable Rating             | Applicable Rating             |
| P5                   | Applicable Rating             | Applicable Rating             |
| P6 <sup>4</sup>      | Applicable Rating             | Applicable Rating             |
| P7                   | Applicable Rating             | Applicable Rating             |
| P1 + P7 <sup>4</sup> | -                             | No Voltage Collapse           |

<sup>1</sup> Applicable Rating – Based on CAISO Transmission Register or facility upgrade plans including established Path ratings.

<sup>2</sup> Applicable Rating – CAISO Grid Planning Criteria or facility owner criteria as appropriate.

<sup>3</sup> Following the first contingency (N-1), the generation must be sufficient to allow the operators to bring the system back to within acceptable operating range (voltage and loading) and/or appropriate OTC following the studied outage conditions and be able to

safely prepare for the loss of the next most stringent element and be within Applicable Rating after the loss of the second element.

- 4 During normal operation or following the first contingency (N-1), the generation must be sufficient to allow the operators to prepare for the next worst N-1 or common mode N-2 without pre-contingency interruptible or firm load shedding. SPS/RAS/Safety Nets may be utilized to satisfy the criteria after the second N-1 or common mode N-2 except if the problem is of a thermal nature such that short-term ratings could be utilized to provide the operators time to shed either interruptible or firm load.

### J.2.1.2 Post Transient Load Flow Assessment:

Table J.2.1-4 Post transient load flow criteria

| Contingencies         | Reactive Margin Criteria <sup>2</sup> |
|-----------------------|---------------------------------------|
| Selected <sup>1</sup> | Applicable Rating                     |

- <sup>1</sup> If power flow results indicate significant low voltages for a given power flow contingency, simulate that outage using the post transient load flow program. The post-transient assessment will develop appropriate Q/V and/or P/V curves.
- <sup>2</sup> Applicable Rating – positive margin based on the higher of imports or load increase by 5% for N-1 contingencies, and 2.5% for N-2 contingencies.

### J.2.1.3 Stability Assessment:

Table J.2.1-5 Stability criteria

| Contingencies         | Stability Criteria <sup>2</sup> |
|-----------------------|---------------------------------|
| Selected <sup>1</sup> | Applicable Rating               |

- <sup>1</sup> Base on historical information, engineering judgment and/or if power flow or post transient study results indicate significant low voltages or marginal reactive margin for a given contingency.
- <sup>2</sup> Applicable Rating – CAISO Grid Planning Criteria or facility owner criteria as appropriate.

## J.2.2 Load Forecast

### J.2.2.1 System Forecast

The California Energy Commission (CEC) derives the load forecast at the system and Participating Transmission Owner (PTO) levels. This relevant CEC forecast is then distributed across the entire system, down to the local area, division and substation level. The PTOs use an econometric equation to forecast the system load. The predominant parameters affecting the

system load are (1) number of households, (2) economic activity (gross metropolitan products, GMP), (3) temperature and (4) increased energy efficiency and distributed generation programs.

### **J.2.2.2 Base Case Load Development Method**

The method used to develop the load in the base case is a melding process that extracts, adjusts and modifies the information from the system, distribution and municipal utility forecasts. The melding process consists of two parts: Part 1 deals with the PTO load and Part 2 deals with the municipal utility load. There may be small differences between the methodologies used by each PTO to disaggregate the CEC load forecast to their level of local area as well as bar-bus model.

#### **J.2.2.2.1 PTO Loads in Base Case**

The methods used to determine the PTO loads are, for the most part, similar. One part of the method deals with the determination of the division<sup>3</sup> loads that would meet the requirements of 1-in-5 or 1-in-10 system or area base cases and the other part deals with the allocation of the division load to the transmission buses.

##### **a. Determination of division loads**

The annual division load is determined by summing the previous year division load and the current division load growth. Thus, the key steps are the determination of the initial year division load and the annual load growth. The initial year for the base case development method is based heavily on recorded data. The division load growth in the system base case is determined in two steps. First, the total PTO load growth for the year is determined, as the product of the PTO load and the load growth rate from the system load forecast. Then this total PTO load growth is allocated to the division, based on the relative magnitude of the load growth projected for the divisions by the distribution planners. For example, for the 1-in-10 area base case, the division load growth determined for the system base case is adjusted to the 1-in-10 temperature using the load temperature relation determined from the latest peak load and temperature data of the division.

##### **b. Allocation of division load to transmission bus level**

Since the loads in the base case are modeled at the various transmission buses, the division loads developed must be allocated to those buses. The allocation process is different depending on the load types. For the most part, each PTO classifies its loads into four types: conforming, non-conforming, self-generation and generation-plant loads. Since the non-conforming and self-generation loads are assumed to not vary with temperature, their magnitude would be the same in the system or area base cases of the same year. The remaining load (the total division load developed above, less the quantity of non-conforming and self-generation load) is the conforming load. The remaining load is allocated to the transmission buses based on the relative magnitude of the distribution forecast. The summation of all base case loads is generally higher than the load forecast because some load, i.e., self-generation and generation-plant, are behind the meter and

---

<sup>3</sup> Each PTO divides its territory in a number of smaller area named divisions. These are usually smaller and compact areas that have the same temperature profile.

must be modeled in the base cases. However, for the most part, metered or aggregated data with telemetry is used to come up with the load forecast.

#### **J.2.2.2      *Municipal Loads in Base Case***

The municipal utility forecasts that have been provided to the CEC and PTOs for the purposes of their base cases were also used for this study.

### **J.2.3 Power Flow Program Used in the LCR analysis**

The technical studies were conducted using General Electric's Power System Load Flow (GE PSLF) program version 22.0.4 and PowerGem's Transmission Adequacy and Reliability Assessment (TARA) program version 2402.1. This GE PSLF program is available directly from GE or through the Western System Electricity Council (WECC) to any member and TARA program is commercially available.

To evaluate Local Capacity Areas, the starting base case was adjusted to reflect the latest generation and transmission projects as well as the one-in-ten-year peak load forecast for each Local Capacity Area as provided to the CAISO by the PTOs.

Electronic contingency files provided by the PTOs were utilized to perform the numerous contingencies required to identify the LCR. These contingency files include remedial action and special protection schemes that are expected to be in operation during the year of study. A CAISO created EPCL (a GE programming language contained within the GE PSLF package) routine and/or TARA software were used to run the combination of contingencies; however, other routines are available from WECC with the GE PSFL package or can be developed by third parties to identify the most limiting combination of contingencies requiring the highest amount of generation within the local area to maintain power flows within applicable ratings.

### **J.2.4 Estimate of Battery Storage Needs due to Charging Constraints**

Local areas and sub-areas have limited transmission capability and therefore rely on internal resources to be available in order to reliably serve internal load. Battery storage will help serve local load during the discharge cycle, however it will also increase local load during the charging cycle.

Due to recent procurement activities geared toward the acquisition of this type of technology, the CAISO is herein estimating the characteristics (MW, MWh, discharge duration) required from battery storage technology in order to seamlessly integrate in each local area and sub-area.

The CAISO expects that for batteries that displace other local resource adequacy resources, the transmission capability under the most limiting contingency and the other local capacity resources must be sufficient to recharge the batteries in anticipation of the outage continuing through the night and into the next day's peak load period.

For each local area and sub-area, the CAISO has estimated the battery storage characteristics, given their unique load shape, constraints and requirements as well as the energy characteristics of other resources required to meet standards. Due to this fact, the strict addition of the sub-area

battery storage characteristics (MW, MWh and duration) may not closely align with the overall local area battery storage characteristic requirements (MW, MWh and duration).

### Assumptions

- 1) Total load serving capability includes capability from transmission system and local generation needed for LCR under the worst contingency.
- 2) Storage added replaces existing generation MW for MW. First the batteries will replace as much as possible of existing gas resources, Second if the area and/or sub-area has run out of gas resources to displace then other technologies may be reduced in order to determine the maximum battery charging limit.
- 3) Effectiveness factors are assumed not to be a factor. Battery storage is assumed to be installed at the same sites where resources are displaced or assumed to have the same effectiveness factors.
- 4) Deliverability of incremental storage capacity is not evaluated. It is assumed battery storage will take over deliverability from old resources through repower. Any new battery storage resource needs to go through the generation interconnection process in order to receive deliverability and it is not evaluated in this study. CAISO cannot guaranty that there is enough deliverability available for new resources. New transmission upgrades may be required in order to make such new resources deliverable to the aggregate of load.
- 5) Includes battery storage charging/discharging efficiency of 85%.
- 6) Daily charging required is distributed to all non-discharging hours proportionally using delta between net load and the total load serving capability.
- 7) Energy required for charging, beyond the transmission capability under contingency condition, is produced by other LCR required resources within the local area and sub-area that are available for production during off-peak hours.
- 8) Hydro resources are considered to be available for production during off-peak hours, however these resources are energy limited themselves and based on past availability data they can have severely limited output during off-peak hours especially during late summer peaks under either normal or dry hydro years.
- 9) The study assumes the ability to provide perfect dispatch and the ability to enforce charging requirements for multiple contingency conditions (like N-1-1) in the day ahead time frame while the system is under normal (no contingency) conditions. CAISO software improvements and/or augmentations are required in order to achieve this goal.

Installing battery storage with insufficient characteristics (MW, MWh and duration) will not result in a one for one reduction of the local area or sub-area need for other types of resources. The CAISO expects that the overall RA portfolio provided by all LSEs to account for the uplift, beyond the minimum LCR need, in MWs required from other type of resources for all areas and sub-areas where LSEs have procured battery storage beyond the charging capability or with incorrect characteristics (MW, MWh and duration). If uplift is not provided the CAISO may use its back stop authority to assure that reliability standards are met throughout the day, including off-peak hours.

## J.3 Locational Capacity Requirement Study Results

### J.3.1 Summary of Study Results

LCR is defined as the amount of resource capacity that is needed within a Local Capacity Area to reliably serve the load located within this area. The results of the CAISO's analysis are summarized in the Executive Summary Tables.

Table J.3.1-1 2034 Local Capacity Needs vs. Peak Load and Local Area Resources

|                           | 2034 Total LCR (MW) | Peak Load (1 in10) (MW) | 2034 LCR as % of Peak Load | Total NQC Local Area Resources (MW) | 2034 LCR as % of Total NQC |
|---------------------------|---------------------|-------------------------|----------------------------|-------------------------------------|----------------------------|
| Humboldt                  | 178                 | 272                     | 65%                        | 178                                 | 100%                       |
| North Coast/North Bay     | 812                 | 1803                    | 45%                        | 1170                                | 69%                        |
| Sierra                    | 1865                | 2130                    | 88%                        | 1990                                | 94%                        |
| Stockton                  | 864                 | 969                     | 89%                        | 917                                 | 94%                        |
| Greater Bay               | 8554                | 14554                   | 59%                        | 9362                                | 91%                        |
| Greater Fresno            | 2695                | 3842                    | 70%                        | 4402                                | 61%                        |
| Kern                      | 121                 | 1011                    | 12%                        | 121                                 | 100%                       |
| Big Creek/Ventura         | 1462                | 5470                    | 27%                        | 4808                                | 30%                        |
| LA Basin                  | 4900                | 20597                   | 24%                        | 11302                               | 43%                        |
| San Diego/Imperial Valley | 1902                | 5419                    | 35%                        | 6406                                | 30%                        |
| <b>Total*</b>             | <b>23353</b>        | <b>56067</b>            | <b>42%</b>                 | <b>406564</b>                       | <b>57%</b>                 |

Table J.3.1-2 2029 Local Capacity Needs vs. Peak Load and Local Area Resources

|                           | 2029 Total LCR (MW) | Peak Load (1 in10) (MW) | 2029 LCR as % of Peak Load | Total NQC Local Area Resources (MW) | 2029 LCR as % of Total NQC |
|---------------------------|---------------------|-------------------------|----------------------------|-------------------------------------|----------------------------|
| Humboldt                  | 173                 | 223                     | 78%                        | 175                                 | 99%                        |
| North Coast/North Bay     | 650                 | 1517                    | 43%                        | 985                                 | 66%                        |
| Sierra                    | 1885                | 1978                    | 95%                        | 1925                                | 98%                        |
| Stockton                  | 763                 | 923                     | 83%                        | 763                                 | 100%                       |
| Greater Bay               | 6259                | 12333                   | 51%                        | 8389                                | 75%                        |
| Greater Fresno            | 2512                | 3773                    | 67%                        | 3267                                | 77%                        |
| Kern                      | 241                 | 902                     | 27%                        | 434                                 | 56%                        |
| Big Creek/Ventura         | 1329                | 5184                    | 26%                        | 4350                                | 31%                        |
| LA Basin                  | 5076                | 19596                   | 26%                        | 10296                               | 49%                        |
| San Diego/Imperial Valley | 3121                | 5046                    | 62%                        | 5809                                | 54%                        |
| <b>Total*</b>             | <b>22009</b>        | <b>51475</b>            | <b>43%</b>                 | <b>36393</b>                        | <b>60%</b>                 |

\* Value shown only illustrative, since each local area peaks at a different time.

Table J.3.1-3 Selected 2039 Local Capacity Needs vs. Peak Load and Local Area Resources

|                           | 2039 Total LCR (MW) | Peak Load (1 in10) (MW) | 2039 LCR as % of Peak Load | Total NQC Local Area Resources (MW) | 2039 LCR as % of Total NQC |
|---------------------------|---------------------|-------------------------|----------------------------|-------------------------------------|----------------------------|
| Greater Bay               | 8071                | 18440                   | 44%                        | 8071                                | 100%                       |
| LA Basin                  | 5377                | 22274                   | 24%                        | 9718                                | 55%                        |
| San Diego/Imperial Valley | 2563                | 5890                    | 44%                        | 6498                                | 39%                        |

Table J.3.1-1, Table J.3.1-2 and Table J.3.1-3 shows how much of the Local Capacity Area load is dependent on local resources and how many local resources must be available in order to serve the load in those Local Capacity Areas in a manner consistent with the Reliability Criteria. These tables also indicate where new transmission projects, new resource additions or demand side management programs would be most useful in order to reduce the dependency on existing, generally older and less efficient local area resources.

The term “Qualifying Capacity” used in this report is the “Net Qualifying Capacity” (“NQC”) posted on the CAISO web site at:

<https://www.caiso.com/generation-transmission/resource-adequacy>.

The NQC list includes the area where each resource is located for units already operational. Neither the NQC list nor this report incorporates Demand Side Management programs and their related NQC. Units scheduled to become operational before June 1, 2034 and June 1, 2039 respectively have been included in this 2034 and selected 2039 Long-Term LCR Report and added to the total NQC values for those respective areas (see detail write-up for each area).

Regarding the main tables up front (page 2), the first column, “August Qualifying Capacity,” reflects three sets of resources. The first set is comprised of resources that would normally be expected to be on-line such as Municipal and Regulatory Must-take resources (state, federal, municipal and QFs). The second set is “market” based resources (market, net seller, wind and battery). The third set are solar resources, since they may or may not be available during the actual peak hour for the respective local area. The second column, “Capacity at Peak” identifies how much of the August Qualifying Capacity is expected to be available during the peak time for each particular local area. The third column, “YEAR LCR Need”, sets forth the local capacity requirements, without the deficiencies that must be addressed, necessary to attain a service reliability level required to comply with NERC/WECC/CAISO mandatory reliability standards.

Table J.3.1-4 and Table J.3.1-5 includes estimated characteristics (MW, MWh, discharge duration) required from battery storage technology in order to seamlessly integrate in each local area and sub-area. The CAISO expects that for batteries that displace other local resource adequacy resources, the transmission capability under the most limiting contingency and the other local capacity resources must be sufficient to recharge the batteries in anticipation of the outage continuing through the night and into the next day’s peak load period.

Table J.3.1-4 2034 Battery Storage Characteristics Limited by Charging Capability

| Area/Sub-area                 | Pmax<br>MW | Energy<br>MWh | Max. # of<br>discharge<br>hours | Max. MW of 4<br>hour battery<br>(1 for 1 MW<br>replacement) | Replacing<br>mostly | Comment          |
|-------------------------------|------------|---------------|---------------------------------|---|---------------------|------------------|
| Humboldt                      | 54         | 161           | 10                              | 43  | gas                 |                  |
| North Coast/North Bay Overall | 590        | 4412          | 11                              | 139   | geothermal          |                  |
| Eagle Rock                    | 115        | 657           | 9                               | 55  | geothermal          |                  |
| Fulton                        | 393        | 2143          | 9                               | 241   | geothermal          |                  |
| Sierra                        | -          | -             | -                               | -   | -                   | Flow through     |
| Placer                        | 16         | 55            | 6                               | 4   | hydro               |                  |
| Pease                         | -          | -             | -                               | -   | -                   | Need eliminated  |
| South of Rio Osos             | -          | -             | -                               | -   | -                   | Flow through     |
| Stockton                      | -          | -             | -                               | -   | -                   | Sum of sub-areas |
| Lockeford                     | -          | -             | -                               | -   | -                   | Need eliminated  |
| Tesla-Bellota                 | 120        | 269           | 5                               | 25  | gas                 |                  |
| Greater Bay Overall           | 2273       | 9091          | 10                              | 2273  | gas                 |                  |
| Llagas                        | 98         | 398           | 8                               | 98  | gas                 |                  |
| San Jose                      | 390        | 1560          | 9                               | 390   | gas                 |                  |
| South Bay-Moss Landing        | 1588       | 6350          | 14                              | 1587  | gas                 |                  |
| Oakland                       | 60         | 304           | 7                               | 60  | distillate          |                  |
| Greater Fresno Overall        | 1340       | 7480          | 10                              | 850   | hydro               |                  |
| Panoche                       | 165        | 1164          | 14                              | 100   | gas                 |                  |
| Herndon                       | 605        | 2930          | 10                              | 480   | hydro               |                  |
| Wilson 115 kV                 | -          | -             | -                               | -   | -                   | Need eliminated  |
| Borden                        | -          | -             | -                               | -   | -                   | Need eliminated  |
| Hanford                       | 19         | 19            | 2                               | 0   | gas                 |                  |
| Coalinga                      | 49         | 254           | 8                               | 27  | none                |                  |
| Reedley                       | 58         | 382           | 10                              | 15  | none                |                  |
| Kern Overall                  | -          | -             | -                               | -   | -                   | N/A              |
| Westpark                      | 40         | 228           | 8                               | 13  | gas                 |                  |
| Kern 70 kV                    | -          | -             | -                               | -   | -                   | Need eliminated  |
| Kern Tevis                    | -          | -             | -                               | -   | -                   | Need eliminated  |
| Kern Oil                      | 100        | 627           | 11                              | 40  | gas                 |                  |
| South Kern PP                 | 290        | 1538          | 9                               | 150   | gas                 |                  |
| Big Creek/Ventura Overall     | 624        | 3407          | 12                              | 4397  | gas                 |                  |
| Vestal                        | 150        | 1071          | 11                              | 60  | hydro               |                  |
| Santa Clara                   | 277        | 949           | 5                               | 237   | gas                 |                  |
| LA Basin Overall              | 2456       | 13269         | 8                               | 360   | gas                 |                  |

| Area/Sub-area                     | Pmax<br>MW | Energy<br>MWh | Max. # of<br>discharge<br>hours | Max. MW of 4<br>hour battery<br>(1 for 1 MW<br>replacement) | Replacing<br>mostly | Comment |
|-----------------------------------|------------|---------------|---------------------------------|---|---------------------|---------|
| Eastern                           | 1730       | 11111         | 11                              | 180   | gas                 |         |
| Western                           | 726        | 2149          | 6                               | 180   | gas                 |         |
| El Nido                           | 201        | 1512          | 11                              | 47  | gas                 |         |
| San Diego/Imperial Valley Overall | 890        | 6380          | 12                              | 470   | gas                 |         |
| San Diego                         | 890        | 6380          | 12                              | 4700  | gas                 |         |
| Border                            | 56         | 234           | 8                               | 53  | gas                 |         |

Table J.3.1-5 Selected 2039 Battery Storage Characteristics Limited by Charging Capability

| Area/Sub-area                     | Pmax<br>MW | Energy<br>MWh | Max. # of<br>discharge<br>hours | Max. MW of 4<br>hour battery<br>(1 for 1 MW<br>replacement) | Replacing<br>mostly | Comment     |
|-----------------------------------|------------|---------------|---------------------------------|---|---------------------|-------------|
| Greater Bay Overall               | 820        | 3291          | 6                               | 820   | gas                 |             |
| Llagas                            | 102        | 415           | 8                               | 102   | gas                 |             |
| San Jose                          | 445        | 1781          | 9                               | 445   | gas                 |             |
| South Bay-Moss Landing            | 2098       | 8404          | 14                              | 2097  | gas                 |             |
| Oakland                           | 39         | 152           | 5                               | 38  | distillate          |             |
| LA Basin Overall                  | 4280       | 27541         | 11                              | 2230  | gas                 |             |
| Eastern                           | 1740       | 11177         | 11                              | 900   | gas                 |             |
| Western                           | 2540       | 16364         | 11                              | 1330  | gas                 |             |
| El Nido                           | 204        | 1534          | 11                              | 47  | gas                 |             |
| San Diego/Imperial Valley Overall | 750        | 5857          | 12                              | 310   | gas                 |             |
| San Diego                         | 750        | 5857          | 12                              | 310   | gas                 |             |
| Border                            | N/A        | N/A           | N/A                             | N/A   | gas                 | Not studied |

## J.3.2 Summary of 2034 Results by Local Area

Each Local Capacity Area's overall requirement is determined by also achieving each sub-area requirement. Because these areas are a part of the interconnected electric system, the total for each Local Capacity Area is not simply a summation of the sub-area needs. For example, some sub-areas may overlap and therefore the same units may count for meeting the needs in both sub-areas.

### J.3.2.1 Humboldt Area

#### J.3.2.1.1 Area Definition:

The transmission tie lines into the area include:


- Bridgeville-Cottonwood 115 kV line #1
- Humboldt-Trinity 115 kV line #1
- Laytonville-Garberville 60 kV line #1
- Trinity-Maple Creek 60 kV line #1
- Humboldt Phase shifter from Off-Shore Wind project

The substations that delineate the Humboldt Area are:

- Bridgeville is in, Low Gap, Wildwood and Cottonwood are out
- Humboldt is in, Trinity is out
- Kekawaka and Garberville are in, Laytonville is out
- Maple Creek is in, Trinity and Ridge Cabin are out
- Humboldt 115 kV is in, Off-shore Wind is out

#### J.3.2.1.1.1 Humboldt LCR Area Diagram

Figure J.3.2-1 Humboldt LCR Area



### J.3.2.1.1.2 Humboldt LCR Area Load and Resources

Table J.3.2-1 provides the forecasted load and resources. The list of generators within the LCR area are provided in Attachment A.

In year 2034 the estimated time of local area peak is 9:00 AM.

This area does not contain models of solar resources capable of providing resource adequacy.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-1 Humboldt LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load                   | 271        | Market, Net Seller, Wind           | 178        | 178        |
| AAEE                         | -4         | Battery                            | 0          | 0          |
| Behind the meter DG          | -8         | MUNI, QF/Self-gen                  | 0          | 0          |
| <b>Net Load</b>              | <b>259</b> | Solar                              | 0          | 0          |
| Transmission Losses          | 13         | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>272</b> | <b>Total</b>                       | <b>178</b> | <b>178</b> |

### J.3.2.1.1.3 Humboldt LCR Area Hourly Profiles

Figure J.3.2-2 illustrates the forecast 2034 profile for the peak day for the Humboldt LCR area along with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-3 illustrates the forecast 2034 hourly profile for Humboldt LCR area with the Category P6 transmission capability without local capacity resources.

Figure J.3.2-2 Humboldt 2034 Peak Day Forecast Profiles





Figure J.3.2-3 Humboldt 2034 Forecast Hourly Profile



#### J.3.2.1.1.4 Approved transmission projects included in base cases

Maple Creek Reactive Support

Garberville area reinforcement

Humboldt off-shore wind project

#### J.3.2.1.2 Humboldt Overall LCR Requirement

Table J.3.2-2 identifies the area LCR requirements. The LCR requirement for Category P6 contingency is 198 MW including 20 MW of deficiency.

Table J.3.2-2 Humboldt LCR Area Requirements

| Year | Limit       | Category | Limiting Facility                   | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-------------------------------------|--|--------------------------|
| 2034 | First Limit | P6       | Humboldt-Bridgeville<br>115 kV line | Humboldt OSW-Humboldt 115 kV and<br>Bridgeville-Cottonwood 115 kV line | 198 (20)                 |

#### J.3.2.1.2.1 Effectiveness factors:

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7110 std at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.2.1.2.2 Changes compared to the 2029 LCR study:

Load forecast increased by 49 MW and the total LCR has increased by 25 MW due to load forecast increase, new transmission project and a different limiting facility.

### J.3.2.2 North Coast / North Bay Area

#### J.3.2.2.1 Area Definition:

The transmission tie facilities coming into the North Coast/North Bay area are:


- Cortina-Mendocino 115 kV Line
- Cortina-Eagle Rock 115 kV Line
- Willits-Garberville 60 kV line #1
- Vaca Dixon-Lakeville 230 kV line #1
- Tulucay-Vaca Dixon 230 kV line #1
- Lakeville-Sobrante 230 kV line #1
- Ignacio-Sobrante 230 kV line #1

The substations that delineate the North Coast/North Bay area are:

- Cortina is out, Mendocino and Indian Valley are in
- Cortina is out, Eagle Rock, Highlands and Homestake are in
- Willits and Lytonville are in, Kekawaka and Garberville are out
- Vaca Dixon is out, Lakeville is in
- Tulucay is in, Vaca Dixon is out
- Lakeville is in, Sobrante is out
- Ignacio is in, Sobrante and Crocket are out

#### J.3.2.2.1.1 North Coast and North Bay LCR Area Diagram

Figure J.3.2-4 North Coast and North Bay LCR Area



### J.3.2.2.1.2 North Coast and North Bay LCR Area Load and Resources

Table J.3.2-3 provides the forecasted load and resources. The list of generators within the LCR area are provided in Attachment A.

In year 2034 the estimated time of local area peak is 19:20 PM.

At the local area peak time the estimated, ISO metered, solar output is 0.00%.

If required, all non-solar technology type resources are dispatched at NQC.


Table J.3.2-3 North Coast and North Bay LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                    | Aug NQC     | At Peak     |
|------------------------------|-------------|------------------------------------|-------------|-------------|
| Gross Load                   | 1868        | Market, Net Seller                 | 975         | 975         |
| AAEE                         | -37         | Battery                            | 43          | 43          |
| Behind the meter DG          | -85         | MUNI, QF/Self-gen                  | 136         | 136         |
| <b>Net Load</b>              | <b>1746</b> | Solar                              | 4           | 0           |
| Transmission Losses          | 57          | Existing 20-minute Demand Response | 12          | 12          |
| Pumps                        | 0           | Mothballed                         | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>1803</b> | <b>Total</b>                       | <b>1170</b> | <b>1166</b> |

### J.3.2.2.1.3 North Coast and North Bay LCR Area Hourly Profiles

Figure J.3.2-5 illustrates the forecast 2034 profile for the peak day for the North Coast/North Bay LCR area along with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-6 illustrates the forecast 2034 hourly profile for North Coast North Bay LCR area with the Category P3 emergency load serving capability without local capacity resources.

Figure J.3.2-5 North Coast and North Bay 2034 Peak Day Forecast Profiles



**CNRB - Lakeville LCR Subarea:  
2034 projected load profile & approx. load serving capability (transmission only)**


The graph displays the 2034 projected net load (grey line) and the 2034 approx. load serving capability (transmission only) (red line) for the CNRB - Lakeville LCR Subarea. The y-axis represents MW (0 to 1800) and the x-axis represents Date/Hours (1/2/2034 12:00 AM to 12/28/2034 10:00 PM).

The 2034 projected net load (grey line) shows significant fluctuations, peaking around 1600 MW and dropping to around 300 MW. The 2034 approx. load serving capability (transmission only) (red line) is constant at 800 MW from 1/2/2034 12:00 AM to 3/18/2034 12:00 AM, then drops to 700 MW until 10/7/2034 2:00 AM, and then returns to 800 MW.

Vaca Dixon-Lakeville 230 kV Corridor Series Compensation  
Tulucay-Napa #2 60 kV Line Capacity Increase  
Clear Lake 60 kV Reinforcement  
Ignacio Area Upgrade  
New Collinsville 500 kV Substation  
Covelo 60kV Voltage Support  
Santa Rosa 115 kV lines Reconductoring project  
Lakeville 60 kV Area Reinforcement

Eagle Rock is a Sub-area of the North Coast and North Bay LCR Area.

Figure J.3.2-7 Eagle Rock LCR Sub-area



### J.3.2.2.2.2 Eagle Rock LCR sub-area Load and Resources

Table J.3.2-4 provides the forecasted load and resources. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-4 Eagle Rock LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load                   | 326        | Market, Net Seller                 | 333        | 333        |
| AAEE                         | -5         | Battery                            | 5          | 5          |
| Behind the meter DG          | -15        | MUNI, QF/Self-gen                  | 2          | 2          |
| <b>Net Load</b>              | <b>306</b> | Solar                              | 0          | 0          |
| Transmission Losses          | 22         | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>328</b> | <b>Total</b>                       | <b>340</b> | <b>340</b> |

### J.3.2.2.2.3 Eagle Rock LCR Sub-area Hourly Profiles

Figure J.3.2-8 illustrates the forecast 2034 profile for the peak day for the Eagle Rock LCR Sub-area with the Category P3 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-9 illustrates the forecast 2034 hourly profile for Eagle Rock LCR sub-area with the Category P3 emergency load serving capability without local capacity resources.

Figure J.3.2-8 Eagle Rock LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-9 Eagle Rock LCR Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.2.2.4 Eagle Rock LCR Sub-area Requirement

Table J.3.2-5 identifies the sub-area LCR requirements. The LCR requirement for Category P3 contingency is 390 MW including a 50 MW deficiency.

Table J.3.2-5 Eagle Rock LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility              | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|--------------------------------|--|--------------------------|
| 2034 | First Limit | P3       | Eagle Rock-Cortina 115 kV line | Cortina-Mendocino 115 kV with<br>Geyser #11 unit out | 390 (50)                 |

#### J.3.2.2.2.5 Effectiveness factors:

Effectiveness factors for generators in the Eagle Rock LCR Sub-area are in Attachment B table titled [Eagle Rock](#).

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7120 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.2.2.3 Fulton Sub-area

Fulton is a sub-area of the North Coast and North Bay LCR Area.

Figure J.3.2-10 Fulton LCR Sub-area




Table J.3.2-4 provides the forecasted load and resources. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-6 Fulton LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|-------------|------------------------------------|------------|------------|
| Gross Load                   | 1111        | Market, Net Seller                 | 675        | 675        |
| AAEE                         | -22         | Battery                            | 43         | 43         |
| Behind the meter DG          | -50         | MUNI, QF/Self-gen                  | 57         | 57         |
| <b>Net Load</b>              | <b>1039</b> | Solar                              | 1          | 0          |
| Transmission Losses          | 36          | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0           | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>1075</b> | <b>Total</b>                       | <b>776</b> | <b>775</b> |

### J.3.2.2.3.3 Fulton LCR Sub-area Hourly Profiles

Figure J.3.2-11 illustrates the forecast 2034 profile for the peak day for the Fulton LCR Sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis.

Figure J.3.2-12 illustrates the forecast 2034 hourly profile for Fulton LCR sub-area with the Category P3 emergency load serving capability without local capacity resources.

Figure J.3.2-11 Fulton LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-12 Fulton LCR Sub-area 2034 Forecast Hourly Profiles



**J.3.2.2.3.4 Fulton LCR Sub-area Requirement**

Table J.3.2-7 identifies the sub-area LCR requirements. The LCR requirement for Category P6 contingency is 398 MW.

Table J.3.2-7 Fulton LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility             | Contingency                                      | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-------------------------------|--|--------------------------|
| 2034 | First Limit | P6       | Eagle Rock-Cortina 115kV Line | Fulton-Lakeville and Fulton-Ignacio 230 kV lines | 398                      |

**J.3.2.2.3.5 Effectiveness factors:**

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7120 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.2.4 North Coast and North Bay Overall****J.3.2.2.4.1 North Coast and North Bay Overall Requirement**

Table J.3.2-8 identifies the sub-area LCR requirements. The LCR requirement for Category P6 contingency is 812 MW.

Table J.3.2-8 North Coast and North Bay LCR area Requirements

| Year | Limit       | Category | Limiting Facility         | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|---------------------------|--|--------------------------|
| 2034 | First Limit | P6       | Eagle Rock-Cortina 115 kV | Vaca Dixon-Tulucay 230 kV and Cortina-Mendocino 115 kV lines | 812                      |

**J.3.2.2.4.2 Effectiveness factors:**

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7120 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.2.4.3 Changes compared to the 2029 LCT study:**

Overall the load forecast went up by 286 MW compared to 2029. The overall LCR requirement (deficiency) went up by 162 MW due to load increase.

**J.3.2.3 Sierra Area****J.3.2.3.1 Area Definition:**

The transmission tie lines into the Sierra Area are:

Table Mountain-Rio Oso 230 kV line

Table Mountain-Palermo 230 kV line

Table Mt-Pease 60 kV line

Caribou-Palermo 115 kV line

Drum-Summit 115 kV line #1

Drum-Summit 115 kV line #2

Spaulding-Summit 60 kV line

Brighton-Bellota 230 kV line

Rio Oso-Lockeford 230 kV line

Gold Hill-Eight Mile Road 230 kV line

Lodi-Eight Mile Road 230 kV line

Gold Hill-Lake 230 kV line

The substations that delineate the Sierra Area are:

Table Mountain is out Rio Oso is in

Table Mountain is out Palermo is in

Table Mt is out Pease is in

Caribou is out Palermo is in

Drum is in Summit is out

Drum is in Summit is out

Spaulding is in Summit is out

Brighton is in Bellota is out

Rio Oso is in Lockeford is out


Gold Hill is in Eight Mile is out

Lodi is in Eight Mile is out

Gold Hill is in Lake is out

## J.3.2.3.1.1 Sierra LCR Area Diagram

Figure J.3.2-13 Sierra LCR Area



## J.3.2.3.1.2 Sierra LCR Area Load and Resources

Table J.3.2-9 provides the forecasted load and resources. The list of generators within the LCR area are provided in Attachment A.

In year 2034 the estimated time of local area peak is 19:30 PM.

At the local area peak time the estimated, ISO metered, solar output is 0.00%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-9 Sierra LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                    | Aug NQC     | At Peak     |
|------------------------------|-------------|------------------------------------|-------------|-------------|
| Gross Load                   | 2218        | Market, Net Seller                 | 709         | 709         |
| AAEE                         | -53         | Battery                            | 60          | 60          |
| Behind the meter DG          | -115        | MUNI, QF                           | 1221        | 1221        |
| <b>Net Load</b>              | <b>2050</b> | Solar                              | 0           | 0           |
| Transmission Losses          | 80          | Existing 20-minute Demand Response | 0           | 0           |
| Pumps                        | 0           | Mothballed                         | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>2130</b> | <b>Total</b>                       | <b>1990</b> | <b>1990</b> |

**J.3.2.3.1.3 Approved transmission projects modeled:**

Rio Oso #1 and #2 230/115 kV transformer replacement Project  
 Rio Oso-W. Sacramento Reconductoring Project  
 South of Palermo 115 kV Reinforcement Project  
 Vaca Dixon Reinforcement Project  
 Vaca-Plainfield 60 kV line reconductoring Project  
 Rio Oso Area 230 kV Voltage Support Project  
 East Marysville 115/60 kV Project  
 Gold Hill 230/115 kV Transformer Addition Project  
 Atlantic High Voltage Mitigation (Rescope) Project

**J.3.2.3.2 Placer Sub-area**

Placer is a sub-area of the Sierra LCR area.

**J.3.2.3.2.1 Placer LCR Sub-area Diagram**

Figure J.3.2-14 Placer LCR Sub-area


**J.3.2.3.2.2 Placer LCR Sub-area Load and Resources**

Table J.3.2-10 provides the forecasted load and resources. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-10 Placer LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC   | At Peak   |
|------------------------------|------------|------------------------------------|-----------|-----------|
| Gross Load                   | 238        | Market, Net Seller                 | 40        | 40        |
| AAEE                         | -6         | Battery                            | 0         | 0         |
| Behind the meter DG          | -13        | MUNI, QF                           | 28        | 28        |
| <b>Net Load</b>              | <b>219</b> | Solar                              | 0         | 0         |
| Transmission Losses          | 4          | Existing 20-minute Demand Response | 0         | 0         |
| Pumps                        | 0          | Mothballed                         | 0         | 0         |
| <b>Load + Losses + Pumps</b> | <b>223</b> | <b>Total</b>                       | <b>68</b> | <b>68</b> |

### J.3.2.3.2.3 Placer LCR Sub-area Hourly Profiles

Figure J.3.2-15 illustrates the forecast 2034 profile for the peak day for the Placer LCR sub-area with the Category P6 normal and emergency capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-16 illustrates the forecast 2034 hourly profile for Placer LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-15 Placer LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-16 Placer LCR Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.3.2.4 Placer LCR Sub-area Requirement

Table J.3.2-11 identifies the sub-area LCR requirements. The LCR requirement for Category P6, P7 contingency is 145 MW, including 77 MW of deficiency.

Table J.3.2-11 Placer LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility          | Contingency                               | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|----------------------------|---|--------------------------|
| 2034 | First Limit | P6, P7   | Drum – Higgins 115 kV line | Gold Hill – Placer #1 and #2 115 kV lines | 145 (77)                 |

#### J.3.2.3.2.5 Effectiveness factors

All units within the Placer Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7240 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.2.3.3 Pease Sub-area

Pease is a sub-area of the Sierra LCR area.

Pease sub-area will be eliminated due to the East Marysville 115/60 kV transmission project

#### J.3.2.3.4 Drum-Rio Oso Sub-area

Drum-Rio Oso is a sub-area of the Sierra LCR area.

Drum-Rio Oso sub-area will be eliminated due to the Rio Oso 230/115 kV transformer upgrade transmission project.

### J.3.2.3.5 Gold Hill-Drum Sub-area

Gold Hill-Drum is a sub-area of the Sierra LCR area.


Gold Hill-Drum sub-area will be eliminated due to the Gold Hill 230/115 kV Transformer Addition transmission project.

### J.3.2.3.6 South of Rio Oso Sub-area

South of Rio Oso is a sub-area of the Sierra LCR area.

#### J.3.2.3.6.1 South of Rio Oso LCR Sub-area Diagram

Figure J.3.2-17 Pease LCR Sub-area



#### J.3.2.3.6.2 South of Rio Oso LCR Sub-area Load and Resources

The South of Rio Oso sub-area does not have a defined load pocket with the limits based upon power flow through the area. Table J.3.2-12 provides the forecasted resources in the sub-area. The list of generators within the LCR area are provided in Attachment A.

Table J.3.2-12 South of Rio Oso LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)   | Generation (MW)                    | Aug NQC    | At Peak    |
|---|------------------------------------|------------|------------|
| The South of Rio Oso Sub-area does not have a defined load pocket with the limits based upon power flow through the area. | Market, Net Seller                 | 88         | 88         |
|   | Battery                            | 50         | 50         |
|   | MUNI, QF                           | 607        | 607        |
|   | Solar                              | 0          | 0          |
|   | Existing 20-minute Demand Response | 0          | 0          |
|   | Mothballed                         | 0          | 0          |
|   | <b>Total</b>                       | <b>745</b> | <b>745</b> |

**J.3.2.3.6.3 South of Rio Oso LCR Sub-area Hourly Profiles**

The South of Rio Oso Sub-area does not have a defined load pocket with the limits based upon power flow through the area. As such, no load profile is provided for this sub-area.

**J.3.2.3.6.4 South of Rio Oso LCR Sub-area Requirement**

Table J.3.2-13 identifies the sub-area LCR requirements. The LCR requirements for Category P6 contingency is 490 MW.

Table J.3.2-13 South of Rio Oso LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility         | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|---------------------------|---|--------------------------|
| 2034 | First limit | P6       | Rio Oso – Atlantic 230 kV | Rio Oso – Gold Hill 230 kV<br>Rio Oso – Brighton 230 kV | 490                      |

**J.3.2.3.6.5 Effectiveness factors:**

Effectiveness factors for generators in the South of Rio Oso LCR Sub-area are in Attachment B table titled [Rio Oso](#).

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7230 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.3.7 South of Palermo Sub-area**

South of Palermo is a sub-area of the Sierra LCR area.

South of Palermo sub-area will be eliminated due to the South of Palermo transmission project.

**J.3.2.3.8 Sierra Area Overall****J.3.2.3.8.1 Sierra LCR Area Hourly Profiles**

The Sierra LCR Area limits are based upon power flow through the area. As such, no load profile is provided for the area.

**J.3.2.3.8.2 Sierra LCR Area Requirement**

Table J.3.2-14 identifies the area requirements. The LCR requirement for Category P6 contingency is 1865 MW.

Table J.3.2-14 Sierra Area Requirements

| Year | Limit       | Category | Limiting Facility            | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|------------------------------|---|--------------------------|
| 2034 | First limit | P6, P7   | Table Mountain – Pease 60 kV | DCTL of Table Mtn. – Palermo and<br>Table Mtn. Rio Oso 230 kV lines | 1865                     |

**J.3.2.3.8.3 Effectiveness factors:**

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7230 and 7240 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.3.8.4 Changes compared to the 2029 LCT study:**

The load forecast went up by 152 MW. The overall LCR need has decreased by 20 MW mostly due to new transmission projects and the total LCR need, including deficiency, has increased by 6 MW mostly due to increase in load forecast.

**J.3.2.4 Stockton Area**

The LCR requirement for the Stockton Area is driven by the requirements for the Tesla-Bellota.

**J.3.2.4.1 Area Definition:***Tesla-Bellota Sub-Area Definition*

The transmission facilities that establish the boundary of the Tesla-Bellota sub-area are:

Bellota 230/115 kV Transformer #1

Bellota 230/115 kV Transformer #2

Tesla-Tracy 115 kV Line

Tesla-Salado 115 kV Line

Tesla-Salado-Manteca 115 kV line

Tesla-Schulte #1 115 kV Line

Tesla-Schulte #2 115kV line

Tesla-Vierra 115 kV Line

The substations that delineate the Tesla-Bellota Sub-area are:

Bellota 230 kV is out Bellota 115 kV is in

Bellota 230 kV is out Bellota 115 kV is in

Tesla is out Tracy is in

Tesla is out Salado is in

Tesla is out Salado and Manteca are in

Tesla is out Schulte is in

Tesla is out Schulte is in

Tesla is out Thermal Energy is in

**J.3.2.4.1.1 Stockton LCR Area Diagram**

The Stockton LCR Area is comprised of the individual noncontiguous sub-areas with diagrams provided for each of the sub-areas below.

**J.3.2.4.1.2 Stockton LCR Area Load and Resources**

Table J.3.2-15 provides the forecast load and resources in the area. The list of generators within the LCR area are provided in Attachment A.

In year 2034 the estimated time of local area peak is 19:30 PM.

At the local area peak time the estimated, ISO metered, solar output is 0.00%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-15 Stockton LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | NQC        | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load                   | 1022       | Market, Net Seller                 | 499        | 499        |
| AAEE                         | -22        | Battery                            | 306        | 306        |
| Behind the meter DG          | -49        | MUNI, QF                           | 101        | 101        |
| <b>Net Load</b>              | <b>951</b> | Solar                              | 5          | 0          |
| Transmission Losses          | 18         | Existing 20-minute Demand Response | 6          | 6          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>969</b> | <b>Total</b>                       | <b>917</b> | <b>912</b> |

**J.3.2.4.1.3 Stockton LCR Area Hourly Profiles**

The Stockton LCR Area is comprised of the individual noncontiguous sub-areas with profiles provided for each of the sub-areas below.

**J.3.2.4.1.4 Approved transmission projects modeled**

Vierra 115 kV Looping Project

Lockeford-Lodi Area 230 kV Development

Mosher Transmission Project

Tesla 230 kV Bus Series Reactor

Kasson – Kasson Junction 1 115 kV Line Section Reconductoring Project

Manteca #1 60 kV Line Section Reconductoring Project

Manteca-Ripon-Riverbank-Melones Area 115 kV Line Reconductoring Project

Weber-Mormon Jct Line Section Reconductoring Project

Tesla 115 kV Bus Reconfiguration

Banta 60 kV Bus Voltage Conversion

#### J.3.2.4.2 *Weber Sub-area*

Weber sub-area has been eliminated due to change in LCR criteria.

#### J.3.2.4.3 *Lockeford Sub-area*


Lockeford sub-area will be eliminated due to the Lockeford-Lodi Area 230 kV Development transmission project.

#### J.3.2.4.4 *Stanislaus Sub-area*

Stanislaus is a sub-area of the Stockton LCR area.

##### J.3.2.4.4.1 *Stanislaus LCR Sub-area Diagram*

Figure J.3.2-18 Stanislaus LCR Sub-area



**J.3.2.4.4.2 Stanislaus LCR Sub-area Load and Resources**

The Stanislaus sub-area does not has a defined load pocket with the limits based upon power flow through the area. Table J.3.2-16 provides the forecasted resources in the sub-area. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-16 Stanislaus LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)  | Generation (MW)                    | Aug NQC    | At Peak    |
|--|------------------------------------|------------|------------|
| The Stanislaus Sub-area does not has a defined load pocket with the limits based upon power flow through the area. | Market, Net Seller                 | 97         | 97         |
|  | Battery                            | 281        | 281        |
|  | MUNI, QF                           | 82         | 82         |
|  | Solar                              | 0          | 0          |
|  | Existing 20-minute Demand Response | 0          | 0          |
|  | Mothballed                         | 0          | 0          |
|  | <b>Total</b>                       | <b>460</b> | <b>460</b> |

**J.3.2.4.4.3 Stanislaus LCR Sub-area Hourly Profiles**

The Stanislaus sub-area does not has a defined load pocket with the limits based upon power flow through the area. As such, no load profile is provided for this sub-area.

**J.3.2.4.4.4 Stanislaus LCR Sub-area Requirement**

Table J.3.2-17 identifies the sub-area requirements. The LCR requirement for Category P3 contingency is 169 MW.

Table J.3.2-17 Stanislaus LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility       | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-------------------------|---|--------------------------|
| 2034 | First limit | P3       | Vierra – Manteca 115 kV | Stanislaus - Melones SW STA-Manteca 115 kV Line and Stanislaus PH | 169                      |

**J.3.2.4.4.5 Effectiveness factors:**

All units within the Stanislaus Sub-area have the same effectiveness factor.


For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7410 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.4.5 Tesla-Bellota Sub-area**

Tesla-Bellota is a sub-area of the Stockton LCR area.

### J.3.2.4.5.1 Tesla-Bellota LCR Sub-area Diagram

Figure J.3.2-19 Tesla-Bellota LCR Sub-area



### J.3.2.4.5.2 Tesla Bellota LCR Sub-area Load and Resources

Table J.3.2-18 provides the forecasted load and resources. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-18 Tesla-Bellota LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load                   | 1022       | Market, Net Seller                 | 499        | 499        |
| AAEE                         | -22        | Battery                            | 306        | 306        |
| Behind the meter DG          | -49        | MUNI, QF                           | 101        | 101        |
| <b>Net Load</b>              | <b>951</b> | Solar                              | 5          | 0          |
| Transmission Losses          | 18         | Existing 20-minute Demand Response | 6          | 6          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>969</b> | <b>Total</b>                       | <b>917</b> | <b>912</b> |

All of the resources needed to meet the Stanislaus sub-area count towards the Tesla-Bellota sub-area LCR need.

### J.3.2.4.5.3 Tesla-Bellota LCR Sub-area Hourly Profiles

Figure J.3.2-20 illustrates the forecast 2034 profile for the peak day for the Tesla-Bellota sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-21 illustrates the forecast 2034 hourly profile for Tesla-Bellota sub-area with of the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-20 Tesla-Bellota LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-21 Tesla-Bellota LCR Sub-area 2034 Forecast Hourly Profile



**J.3.2.4.5.4 Tesla-Bellota LCR Sub-area (Stockton Overall) Requirement**

Table J.3.2-19 identifies the sub-area LCR requirements. The LCR requirement for Category P2 and P6 contingency is 1260 MW including a 396 MW of NQC deficiency.

Table J.3.2-19 Tesla-Bellota LCR Sub-area Requirements

| Year  | Limit       | Category | Limiting Facility                | Contingency   | LCR (MW)<br>(Deficiency)   |
|---|-------------|----------|----------------------------------|---|----------------------------|
| 2034  | First limit | P2-4     | Melones–Riverbank–Bellota 115 kV | P2-4:A11:10: Tesla 115 kV - Section 2D & 1D             | 732                        |
| 2034  | First limit | P6       | Tesla – Tracy 115 kV             | Schulte – Lammers 115 kV & Schulte-Kasson-Manteca 115kV | 977<br>(396 NQC/401 Peak)  |
| Total LCR Need for Tesla – Bellota Sub-area in 2034 |             |          |                                  |   | 1260<br>(396 NQC/401 Peak) |

**J.3.2.4.5.5 Effectiveness factors:**

All units within the Tesla-Bellota Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7410 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.4.6 Stockton Overall****J.3.2.4.6.1 Stockton LCR Area Overall Requirement**

The requirement for this area is driven by the requirement for the Tesla-Bellota sub-area. Table J.3.2-20 identifies the area requirements. The LCR requirement for Category P6 contingency is 1260 MW with a 396 MW NQC deficiency.

Table J.3.2-20 Stockton LCR Sub-area Overall Requirements

| Year | Limit | Category | Limiting Facility | Contingency | LCR (MW)<br>(Deficiency)   |
|------|-------|----------|-------------------|-------------|----------------------------|
| 2034 |       | P6       | Stockton Overall  |             | 1260<br>(396 NQC/401 Peak) |

**J.3.2.4.6.2 Changes compared to the 2029 LCT study**

The load forecast went up by 46 MW and the total LCR need, including deficiency, has increased by 369 MW mostly due to load growth and increased deficiency due to low effectiveness factors of new resources vs internal load.

**J.3.2.5 Greater Bay Area****J.3.2.5.1 Area Definition:**

The transmission tie lines into the Greater Bay Area are:

Lakeville-Sobrante 230 kV  
Ignacio-Sobrante 230 kV  
Parkway-Moraga 230 kV  
Bahia-Moraga 230 kV  
Lambie SW Sta-Vaca Dixon 230 kV  
Peabody-Contra Costa P.P. 230 kV  
Tesla-Kelso 230 kV  
Tesla-Delta Switching Yard 230 kV  
Tesla-Pittsburg #1 230 kV  
Tesla-Pittsburg #2 230 kV  
Tesla-Newark #1 230 kV  
Tesla-Newark #2 230 kV  
Tesla-Ravenswood 230 kV  
Tesla-Metcalf 500 kV  
Moss Landing-Metcalf 500 kV  
Moss Landing-Metcalf #1 230 kV  
Moss Landing-Metcalf #2 230 kV  
Oakdale TID-Newark #1 115 kV  
Oakdale TID-Newark #2 115 kV

The substations that delineate the Greater Bay Area are:

Lakeville is out Sobrante is in  
Ignacio is out Sobrante is in  
Parkway is out Moraga is in  
Bahia is out Moraga is in  
Lambie SW Sta is in Vaca Dixon is out  
Peabody is out Contra Costa P.P. is in  
Tesla is out Kelso is in  
Tesla is out Delta Switching Yard is in

Tesla is out Pittsburg is in

Tesla is out Pittsburg is in

Tesla is out Newark is in

Tesla is out Newark is in

Tesla is out Ravenswood is in

Tesla is out Metcalf is in

Moss Landing is out Metcalf is in

Moss Landing is out Metcalf is in


Moss Landing is out Metcalf is in

Oakdale TID is out Newark is in

Oakdale TID is out Newark is in

### J.3.2.5.1.1 Greater Bay LCR Area Diagram

Figure J.3.2-22 Greater Bay LCR Area



**J.3.2.5.1.2 Greater Bay LCR Area Load and Resources**

Table J.3.2-21 provides the forecasted load and resources. The list of generators within the LCR area are provided in Attachment A.

In year 2034 the estimated time of local area peak is 19:00 PM.

At the local area peak time the estimated, ISO metered, solar output is 0%.

If required, all technology type resources, including solar, are dispatched at NQC.

Table J.3.2-21 Greater Bay Area LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |               | Generation (MW)                    | Aug NQC      | At Peak      |
|------------------------------|---------------|------------------------------------|--------------|--------------|
| Gross Load (inc. ATE)        | 14,697        | Market, Net Seller, Wind           | 6,133        | 6,133        |
| AAEE                         | -236          | Battery                            | 2,206        | 2,206        |
| Behind the meter DG          | -405          | MUNI, QF                           | 598          | 598          |
| <b>Net Load</b>              | <b>14,056</b> | Solar                              | 6            | 0            |
| Transmission Losses          | 498           | Existing 20-minute Demand Response | 65           | 0            |
| Pumps                        | 0             | Mothballed                         | 0            | 0            |
| <b>Load + Losses + Pumps</b> | <b>14,554</b> | <b>Total</b>                       | <b>9,362</b> | <b>9,362</b> |

**J.3.2.5.1.3 Approved transmission projects modeled**

Oakland Clean Energy Initiative Project (Oakland CTs are assumed retired)

Moraga – Oakland X lines rebuild project

Morgan Hill Area Reinforcement (revised scope)

Metcalf-Piercy & Swift and Newark-Dixon Landing 115 kV Upgrade

East Shore-Oakland J 115 kV Reconductoring Project

Vaca Dixon-Lakeville 230 kV Corridor Series Compensation

Lone Tree – Cayetano – Newark corridor Series Compensation

Metcalf-Evergreen 115 kV Line Reconductoring

South of San Mateo Capacity Increase

Newark - NRS 230 kV AC Line

San Jose Area HVDC Line (Metcalf – San Jose)

Series Compensation on Los Esteros-Nortech 115 kV Line


New Collinsville 500 kV substation

### J.3.2.5.2 Llagas Sub-area

Llagas is a sub-area of the Greater Bay LCR area.

#### J.3.2.5.2.1 Llagas LCR Sub-area Diagram

Figure J.3.2-23 Llagas LCR Sub-area



#### J.3.2.5.2.2 Llagas LCR Sub-area Load and Resources

Table J.3.2-22 provides the forecasted load and resources. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-22 Llagas LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load (inc. ATE)        | 469        | Market, Net Seller                 | 256        | 256        |
| AAEE                         | -6         | Battery                            | 64         | 64         |
| Behind the meter DG          | -13        | MUNI, QF                           | 0          | 0          |
| <b>Net Load</b>              | <b>450</b> | Solar                              | 0          | 0          |
| Transmission Losses          | 1          | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>451</b> | <b>Total</b>                       | <b>320</b> | <b>320</b> |

### J.3.2.5.2.3 Llagas LCR Sub-area Hourly Profiles

Figure J.3.2-24 illustrates the forecast 2034 profile for the peak day for the Llagas LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-25 illustrates the forecast 2034 hourly profile for Llagas LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-24 Llagas LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-25 Llagas LCR Sub-area 2034 Forecast Hourly Profiles



**J.3.2.5.2.4 Llagas LCR Sub-area Requirement**

Table J.3.2-23 identifies the sub-area LCR requirements. The LCR requirement for the Category P6 contingency is 294 MW.

Table J.3.2-23 Llagas LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility          | Contingency   | LCR (MW) |
|------|-------------|----------|----------------------------|---|----------|
| 2034 | First limit | P6       | Metcalf-Llagas 115 kV line | Metcalf-Morgan Hill 115 kV &<br>Morgan Hill-Green Valley 115 kV | 294      |

**J.3.2.5.2.5 Effectiveness factors:**

All units within the Llagas Sub-area have the same effectiveness factor.

**J.3.2.5.3 San Jose Sub-area**

San Jose is a sub-area of the Greater Bay LCR area.

**J.3.2.5.3.1 San Jose LCR Sub-area Diagram**

The San Jose LCR sub-area is identified in Figure J.3.2-23.

**J.3.2.5.3.2 San Jose LCR Sub-area Load and Resources**

Table J.3.2-24 provides the forecast load and resources in San Jose LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-24 San Jose LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                    | Aug NQC      | At Peak      |
|------------------------------|--------------|------------------------------------|--------------|--------------|
| Gross Load (inc. ATE)        | 4,138        | Market, Net Seller                 | 585          | 585          |
| AAEE                         | -54          | Battery                            | 345          | 345          |
| Behind the meter DG          | -78          | MUNI, QF                           | 192          | 192          |
| <b>Net Load</b>              | <b>4,006</b> | Solar                              | 0            | 0            |
| Transmission Losses          | 140          | Existing 20-minute Demand Response | 0            | 0            |
| Pumps                        | 0            | Mothballed                         | 0            | 0            |
| <b>Load + Losses + Pumps</b> | <b>4,146</b> | <b>Total</b>                       | <b>1,122</b> | <b>1,122</b> |

**J.3.2.5.3.3 San Jose LCR Sub-area Hourly Profiles**

Figure J.3.2-26 illustrates the forecast 2034 profile for the peak day for the San Jose LCR sub-area with the Category P2 normal and emergency load serving capabilities without local capacity

resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-27 illustrates the forecast 2034 hourly profile for San Jose LCR sub-area with the Category P2 emergency load serving capability without local capacity resources.

Figure J.3.2-26 San Jose LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-27 San Jose LCR Sub-area 2034 Forecast Hourly Profiles



**J.3.2.5.3.4 San Jose Sub-area Requirement**

Table J.3.2-25 identifies the sub-area LCR requirements. The LCR requirement for the Category P6 contingency is 1,412 MW including 290 MW of deficiency.

Table J.3.2-25 San Jose LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                 | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-----------------------------------|---|--------------------------|
| 2034 | First limit | P6       | Metcalf 230/115 kV transformer #2 | Metcalf 230/115 kV transformer #3 and Metcalf 230/115 kV transformer #4 | 1,412 (290)              |

**J.3.2.5.3.5 Effectiveness factors:**

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7320 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.5.4 South Bay-Moss Landing Sub-area**

South Bay-Moss Landing is a sub-area of the Greater Bay LCR area.

**J.3.2.5.4.1 South Bay-Moss Landing LCR Sub-area Diagram**

The South Bay-Moss Landing LCR sub-area is identified in Figure J.3.2-23.

**J.3.2.5.4.2 South Bay-Moss Landing LCR Sub-area Load and Resources**

Table J.3.2-26 provides the forecast load and resources in South Bay-Moss Landing LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-26 South Bay-Moss Landing LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                    | Aug NQC      | At Peak      |
|------------------------------|--------------|------------------------------------|--------------|--------------|
| Gross Load (inc. ATE)        | 6,176        | Market, Net Seller                 | 2,204        | 2,204        |
| AAEE                         | -95          | Battery                            | 1,597        | 1,597        |
| Behind the meter DG          | -156         | MUNI, QF                           | 192          | 192          |
| <b>Net Load</b>              | <b>5,925</b> | Solar                              | 0            | 0            |
| Transmission Losses          | 201          | Existing 20-minute Demand Response | 0            | 0            |
| Pumps                        | 0            | Mothballed                         | 0            | 0            |
| <b>Load + Losses + Pumps</b> | <b>6,126</b> | <b>Total</b>                       | <b>3,993</b> | <b>3,993</b> |

**J.3.2.5.4.3 South Bay-Moss Landing LCR Sub-area Hourly Profiles**

Figure J.3.2-28 illustrates the forecast 2034 profile for the peak day for the South Bay-Moss Landing LCR sub-area with the Category P6 normal and emergency load serving capabilities

without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. The energy storage amount is incremental to the existing system and doesn't include approved energy storage. Figure J.3.2-29 illustrates the forecast 2034 hourly profile for South Bay-Moss Landing LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-28 South Bay-Moss Landing LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-29 South Bay-Moss Landing LCR Sub-area 2034 Forecast Hourly Profiles



**J.3.2.5.4.4 South Bay-Moss Landing LCR Sub- Requirement**

Table J.3.2-27 identifies the sub-area LCR requirements. The LCR requirement for the Category P6 contingency is 4,549 MW including 1,233 MW of deficiency.

Table J.3.2-27 South Bay-Moss Landing LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility               | Contingency   | LCR (MW)         |
|------|-------------|----------|---------------------------------|---|------------------|
| 2034 | First Limit | P6       | Moss Landing-Las Aguilas 230 kV | Tesla-Metcalf 500 kV and<br>Moss Landing-Los Banos 500 kV | 4,549<br>(1,233) |

**J.3.2.5.4.5 Effectiveness factors:**

Effectiveness factors for generators in the South Bay-Moss Landing LCR sub-area are in Attachment B table titled [South Bay-Moss Landing](#).


For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7230 posted at: <http://www.caiso.com/Documents/2210Z.pdf>.

**J.3.2.5.5 Oakland Sub-area**

Oakland is a sub-area of the Greater Bay LCR area.

**J.3.2.5.5.1 Oakland LCR Sub-area Diagram**

Figure J.3.2-30 Oakland LCR Sub-area



### J.3.2.5.5.2 Oakland LCR Sub-area Load and Resources

Table J.3.2-28 provides the forecast load and resources in Oakland LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-28 Oakland LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load (inc. ATE)        | 379        | Market, Net Seller                 | 110        | 110        |
| AAEE                         | -6         | Battery                            | 0          | 0          |
| Behind the meter DG          | -8         | MUNI, QF                           | 49         | 49         |
| <b>Net Load</b>              | <b>365</b> | Solar                              | 0          | 0          |
| Transmission Losses          | 1          | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>366</b> | <b>Total</b>                       | <b>159</b> | <b>159</b> |

### J.3.2.5.5.3 Oakland LCR Sub-area Hourly Profiles

Figure J.3.2-28 illustrates the forecast 2034 profile for the peak day for the Oakland LCR sub-area with the Category P2 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. The energy storage amount is incremental to the existing system and doesn't include approved energy storage. Figure J.3.2-29 illustrates the forecast 2034 hourly profile for Oakland LCR sub-area with the Category P2 emergency load serving capability without local capacity resources.

Figure J.3.2-31 Oakland LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-32 Oakland LCR Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.5.5.4 Oakland LCR Sub-area Requirement

Table J.3.2-29 identifies the sub-area requirements. The LCR requirement for the Category P2 contingency is 121 MW.

Table J.3.2-29 Oakland LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility           | Contingency                         | LCR (MW)         |
|------|-------------|----------|-----------------------------|-------------------------------------|------------------|
| 2034 | First limit | P2       | Oakland C-X #2 115 kV cable | Claremont 115 kV Section<br>1D & 2D | 121 <sup>4</sup> |

#### J.3.2.5.5.5 Effectiveness factors:

All units within the Oakland sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7320 posted at: <http://www.caiso.com/Documents/2210Z.pdf>


#### J.3.2.5.6 Ames-Pittsburg-Oakland Sub-areas Combined

Ames-Pittsburg-Oakland is a sub-area of the Greater Bay LCR area.

<sup>4</sup> This requirement doesn't reflect potential load transfer that could occur following the first contingency. An approved operating procedure including this load transfer could reduce this requirement.

### J.3.2.5.6.1 Ames-Pittsburg-Oakland LCR Sub-area Diagram

Figure J.3.2-33 Ames-Pittsburg-Oakland LCR Sub-area



### J.3.2.5.6.2 Ames-Pittsburg-Oakland LCR Sub-area Load and Resources

Table J.3.2-30 provides the forecast load and resources in Ames-Pittsburg-Oakland LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-30 Ames-Pittsburg-Oakland LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)   | Generation (MW)                    | Aug NQC      | At Peak      |
|---|------------------------------------|--------------|--------------|
| The Ames-Pittsburg-Oakland Sub-area does not have a defined load pocket with the limits based upon power flow through the area. | Market, Net Seller, Wind           | 2,266        | 2,266        |
|   | Battery                            | 200          | 200          |
|   | MUNI, QF                           | 274          | 274          |
|   | Solar                              | 2            | 2            |
|   | Existing 20-minute Demand Response | 0            | 0            |
|   | Mothball                           | 0            | 0            |
|   | <b>Total</b>                       | <b>2,742</b> | <b>2,742</b> |

### J.3.2.5.6.3 Ames-Pittsburg-Oakland LCR Sub-area Hourly Profiles

The Ames-Pittsburg-Oakland sub-area does not have a defined load pocket with the limits based upon power flow through the area. As such, no load profile is provided for this sub-area.

### J.3.2.5.6.4 Ames-Pittsburg-Oakland LCR Sub-area Requirement

Table J.3.2-31 identifies the sub-area LCR requirements. The LCR requirement for the Category P7 or P2 contingency is 2,781 MW including 39 MW of deficiency.

Table J.3.2-31 Ames-Pittsburg-Oakland LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility              | Contingency  | LCR (MW)   |
|------|-------------|----------|--------------------------------|--|------------|
| 2034 | First limit | P6       | Ames-Ravenswood #1 115 kV line | Newark-Ravenswood 230 kV & Tesla-Ravenswood 230 kV | 2,781 (39) |

### J.3.2.5.6.5 Effectiveness factors:

Effectiveness factors for generators in the Ames-Pittsburg-Oakland LCR sub-area are in Attachment B table titled [Ames/Pittsburg/Oakland](#).


For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7320 (T-165Z) posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.2.5.7 Contra Costa Sub-area

Contra Costa is a sub-area of the Greater Bay LCR area.

### J.3.2.5.7.1 Contra Costa LCR Sub-area Diagram

Figure 3.2-34 Contra Costa LCR Sub-area



**J.3.2.5.7.2 Contra Costa LCR Sub-area Load and Resources**

Table J.3.2-32 provides the forecast load and resources in Contra Costa LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-32 Contra Costa LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)   | Generation (MW)                    | Aug NQC      | At Peak      |
|---|------------------------------------|--------------|--------------|
| The Contra Costa Sub-area does not have a defined load pocket with the limits based upon power flow through the area. | Market, Net Seller, Wind           | 1,663        | 1,663        |
|   | Battery                            | 138          | 138          |
|   | MUNI, QF                           | 127          | 127          |
|   | Wind                               | 353          | 353          |
|   | Existing 20-minute Demand Response | 0            | 0            |
|   | Mothballed                         | 0            | 0            |
|   | <b>Total</b>                       | <b>2,281</b> | <b>2,281</b> |

**J.3.2.5.7.3 Contra Costa LCR Sub-area Hourly Profiles**

The Contra Costa sub-area does not has a defined load pocket with the limits based upon power flow through the area. As such, no load profile is provided for this sub-area.

**J.3.2.5.7.4 Contra Costa LCR Sub-area Requirement**

Table J.3.2-33 identifies the sub-area LCR requirements. The LCR requirement for the Category P3 contingency is 1,214 MW.

Table J.3.2-33 Contra Costa LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                           | Contingency                         | LCR (MW) |
|------|-------------|----------|---|-------------------------------------|----------|
| 2034 | First limit | P2       | Tesla – Delta Switching Yard<br>230 kV line | Tesla E 230 kV – Section 2E &<br>1E | 1,214    |

**J.3.2.5.7.5 Effectiveness factors:**

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7230 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.5.8 Bay Area overall****J.3.2.5.8.1 Bay Area LCR Area Hourly Profiles**

Figure J.3.2-35 illustrates the forecast 2034 profile for the peak day for the Bay Area LCR area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to

this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-36 illustrates the forecast 2034 hourly profile for Bay Area LCR area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-35 Bay Area LCR Area 2034 Peak Day Forecast Profiles





Figure J.3.2-36 Bay Area LCR Area 2034 Forecast Hourly Profiles



**J.3.2.5.8.2 Greater Bay LCR Area Overall Requirement**

Table J.3.2-34 identifies the area LCR requirements. The LCR requirement for the Category P6 contingency is 8,554 MW.

Table J.3.2-34 Bay Area LCR Overall area Requirements

| Year | Limit       | Category | Limiting Facility                  | Contingency                               | LCR (MW) |
|------|-------------|----------|------------------------------------|---|----------|
| 2034 | First limit | P6       | Metcalf 500/230 kV #13 transformer | Metcalf 500/230 kV #11 & #12 transformers | 8,554    |

**J.3.2.5.8.3 Changes compared to the 2029 LCT study**

Load forecast went up by 2,221 MW and total LCR need went up by 2,295 MW mainly due to the load increase.

**J.3.2.6 Greater Fresno Area****J.3.2.6.1 Area Definition:**

The transmission facilities coming into the Greater Fresno area are:

- Gates-Mustang #1 230 kV Line
- Gates-Mustang #2 230 kV Line
- Gates #5 230/70 kV Transformer Bank
- Gates #6 230/70 kV Transformer Bank
- Mercy Spring #1 230 /70 Transformer Bank
- Los Banos #3 230/70 Transformer Bank
- Los Banos #4 230/70 Transformer Bank
- Poleline 230/70 kV Transformer Bank
- Warnerville-Wilson 230 kV Line
- Melones-North Merced 230 kV Line
- Panoche-Tranquility #1 230 kV Line
- Panoche-Tranquility #2 230 kV Line
- Panoche #1 230/115 kV Transformer Bank
- Panoche #2 230/115 kV Transformer Bank
- Corcoran-Smyrna 115 kV Line

Coalinga #1-San Miguel 70 kV Line

The substations that delineate the Greater Fresno area are:

Gates is out Mustang is in

Gates is out Mustang is in

Gates 230 is out Gates 70 is in

Mercy Springs 230 is out Mercy Springs 70 is in

Los Banos 230 is out Los Banos 70 is in

Los Banos 230 is out Los Banos 70 is in

Poleline 230 is out and Poleline 70 is in

Warnerville is out Wilson is in

Melones is out North Merced is in

Panoche is out Tranquility #1 is in

Panoche is out Tranquility #2 is in

Panoche 230 is out Panoche 115 is in


Panoche 230 is out Panoche 115 is in

Corcoran is in Smyrna is out

Coalinga is in San Miguel is out

### J.3.2.6.1.1 Fresno LCR Area Diagram

Figure J.3.2-37 Fresno LCR Area



**J.3.2.6.1.2 Fresno LCR Area Load and Resources**

Table J.3.2-35 provides the forecast load and resources in Fresno LCR Area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

In year 2034 the estimated time of local area peak is 19:40 PM.

At the local area peak time the estimated, ISO metered, solar output is 0.00%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-35 Fresno LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                    | Aug NQC     | At Peak     |
|------------------------------|-------------|------------------------------------|-------------|-------------|
| Gross Load                   | 4019        | Market, Net Seller                 | 2372        | 2372        |
| AAEE                         | -96         | Battery, Hybrid                    | 1501        | 1501        |
| Behind the meter DG          | -213        | MUNI, QF                           | 227         | 227         |
| <b>Net Load</b>              | <b>3710</b> | Solar                              | 302         | 0           |
| Transmission Losses          | 132         | Existing 20-minute Demand Response | 0           | 0           |
| Pumps                        | 0           | Mothballed                         | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>3842</b> | <b>Total</b>                       | <b>4402</b> | <b>4100</b> |

**J.3.2.6.1.3 Approved transmission projects modeled**

Panoche-Oro Loma 115 kV Reconductoring (In-service)

Wilson 115 kV Area Reinforcement (Q1-2028)

Oro Loma 70 kV Area Reinforcement (Q1-2027)

Giffen Line Reconductoring (In-service)

Borden 230/70 kV Transformer Bank #1 Capacity Increase (Q1-2028)

Wilson-Oro Loma 115 kV Line Reconductoring (Q2-2027)

Bellota-Warnerville 230kV Reconductoring (In-service)

New Manning 500 kV substation project (Q4-2027)

Herndon - Bullard Nos. 1 and 2 115 kV Reconductoring (Q4-2026)

Los banos 70 kV area reinforcement (Q2-2028)

Coppermine 70 kV Reinforcement Project (Q2-2027)

Gates new bank project (2030)

Camden 70 kV reinforcement project (2030)


Reedley 70 kV reinforcement project (2030)

### J.3.2.6.2 Hanford Sub-area

Hanford is a sub-area of the Fresno LCR area.

#### J.3.2.6.2.1 Hanford LCR Sub-area Diagram

Figure J.3.2-38 Hanford LCR Sub-area



#### J.3.2.6.2.2 Hanford LCR Sub-area Load and Resources

Table J.3.2-36 provides the forecast load and resources in Hanford LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-36 Hanford LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load                   | 229        | Market, Net Seller                 | 133        | 133        |
| AAEE                         | -5         | Battery, Hybrid                    | 32         | 32         |
| Behind the meter DG          | -10        | MUNI, QF                           | 0          | 0          |
| <b>Net Load</b>              | <b>214</b> | Solar                              | 29         | 0          |
| Transmission Losses          | 5          | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>218</b> | <b>Total</b>                       | <b>194</b> | <b>163</b> |

### J.3.2.6.2.3 Hanford LCR Sub-area Hourly Profiles

Figure J.3.2-39 illustrates the forecast 2034 profile for the peak day for the Hanford LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-40 illustrates the forecast 2034 hourly profile for Hanford LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-39 Hanford LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-40 Hanford LCR Sub-area 2034 Forecast Hourly Profiles



### J.3.2.6.2.4 Hanford LCR Sub-area Requirement

Table J.3.2-37 identifies the sub-area requirements. The LCR Requirement for a Category P6 contingency is 19 MW.

Table J.3.2-37 Hanford LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                 | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-----------------------------------|---|--------------------------|
| 2034 | First Limit | P6       | Henrietta-Leprino Jct 115 kV line | McCall-Kingsburg #1 115kV line and McCall-Kingsburg #2 115kV line | 19                       |

### J.3.2.6.2.5 Effectiveness factors:

All units within the Hanford sub-area have the same effectiveness factor.


For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7430 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.2.6.3 Coalinga Sub-area

Coalinga is a sub-area of the Fresno LCR area.

#### J.3.2.6.3.1 Coalinga LCR Sub-area Diagram

Figure J.3.2-41 Coalinga LCR Sub-area



### J.3.2.6.3.2 Coalinga LCR Sub-area Load and Resources

Table J.3.2-38 provides the forecast load and resources in Coalinga LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-38 Coalinga LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC   | At Peak   |
|------------------------------|------------|------------------------------------|-----------|-----------|
| Gross Load                   | 161        | Market, Net Seller                 | 0         | 0         |
| AAEE                         | -2         | Battery, Hybrid                    | 10        | 10        |
| Behind the meter DG          | -4         | MUNI, QF                           | 1         | 1         |
| <b>Net Load</b>              | <b>155</b> | Solar                              | 14        | 0         |
| Transmission Losses          | 4          | Existing 20-minute Demand Response | 0         | 0         |
| Pumps                        | 0          | Mothballed                         | 0         | 0         |
| <b>Load + Losses + Pumps</b> | <b>159</b> | <b>Total</b>                       | <b>25</b> | <b>11</b> |

### J.3.2.6.3.3 Coalinga LCR Sub-area Hourly Profiles

Figure J.3.2-42 illustrates the forecast 2034 profile for the peak day for the Coalinga LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-43 illustrates the forecast 2034 hourly profile for Coalinga LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-42 Coalinga LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-43 Coalinga LCR Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.6.3.4 Coalinga LCR Sub-area Requirement

Table J.3.2-39 identifies the sub-area requirements. The LCR Requirement for a Category P6 contingency is 109 MW.

Table J.3.2-39 Coalinga LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                        | Contingency  | LCR (MW)<br>(Deficiency)     |
|------|-------------|----------|--|--|------------------------------|
| 2034 | First Limit | P6       | Gates-Jayne switching station 70 kV line | Gates-Coalinga #2 70 kV line and Schindler-Fivepoints Sw station | 109<br>(84 NQC)<br>(98 Peak) |

#### J.3.2.6.3.5 Effectiveness factors:

All units within the Coalinga Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7430 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.2.6.4 *Borden Sub-area*

Borden is a sub-area of the Fresno LCR area.


Borden Sub-area will be eliminated due to the Borden transformer capacity increase transmission project.

#### J.3.2.6.5 *Reedley Sub-area*

Reedley is a sub-area of the Fresno LCR area.

### J.3.2.6.5.1 Reedley LCR Sub-area Diagram

Figure J.3.2-44 Reedley LCR Sub-area



### J.3.2.6.5.2 Reedley LCR Sub-area Load and Resources

Table J.3.2-40 provides the forecast load and resources in Reedley LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-40 Reedley LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |     | Generation (MW)                    | Aug NQC   | At Peak   |
|------------------------------|-----|------------------------------------|-----------|-----------|
| Gross Load                   | 235 | Market, Net Seller                 | 41        | 41        |
| AAEE                         | -7  | Battery, Hybrid                    | 0         | 0         |
| Behind the meter DG          | -15 | MUNI, QF                           | 0         | 0         |
| <b>Net Load</b>              | 213 | LTPP Preferred Resources           | 0         | 0         |
| Transmission Losses          | 51  | Existing 20-minute Demand Response | 0         | 0         |
| Pumps                        | 0   | Mothballed                         | 0         | 0         |
| <b>Load + Losses + Pumps</b> | 264 | <b>Total</b>                       | <b>41</b> | <b>41</b> |

### J.3.2.6.5.3 Reedley LCR Sub-area Hourly Profiles

Figure J.3.2-45 illustrates the forecast 2034 profile for the peak day for the Reedley LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity

resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-46 illustrates the forecast 2034 hourly profile for Reedley LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-45 Reedley LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-46 Reedley LCR Sub-area 2034 Forecast Hourly Profiles



### J.3.2.6.5.4 Reedley LCR Sub-area Requirement

Table J.3.2-41 identifies the sub-area requirements. The LCR Requirement for a Category P6 contingency is 145 MW including 104 MW of deficiency.

Table J.3.2-41 Reedley LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility   | Contingency                                   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|---|---|--------------------------|
| 2034 | First Limit | P6       | Kings River-Sanger-Reedley 115 kV line with Wahtoke load online | McCall-Reedley 115 kV & Sanger-Reedley 115 kV | 145 (104)                |

### J.3.2.6.5.5 Effectiveness factors:

All units within the Reedley Sub-area have the same effectiveness factor.


For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7430 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.2.6.1 Panoche Sub-area

Panoche is a sub-area of the Fresno LCR area.

### J.3.2.6.1.1 Panoche LCR Sub-area Diagram

Figure J.3.2-47 Panoche LCR Sub-area



### J.3.2.6.1.2 Panoche LCR Sub-area Load and Resources

Table J.3.2-42 provides the forecast load and resources in Panoche LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-42 Panoche LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load                   | 570        | Market, Net Seller                 | 181        | 181        |
| AAEE                         | -9         | Battery, Hybrid                    | 0          | 0          |
| Behind the meter DG          | -21        | MUNI, QF                           | 104        | 104        |
| <b>Net Load</b>              | <b>539</b> | <b>Solar</b>                       | <b>46</b>  | <b>0</b>   |
| Transmission Losses          | 20         | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>559</b> | <b>Total</b>                       | <b>331</b> | <b>285</b> |

### J.3.2.6.1.3 Panoche LCR Sub-area Hourly Profiles

Figure J.3.2-48 illustrates the forecast 2034 profile for the peak day for the Panoche LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-49 illustrates the forecast 2034 hourly profile for Panoche LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-48 Panoche LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-49 Panoche LCR Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.6.1.4 Panoche LCR Sub-area Requirement

Table J.3.2-43 identifies the sub-area LCR requirements. The LCR Requirement for a Category P6 contingency is 382 MW.

Table J.3.2-43 Panoche LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                  | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|------------------------------------|--|--------------------------|
| 2034 | First limit | P6       | Five Points-Huron-Gates 70 kV line | Panoche 230/115 kV TB #2 and<br>Panoche 230/115 kV TB #3 | 382<br>(51 NQC, 97 Peak) |

#### J.3.2.6.1.5 Effectiveness factors:

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7430 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.2.6.2 Wilson 115 kV Sub-area


Wilson 115 kV sub-area will be eliminated due to the Wilson #3 230/115 kV transformer coming into service as part of the Wilson 115 kV area reinforcement transmission project.

#### J.3.2.6.3 Herndon Sub-area

Herndon is a sub-area of the Fresno LCR area.

## J.3.2.6.3.1 Herndon LCR Sub-area Diagram

Figure J.3.2-50 Herndon LCR Sub-area



## J.3.2.6.3.2 Herndon LCR Sub-area Load and Resources

Table J.3.2-44 provides the forecast load and resources in Herndon LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-44 Herndon LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|-------------|------------------------------------|------------|------------|
| Gross Load                   | 1813        | Market, Net Seller                 | 776        | 776        |
| AAEE                         | -47         | Battery, Hybrid                    | 48         | 48         |
| Behind the meter DG          | -102        | MUNI, QF                           | 121        | 121        |
| <b>Net Load</b>              | <b>1663</b> | Solar                              | <b>33</b>  | <b>0</b>   |
| Transmission Losses          | 35          | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0           | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>1698</b> | <b>Total</b>                       | <b>978</b> | <b>945</b> |

### J.3.2.6.3.3 Herndon LCR Sub-area Hourly Profiles

Figure J.3.2-51 illustrates the forecast 2034 profile for the peak day for the Herndon LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-52 illustrates the forecast 2034 hourly profile for Herndon LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-51 Herndon LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-52 Herndon LCR Sub-area 2034 Forecast Hourly Profiles



### J.3.2.6.3.4 Herndon LCR Sub-area Requirement

Table J.3.2-45 identifies the sub-area LCR requirements. The LCR Requirement for a Category P6 contingency is 775 MW.

Table J.3.2-45 Herndon LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility        | Contingency                         | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|--------------------------|-------------------------------------|--------------------------|
| 2034 | First limit | P6       | Herndon 230/115kV bank 3 | Herndon 230/115kV Bank 1 and Bank 2 | 775                      |

### J.3.2.6.3.5 Effectiveness factors:


Effectiveness factors for generators in the Herndon LCR sub-area are in Attachment B table titled [Herndon](#).

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7430 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.2.6.4 Fresno Area Overall

#### J.3.2.6.4.1 Fresno Overall Area Diagram

Figure J.3.2-53 Fresno Overall LCR Area



### J.3.2.6.4.2 Fresno Overall LCR Area Load and Resources

Table J.3.2-35 provides the forecast load and resources in Fresno LCR area in 2024. The list of generators within the LCR area are provided in Attachment A.

### J.3.2.6.4.3 Fresno Overall LCR Area Hourly Profiles

Figure J.3.2-54 illustrates the forecast 2034 profile for the peak day for the overall LCR area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-55 illustrates the forecast 2034 hourly profile for overall LCR area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-54 Greater Fresno Overall LCR Area 2034 Peak Day Forecast Profiles





Figure J.3.2-55 Greater Fresno Overall LCR Area 2034 Forecast Hourly Profiles



**J.3.2.6.4.4 Fresno Overall LCR Sub-area Requirement**

Table J.3.2-46 identifies the area LCR requirements. The LCR requirement Category P6 contingency is 2695 MW.

Table J.3.2-46 Fresno Overall LCR Area Requirements

| Year | Limit       | Category | Limiting Facility               | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|---------------------------------|--|--------------------------|
| 2034 | First limit | P6       | Kingsburg-Contadina 115 kV Line | Helm-Mc Call 230 kV Line and Mustang-Mc Call 230 kV line | 2695                     |

**J.3.2.6.4.5 Effectiveness factors:**

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7430 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.6.4.6 Changes compared to the 2029 LCT study**

The load forecast increased by 69 MW and the LCR has increased by 183 MW, due to load increase.

**J.3.2.7 Kern Area****J.3.2.7.1 Area Definition:**

The transmission facilities coming into the Kern PP sub-area are:

- Midway-Kern PP #1 230 kV Line
- Midway-Kern PP #2 230 kV Line
- Midway-Kern PP #3 230 kV Line
- Midway-Kern PP #4 230 kV Line
- Wind Gap-Wheeler Ridge #1 230 kV Line
- Wind Gap-Wheeler Ridge #2 230 kV Line
- Famoso-Lerdo 115 kV Line (Normal Open)
- Wasco-Famoso 70 kV Line (Normal Open)
- Copus-Old River 70 kV Line (Normal Open)
- Copus-Old River 70 kV Line (Normal Open)
- Weedpatch CB 32 70 kV (Normal Open)

The substations that delineate the Kern-PP sub-area are:

Midway 230 kV is out and Bakersfield 230 kV is in

Midway 230 kV is out Kern PP 230 kV is in

Midway 230 kV is out and Stockdale 230 kV is in

Midway 230 kV is out Kern PP 230 kV is in

Wind Gap 230 kV is out Wheeler Ridge 230 kV is in

Wind Gap 230 kV is out Wheeler Ridge 230 kV is in

Famoso 115 kV is out Cawelo 115 kV is in

Wasco 70 kV is out Mc Farland 70 kV is in


Copus 70 kV is out, South Kern Solar 70 kV is in

Lakeview 70 kV is out, San Emidio Junction 70 kV is in

Weedpatch 70 kV is out, Wellfield 70 kV is in

### J.3.2.7.1.1 Kern LCR Area Diagram

Figure J.3.2-56 Kern LCR Area



**J.3.2.7.1.2 Kern LCR Area Load and Resources**

Table J.3.2-47 provides the forecast load and resources in Kern LCR area in 2034. The list of generators within the LCR area are provided in Attachment A.

In year 2034 the estimated time of local area peak is 19:00 PM.

At the local area peak time the estimated, ISO metered, solar output is 0.00%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-47 Kern LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                    | Aug NQC    | At Peak   |
|------------------------------|-------------|------------------------------------|------------|-----------|
| Gross Load                   | 1013        | Market, Net Seller                 | 49         | 49        |
| AAEE                         | -15         | Battery                            | 20         | 20        |
| Behind the meter DG          | 0           | MUNI, QF                           | 0          | 0         |
| <b>Net Load</b>              | <b>1000</b> | Solar                              | 43         | 0         |
| Transmission Losses          | 11          | Existing 20-minute Demand Response | 9          | 9         |
| Pumps                        | 0           | Mothballed                         | 0          | 0         |
| <b>Load + Losses + Pumps</b> | <b>1011</b> | <b>Total</b>                       | <b>121</b> | <b>78</b> |

**J.3.2.7.1.3 Approved transmission projects modeled**

Midway-Temblor 115 kV Line Reconductor & Voltage Support

Bakersfield Nos. 1 and 2 230 kV Tap Lines Reconductoring

Kern PP 115 kV area reinforcement project

Wheeler Ridge Junction Station Project

**J.3.2.7.2 Kern PP 70 kV Sub-area**

Kern PP 70 kV is a sub-area of the Kern LCR area.

The Kern PP 70 kV Sub-area has been eliminated due to load changes and project modeling changes in the area.

**J.3.2.7.3 Westpark Sub-area**

Westpark is a sub-area of the Kern LCR area.

**J.3.2.7.3.1 Westpark LCR Sub-area Diagram**

Please see Figure J.3.2-56 for Westpark sub-area diagram.

### J.3.2.7.3.2 Westpark LCR Sub-area Load and Resources

Table J.3.2-48 provides the forecast load and resources in Westpark LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-48 Westpark LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC  | At Peak  |
|------------------------------|------------|------------------------------------|----------|----------|
| Gross Load                   | 120        | Market, Net Seller                 | 0        | 0        |
| AAEE                         | -5         | Battery                            | 0        | 0        |
| Behind the meter DG          | 0          | MUNI, QF                           | 0        | 0        |
| <b>Net Load</b>              | <b>115</b> | Solar                              | 0        | 0        |
| Transmission Losses          | 0          | Existing 20-minute Demand Response | 0        | 0        |
| Pumps                        | 0          | Mothballed                         | 0        | 0        |
| <b>Load + Losses + Pumps</b> | <b>115</b> | <b>Total</b>                       | <b>0</b> | <b>0</b> |

### J.3.2.7.3.3 Westpark LCR Sub-area Hourly Profiles

Figure J.3.2-57 illustrates the forecast 2034 profile for the peak day for the Westpark LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-58 illustrates the forecast 2034 hourly profile for Westpark LCR sub-area with the Category P6 contingency transmission capability without local capacity resources.

Figure J.3.2-57 Westpark LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-58 Westpark LCR Sub-area 2034 Forecast Hourly Profiles



### J.3.2.7.3.4 Westpark LCR Sub-area Requirement

Table J.3.2-49 identifies the sub-area LCR requirements. The LCR requirement for Category P7 contingency is 20 MW with a 20 MW of deficiency.

Table J.3.2-49 Westpark LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                      | Contingency                   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|--|-------------------------------|--------------------------|
| 2034 | First Limit | P7       | Magunden – Magunden Jct<br>115 kV line | Kern-West Park #1 & #2 115 kV | 20 (20)                  |

### J.3.2.7.3.5 Effectiveness factors:

All units within the Westpark Sub-area have the same effectiveness factor.


For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7450 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.2.7.4 Kern Oil Sub-area

Kern Oil is a sub-area of the Kern LCR area.

## J.3.2.7.4.1 Kern Oil LCR Sub-area Diagram

Figure J.3.2-59 Kern Oil LCR Sub-area



## J.3.2.7.4.2 Kern Oil LCR Sub-area Load and Resources

Table J.3.2-50 provides the forecast load and resources in Kern Oil LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-50 Kern Oil LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC   | At Peak   |
|------------------------------|------------|------------------------------------|-----------|-----------|
| Gross Load                   | 363        | Market, Net Seller                 | 41        | 41        |
| AAEE                         | -6         | Battery                            | 0         | 0         |
| Behind the meter DG          | 13         | MUNI, QF                           | 0         | 0         |
| <b>Net Load</b>              | <b>344</b> | Solar                              | 4         | 0         |
| Transmission Losses          | 2          | Existing 20-minute Demand Response | 0         | 0         |
| Pumps                        | 0          | Mothballed                         | 0         | 0         |
| <b>Load + Losses + Pumps</b> | <b>346</b> | <b>Total</b>                       | <b>45</b> | <b>41</b> |

### J.3.2.7.4.3 Kern Oil LCR Sub-area Hourly Profiles

Figure J.3.2-60 illustrates the forecast 2034 profile for the peak day for the Kern Oil LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-61 illustrates the forecast 2034 hourly profile for Kern Oil LCR sub-area with the Category P6 contingency transmission capability without local capacity resources.

Figure J.3.2-60 Kern Oil LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-61 Kern Oil LCR Sub-area 2034 Forecast Hourly Profiles



**J.3.2.7.4.4 Kern Oil LCR Sub-area Requirement**

Table J.3.2-51 identifies the sub-area LCR requirements. The LCR requirement for Category Category P6 contingency LCR requirement is 178 MW with a 133 MW NQC deficiency (137 MW peak deficiency).

Table J.3.2-51 Kern Oil LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                               | Contingency-  | LCR (MW)<br>(Deficiency)      |
|------|-------------|----------|---|---|-------------------------------|
| 2034 | First Limit | P6       | Kern Power to Kern<br>Water 115 kV line section | Kern PP-7th Standard 115 kV lines<br>& Kern PP-Live Oak 115 kV Line | 178<br>(133 NQC/<br>137 Peak) |

**J.3.2.7.4.5 Effectiveness factors:**

All units within the Kern Oil Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7450 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.7.5 Kern PP-Tevis 115 kV Sub-area**

Kern PP-Tevis 115 kV is a sub-area of the Kern LCR area.


The sub-area is removed by the Wheeler Ridge Junction project.

**J.3.2.7.6 South Kern PP Sub-area**

South Kern PP is a sub-area of the Kern LCR area.

**J.3.2.7.6.1 South Kern PP LCR Sub-area Diagram**

Figure J.3.2-62 South Kern PP LCR Sub-area



### J.3.2.7.6.2 South Kern PP LCR Sub-area Load and Resources

Refer to Table J.3.2-47 Kern Area Load and Resources table.

### J.3.2.7.6.3 South Kern PP LCR Sub-area Hourly Profiles

Figure J.3.2-63 illustrates the forecast 2034 profile for the summer peak, winter peak and spring off-peak days for the South Kern PP LCR sub-area with the Category P6 contingency transmission capability without resources. Figure J.3.2-64 illustrates the forecast 2034 hourly profile for South Kern PP LCR sub-area with the Category P6 contingency transmission capability without resources.

Figure J.3.2-63 South Kern PP LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-64 South Kern Overall LCR Area 2034 Forecast Hourly Profiles



**J.3.2.7.6.4 South Kern PP LCR Sub-area Requirement**

Table J.3.2-52 identifies the sub-area LCR requirements. The LCR requirement for Category P6 contingency is 283 MW with a 162 MW NQC deficiency (205 MW peak deficiency).

Table J.3.2-52 South Kern PP LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility       | Contingency  | LCR (MW)<br>(Deficiency)   |
|------|-------------|----------|-------------------------|--|----------------------------|
| 2034 | First Limit | P6       | Kern 230/115 kV T/F # 5 | Kern 230/115 kV T/F # 3 &<br>Kern 230/115 kV T/F # 4 | 283<br>(162 NQC/ 205 Peak) |

**J.3.2.7.6.5 Effectiveness factors:**

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7450 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.7.7 Kern Area Overall Requirements****J.3.2.7.7.1 Kern LCR Area Overall Requirement**

Table J.3.2-53 identifies the limiting facility and contingency that establishes the Kern Area 2034 LCR requirements. The LCR requirement for Category P6 contingency the LCR requirement is 283 MW with a 162 MW NQC deficiency or 205 MW of at peak deficiency.

Table J.3.2-53 Kern Overall LCR Sub-area Requirements

| Year | Limit | Category | Limiting Facility       | Contingency | LCR (MW)<br>(Deficiency)   |
|------|-------|----------|-------------------------|-------------|----------------------------|
| 2034 | N/A   | P6       | Aggregate of Sub-areas. |             | 283<br>(162 NQC/ 205 Peak) |

**J.3.2.7.7.2 Changes compared to the 2029 LCT study**

Compared to the 2029, the load has increased by 109 MW and the LCR requirement has increased by 42 MW due to load forecast increase and increase in rating for the limiting element.

### J.3.2.8 Big Creek/Ventura Area

#### J.3.2.8.1 Area Definition:

The transmission tie lines into the Big Creek/Ventura Area are:


- Antelope #1 500/230 kV Transformer
- Antelope #2 500/230 kV Transformer
- Sylmar - Pardee 230 kV #1 and #2 Lines
- Vincent - Pardee 230 kV #2 Line
- Vincent - Santa Clara 230 kV Line

The substations that delineate the Big Creek/Ventura Area are:

- Antelope 500 kV is out Antelope 230 kV is in
- Antelope 500 kV is out Antelope 230 kV is in
- Sylmar is out Pardee is in
- Vincent is out Pardee is in
- Vincent is out Santa Clara is in

#### J.3.2.8.1.1 Big Creek/Ventura LCR Area Diagram

Figure J.3.2-65 Big Creek/Ventura LCR Area



### J.3.2.8.1.2 Big Creek/Ventura LCR Area Load and Resources

Table J.3.2-54 provides the forecast load and resources in the Big Creek/Ventura LCR area in 2034. The list of generators within the LCR area are provided in Attachment A and does not include new LTPP Preferred resources or existing DR.

In year 2034 the estimated time of local area peak is hour ending 18:00 PST (HE 19:00 PDT).

At the local area peak time the estimated, ISO-metered solar output is 0.0%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-54 Big Creek/Ventura LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                       | Aug NQC     | At Peak     |
|------------------------------|-------------|---------------------------------------|-------------|-------------|
| Gross Load                   | 5268        | Market, Net Seller, Wind              | 1946        | 1946        |
| AAEE                         | -128        | Battery                               | 2057        | 2057        |
| Behind the meter DG          | 0           | MUNI, QF                              | 399         | 399         |
| <b>Net Load</b>              | <b>5140</b> | Solar                                 | 343         | 0           |
| Transmission Losses          | 97          | Other preferred resources and storage | 0           | 0           |
| Pumps                        | 233         | Existing Demand Response              | 63          | 63          |
| <b>Load + Losses + Pumps</b> | <b>5470</b> | <b>Total</b>                          | <b>4808</b> | <b>4465</b> |

### J.3.2.8.1.3 Approved transmission projects modeled:

Pardee-Sylmar 230 kV Rating Increase Project (ISD- October 2027)

### J.3.2.8.2 Rector Sub-area


LCR need is satisfied by the need in the larger Vestal sub-area.

### J.3.2.8.3 Vestal Sub-area

Vestal is a sub-area of the Big Creek/Ventura LCR area.

### J.3.2.8.3.1 Vestal LCR Sub-area Diagram

Figure J.3.2-66 Vestal LCR Sub-area



### J.3.2.8.3.2 Vestal LCR Sub-area Load and Resources

Table J.3.2-55 provides the forecast load and resources in Vestal LCR sub-area in 2034. The list of generators within the LCR sub-area is provided in Attachment A.

Table J.3.2-55 Vestal LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                       | Aug NQC     | At Peak     |
|------------------------------|-------------|---------------------------------------|-------------|-------------|
| Gross Load                   | 1461        | Market, Net Seller, Wind              | 965         | 965         |
| AAEE                         | -41         | Battery, Hybrid                       | 472         | 472         |
| Behind the meter DG          | -38         | MUNI, QF                              | 0           | 0           |
| <b>Net Load</b>              | <b>1382</b> | Solar                                 | 84          | 0           |
| Transmission Losses          | 22          | Other preferred resources and storage | 0           | 0           |
| Pumps                        | 0           | Existing 20-minute Demand Response    | 30          | 30          |
| <b>Load + Losses + Pumps</b> | <b>1404</b> | <b>Total</b>                          | <b>1551</b> | <b>1467</b> |

### J.3.2.8.3.3 Vestal LCR Sub-area Hourly Profiles

Figure J.3.2-67 illustrates the forecast 2034 profile for the peak day for the Vestal LCR sub-area along with the Category P3 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-68 illustrates the forecast 2034 hourly profile for Vestal LCR sub-area along with the Category P3 emergency load serving capability without local capacity resources.

Figure J.3.2-67 Vestal LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-68 Vestal Sub-area 2034 Forecast Hourly Profile



#### J.3.2.8.3.4 Vestal LCR Sub-area Requirement

Table J.3.2-56 identifies the sub-area LCR requirements. The 2034 LCR requirement for Category P3 contingency is 541 MW.

Table J.3.2-56 Vestal LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                 | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-----------------------------------|---|--------------------------|
| 2034 | First Limit | P3       | Magunden–Vestal #1<br>230 kV line | Magunden–Vestal #2 line with<br>Eastwood out of service | 541                      |

#### J.3.2.8.3.5 Effectiveness factors:

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7500 posted at: <http://www.aiso.com/Documents/2210Z.pdf>

#### J.3.2.8.4 Goleta Sub-area

Goleta is a sub-area of the Big Creek/Ventura LCR area.


The LCR need is satisfied by the need in the larger Santa Clara sub-area.

#### J.3.2.8.5 Santa Clara Sub-area

Santa Clara is a sub-area of the Big Creek/Ventura LCR area.

### J.3.2.8.5.1 Santa Clara LCR Sub-area Diagram

Figure J.3.2-69 Santa Clara LCR Sub-area



### J.3.2.8.5.2 Santa Clara LCR Sub-area Load and Resources

Table J.3.2-57 provides the forecast load and resources in Santa Clara LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-57 Santa Clara LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)                       | Aug NQC    | At Peak    |
|------------------------------|-------------|---------------------------------------|------------|------------|
| Gross Load                   | 1075        | Market                                | 144        | 144        |
| AAEE                         | -21         | Battery                               | 436        | 436        |
| Behind the meter DG          | -26         | MUNI, QF                              | 87         | 87         |
| <b>Net Load</b>              | <b>1028</b> | Solar                                 | 0          | 0          |
| Transmission Losses          | 7           | Existing Demand Response              | 6          | 6          |
| Pumps                        | 0           | Other preferred resources and storage | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>1035</b> | <b>Total</b>                          | <b>673</b> | <b>673</b> |

### J.3.2.8.5.3 Santa Clara LCR Sub-area Hourly Profiles

Figure J.3.2-70 illustrates the forecast 2034 profile for the peak day for the Santa Clara sub-area along with the Category P1+P7 load serving capability without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-71 illustrates the forecast 2034 hourly profile for Santa Clara sub-area along with the Category P1+P7 emergency load serving capability without local capacity resources.

Figure J.3.2-70 Santa Clara LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-71 Santa Clara Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.8.5.4 Santa Clara LCR Sub-area Requirement

Table J.3.2-58 identifies the sub-area requirement. The 2034 LCR requirement for Category P1 + P7 contingency is 424 MW.

Table J.3.2-58 Santa Clara LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-------------------|--|--------------------------|
| 2034 | First Limit | P1 + P7  | Voltage collapse  | Pardee - Santa Clara 230 kV followed by<br>Moorpark - Santa Clara #1 & #2 230 kV | 424                      |

#### J.3.2.8.5.5 Effectiveness factors:

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7500, 7510, 7550 , 7680 and 8610 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.2.8.6 Moorpark Sub-area

Moorpark is a sub-area of the Big Creek/Ventura LCR area.

No requirement is identified for the sub-area due to the Pardee-Moorpark No. 4 230 kV Transmission Project.

#### J.3.2.8.7 Big Creek/Ventura Overall

##### J.3.2.8.7.1 Big Creek/Ventura LCR Sub-area Hourly Profiles

Figure J.3.2-72 illustrates the forecast 2034 profile for the peak day for Big Creek/Ventura area along with the Category P6 normal and emergency load serving capability without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-73 illustrates the forecast 2034 hourly profile for Santa Clara sub-area along with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.2-72 Big Creek/Ventura LCR area 2034 Peak Day Forecast Profiles





Figure J.3.2-73 Big Creek/Ventura LCR area 2034 Peak Day Forecast Profiles



### J.3.2.8.7.2 Big Creek/Ventura LCR area Requirement

Table J.3.2-59 identifies the area LCR requirements. The LCR requirement for Category P6 contingency is 1,462 MW.

Table J.3.2-59 Big Creek/Ventura LCR area Requirements

| Year | Limit       | Category | Limiting Facility                | Contingency   | LCR (MW) |
|------|-------------|----------|----------------------------------|---|----------|
| 2034 | First limit | P6       | Remaining Sylmar - Pardee 230 kV | Lugo - Victorville 500 kV line followed by one of the Sylmar - Pardee #1 or #2 230 kV lines | 1462     |

### J.3.2.8.7.3 Effectiveness factors:

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7500, 7510, 7550, 7680 and 8610 posted at: <http://www.aiso.com/Documents/2210Z.pdf>

### J.3.2.8.7.4 Changes compared to the 2029 LCT study

The load forecast is up by 286 MW and the LCR went up by 133 MW mostly due to load increase.

**J.3.2.9 LA Basin Area****J.3.2.9.1 Area Definition:**

The transmission tie lines into the LA Basin Area are:

- San Onofre - San Luis Rey #1, #2, and #3 230 kV Lines
- San Onofre - Talega #2 230 kV Line
- San Onofre - Capistrano #1 230 kV Line
- Lugo - Mira Loma #2 & #3 500 kV Lines
- Lugo - Rancho Vista #1 500 kV Line
- Vincent – Mesa 500 kV Line
- North of SONGS – Imperial Valley 500 kV Line
- Sylmar - Eagle Rock 230 kV Line
- Sylmar - Gould 230 kV Line
- Vincent - Mesa #1 & #2 230 kV Lines
- Vincent - Rio Hondo #1 & #2 230 kV Lines
- Devers - Red Bluff 500 kV #1 and #2 Lines
- Mirage – Coachella Valley # 1 230 kV Line
- Mirage - Ramon # 1 & #2 230 kV Line
- Mirage - Julian Hinds 230 kV Line
- Devers – Ramon 230 kV Line

The substations that delineate the LA Basin Area are:

- San Onofre is in San Luis Rey is out
- San Onofre is in Talega is out
- San Onofre is in Capistrano is out
- Mira Loma is in Lugo is out
- Rancho Vista is in Lugo is out
- Eagle Rock is in Sylmar is out
- Gould is in Sylmar is out
- Mira Loma is in Vincent is out
- Mesa is in Vincent is out
- North of SONGS is in Imperial Valley is out
- Rio Hondo is in Vincent is out

Devers is in Red Bluff is out

Mirage is in Coachella Valley is out


Mirage is in Ramon is out

Mirage is in Julian Hinds is out

Devers is in Ramon is out

### J.3.2.9.1.1 LA Basin LCR Area Diagram

Figure J.3.2-74 LA Basin LCR Area



### J.3.2.9.1.2 LA Basin LCR Area Load and Resources

Table J.3.2-60 provides the forecast load and resources in the LA Basin LCR area in 2034. The list of generators within the LCR area are provided in Attachment A and does not include LTPP Preferred resources or DR.

In year 2034 the estimated time of local area peak is 6:00 PM (PDT) on September 6, 2034.

At the local area peak time the estimated, ISO metered, solar output is 11%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-60 LA Basin LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                                 | Aug NQC      | At Peak      |
|------------------------------|--------------|---|--------------|--------------|
| Gross Load (inc. ATE & FS)   | 18992        | Market, Net Seller, Wind                        | 5214         | 5214         |
| AAEE, AAFS & AATE            | 1871         | Battery, Hybrid                                 | 4374         | 4374         |
| Behind the meter DG          | -591         | MUNI, QF  | 1049         | 1049         |
| <b>Net Load</b>              | <b>20272</b> | Solar   | 64           | 64           |
| Transmission Losses          | 325          | Existing Demand Response                        | 428          | 428          |
| Pumps                        | 0            | LTPP Preferred Resources (BTM BESS, EE, DR, PV) | 173          | 173          |
| <b>Load + Losses + Pumps</b> | <b>20597</b> | <b>Total</b>                                    | <b>11302</b> | <b>11302</b> |

**J.3.2.9.1.3 Approved transmission projects modeled:**

Mesa Loop-In Project and Laguna Bell Corridor 230 kV line upgrades

Delaney – Colorado River 500 kV Line (Ten West Link Project) and Cielo Azul 500 kV Switchyard

Hassayampa – North Gila #2 500 kV Line (APS)

West of Devers 230 kV line upgrades

Lugo – Victorville 500 kV Upgrade

Alberhill 500 kV Method of Service

Laguna Bell – Mesa No. 1 230 kV Line Rating Increase Project

Pardee – Sylmar 230 kV Line Rating Increase Project

Serrano 4AA 500/230 kV Transformer Bank Addition

Sylmar Transformer Replacement Project

Antelope – Whirlwind 500 kV Line Upgrade Project

Devers – Red Bluff 500 kV Lines #1 and 2 Upgrade

Colorado River – Red Bluff 500 kV Line #1 Upgrade

Devers – Valley 500 kV Line #1 Upgrade

Serrano – Alberhill – Valley 500 kV Line #1 Upgrade

Mira Loma – Mesa 500 kV Underground Third Cable

San Bernardino – Etiwanda 230 kV Line #1 Upgrade

Serrano – Del Amo – Mesa 500 kV Transmission Reinforcement

Antelope – Whirlwind 500 kV Line Upgrade Project

Serrano – North of SONGS 500 kV Line

Imperial Valley – North of SONGS 500 kV Line and Substation

Retirement of 1,356 MW of the existing Redondo Beach OTC generation

Alamitos repowering (640 MW)

Alamitos Battery Energy Storage System (179 MW)

Retirement of 2,010 MW of the existing Alamitos OTC generation

Huntington Beach repowering (644 MW)

Retirement of 452 MW of the existing Huntington Beach OTC generation

Stanton Energy Reliability Center (98 MW)

### J.3.2.9.2 *El Nido Sub-area*

El Nido is a sub-area of the LA Basin LCR area.

#### J.3.2.9.2.1 **El Nido LCR Sub-area Diagram**

Please refer to Figure J.3.2-74 above.

#### J.3.2.9.2.2 **El Nido LCR Sub-area Load and Resources**

Table J.3.2-61 provides the forecast load and resources in El Nido LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-61 El Nido LCR Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC    | At Peak    |
|------------------------------|-------------|--------------------------|------------|------------|
| Gross Load                   | 944         | Market, Net Seller, Wind | 546        | 546        |
| AAEE, AAFS and AATE          | 104         | Battery                  | 133        | 133        |
| Behind the meter DG          | -27         | MUNI, QF                 | 0          | 0          |
| <b>Net Load</b>              | <b>1021</b> | Solar                    | 0          | 0          |
| Transmission Losses          | 2           | Existing Demand Response | 12         | 12         |
| Pumps                        | 0           | LTPP Preferred Resources | 10         | 10         |
| <b>Load + Losses + Pumps</b> | <b>1023</b> | <b>Total</b>             | <b>701</b> | <b>701</b> |

#### J.3.2.9.2.3 **El Nido LCR Sub-area Hourly Profiles**

Figure J.3.2-75 illustrates the forecasted 2034 profile for the peak day for the El Nido LCR sub-area with the Category P7 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-76 illustrates the

forecasted 2034 hourly profile for El Nido LCR sub-area with the Category P7 normal and emergency load serving capability without local capacity resources.

Figure J.3.2-75 El Nido LCR Sub-area 2034 Peak Day Forecast Profile





Figure J.3.2-76 El Nido LCR Sub-area 2034 Forecast Hourly Profile



#### J.3.2.9.2.4 El Nido LCR Sub-area Requirement

Table J.3.2-62 identifies the sub-area requirements. The LCR requirement for Category P7 contingency is 432 MW. The LCR need increases when compared with the 2029 LCR need (284 MW) due to higher demand forecast for the El Nido sub-area.

Table J.3.2-62 El Nido LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility          | Contingency                       | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|----------------------------|-----------------------------------|--------------------------|
| 2034 | First Limit | P7       | La Fresa-La Cienega 230 kV | La Fresa – El Nido #3 & #4 230 kV | 432                      |

**J.3.2.9.2.5 Effectiveness factors:**

All units within the El Nido Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7630 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.2.9.3 Western LA Basin Sub-area**

Western LA Basin is a sub-area of the LA Basin LCR area.

**J.3.2.9.3.1 Western LA Basin LCR Sub-area Diagram**

Please refer to Figure J.3.2-74 above.

**J.3.2.9.3.2 Western LA Basin LCR Sub-area Load and Resources**

Table J.3.2-63 provides the forecast load and resources in Western LA Basin LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-63 Western LA Basin Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                                 | Aug NQC     | At Peak     |
|------------------------------|--------------|---|-------------|-------------|
| Gross Load                   | 11129        | Market, Net Seller, Wind                        | 3391        | 3391        |
| AAEE, AAFS and AATE          | 1211         | Battery, Hybrid                                 | 1978        | 1978        |
| Behind the meter DG          | -356         | MUNI, QF  | 593         | 593         |
| <b>Net Load</b>              | <b>11984</b> | Solar   | 8           | 8           |
| Transmission Losses          | 180          | Existing Demand Response                        | 355         | 355         |
| Pumps                        |              | LTPP Preferred Resources (BTM BESS, EE, DR, PV) | 135         | 135         |
| <b>Load + Losses + Pumps</b> | <b>12164</b> | <b>Total</b>                                    | <b>6460</b> | <b>6460</b> |

**J.3.2.9.3.3 Western LA Basin LCR Sub-area Hourly Profiles**

Figure J.3.2-77 illustrates the forecasted 2034 profile for the peak day for the Western LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be

added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-78 illustrates the forecasted 2034 hourly profile for Western LCR sub-area with the Category P6 normal and emergency load serving capability without local capacity resources.

Figure J.3.2-77 Western LA Basin LCR Sub-area 2034 Peak Day Forecast Profile





Figure J.3.2-78 Western LA Basin LCR Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.9.3.4 Western LA Basin LCR Sub-area Requirement

Table J.3.2-64 identifies the sub-area LCR requirements. The LCR requirement for Category P6 contingency is 726 MW. The 2034 LCR need is lower than 2029 LCR need (3053 MW) due to implementation of CAISO Board-approved policy driven bulk transmission upgrades despite higher load forecast for the western LA Basin sub-area.

Table J.3.2-64 Western LA Basin LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility  | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|--|---|--------------------------|
| 2034 | First Limit | P6       | Low voltage at Mesa and Del Amo 500 kV buses (below 498.8 kV minimum post-contingency limit) | Imperial Valley – North of SONGS 500 kV line, followed by Alberhill – Serrano 500 kV line (or vice versa) | 726                      |

**J.3.2.9.3.5 Effectiveness factors:**

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7630 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

There are other combinations of contingencies in the area that could overload a significant number of 230 kV lines in this sub-area have less LCR need. As such, anyone of them (combination of contingencies) could become binding for any given set of procured resources. As a result, these effectiveness factors may not be the best indicator towards informed procurement.

**J.3.2.9.4 West of Devers Sub-area**

West of Devers is a sub-area of the LA Basin LCR area.

There are no local capacity requirements due to implementation of the Mesa Loop-in as well as West of Devers reconductoring projects.

**J.3.2.9.5 Valley-Devers Sub-area**

Valley-Devers is a sub-area of the LA Basin LCR area.

There are no local capacity requirements due to implementation of the Colorado River-Delaney 500 kV line project.

**J.3.2.9.6 Valley Sub-area**

Valley is a sub-area of the LA Basin LCR area.

There are no local capacity requirements due to implementation of the Colorado River-Delaney 500 kV line project.

**J.3.2.9.7 Eastern LA Basin Sub-area**

Eastern LA Basin is a sub-area of the LA Basin LCR area.

**J.3.2.9.7.1 Eastern LA Basin LCR Sub-area Diagram**

Please refer to Figure J.3.2-74 above.

### J.3.2.9.7.2 Eastern LA Basin LCR Sub-area Load and Resources

Table J.3.2-65 provides the forecast load and resources in Eastern LA Basin LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-65 Eastern LA Basin Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC     | At Peak     |
|------------------------------|-------------|--------------------------|-------------|-------------|
| Gross Load                   | 7864        | Market, Net Seller, Wind | 1823        | 1823        |
| AAEE, AAFS and AATE          | 660         | Battery, Hybrid          | 2396        | 2396        |
| Behind the meter DG          | -235        | MUNI, QF                 | 456         | 456         |
| <b>Net Load</b>              | <b>8289</b> | Solar                    | 56          | 56          |
| Transmission Losses          | 124         | Existing Demand Response | 205         | 205         |
| Pumps                        | 20          | LTPP Preferred Resources | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>8433</b> | <b>Total</b>             | <b>4936</b> | <b>4936</b> |

### J.3.2.9.7.3 Eastern LA Basin LCR Sub-area Hourly Profiles

Figure J.3.2-79 illustrates the forecasted 2034 profile for the peak day for the Eastern LCR sub-area with the Category P1+P7 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.2-80 illustrates the forecasted 2034 hourly profile for Eastern LCR sub-area with the Category P1+P7 normal and emergency load serving capability without local capacity resources.

Figure J.3.2-79 Eastern LA Basin LCR Sub-area 2034 Peak Day Forecast Profile





Figure J.3.2-80 Eastern LA Basin LCR Sub-area 2034 Forecast Hourly Profiles



#### J.3.2.9.7.4 Eastern LA Basin LCR Sub-area Requirement

Table J.3.2-66 identifies the sub-area LCR requirements. The LCR requirement for Category P1+P7 contingency is 4174 MW. The 2034 LCR need for the Eastern LA Basin is higher than the 2029 local capacity need (2023 MW) due to higher demand forecast as well as having lower LCR need in the Western LA Basin. Both the Eastern and Western LA Basin sub-areas interact with each other. When the LCR need is lower in the Western LA Basin, the LCR need in the Eastern LA Basin increases to provide voltage support under critical contingency condition. Further voltage support devices such as synchronous condensers, or other reactive support devices may be considered potential cost-effective mitigation option to address post-contingency low voltage concern.

Table J.3.2-66 Eastern LA Basin LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|----------------------------------|---|--------------------------|
| 2034 | First Limit | P1+P7    | Post transient voltage stability | Lugo-Rancho Vista 500 kV, followed by Lugo-Mira Loma #2 and #3 500 kV | 4174                     |

#### J.3.2.9.7.5 Effectiveness factors:

All units within the Eastern LA Basin Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7750 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.2.9.8 LA Basin Overall

#### J.3.2.9.8.1 LA Basin LCR area Hourly Profiles

Figure J.3.2-81 illustrates the forecasted 2034 profile for the peak day for the LA Basin LCR area with the approximate total normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-82 illustrates the forecasted 2034 hourly profile for LA Basin LCR area with the normal and emergency load serving transmission capability without local capacity resources.

Figure J.3.2-81 Overall LA Basin LCR Area 2034 Peak Day Forecast Profile





Figure J.3.2-82 Overall LA Basin LCR area 2034 Forecast Hourly Profiles



The following is a summary of estimated amount of storage for the sub-areas and the overall area based on maximum charging capability perspective. Due to non-linearity of power system and the various critical contingencies and load shapes for each sub-area and the overall area, it is noted that the estimated maximum amount of storage for the sub-areas may not add up to be sum of the overall area. The estimated maximum amount of storage for the LCR area is the amount listed in the last row in the table.

Table J.3.2-67 Estimated LA Basin Sub-areas and Overall Area Energy Storage Capacity and Energy Based on Maximum Charging Capability Perspective

| Area/Sub-area                      | Estimated Energy Storage Maximum Capacity (MW) | Estimated Energy Storage Maximum Energy (MWh) | Estimated Maximum 4-hour Energy Storage |
|------------------------------------|--|---|---|
| El Nido sub-area                   | 201  | 1512  | 47                                      |
| Western LA Basin sub-area          | 726  | 2149  | 180                                     |
| Eastern LA Basin sub-area          | 1730   | 11111   | 180                                     |
| Overall LA Basin area <sup>5</sup> | 2456   | 13260   | 360                                     |

### J.3.2.9.8.2 Overall LA Basin LCR area Requirement

Table J.3.2-68 identifies the area's LCR requirement. The LCR requirement is driven by the sum of the LCR needs for the Western LA Basin and Eastern LA Basin sub-areas, at 4900 MW.

Table J.3.2-68 LA Basin LCR area Requirements

| Year | Limit       | Category | Limiting Facility           | Contingency | LCR (MW) (Deficiency) |
|------|-------------|----------|-----------------------------|-------------|-----------------------|
| 2034 | First Limit | N/A      | Sum of Western and Eastern. |             | 4900                  |

### J.3.2.9.8.3 Effectiveness factors:

See Attachment B - Table titled [LA Basin](#).

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7550, 7570, 7580, 7590, 7590, 7680 and 7750 posted at: <http://www.aiso.com/Documents/2210Z.pdf>

There are other combinations of contingencies in the area that could overload a significant number of 230 kV lines in this sub-area have less LCR need. As such, anyone of them (combination of contingencies) could become binding for any given set of procured resources.

<sup>5</sup> Total for the overall LA Basin includes the addition of the Western and Eastern LA Basin storage capacity charging capability values. The El Nido sub-area is located within the Western LA Basin sub-area.

As a result, these effectiveness factors may not be the best indicator towards informed procurement.

#### **J.3.2.9.8.4 Changes compared to the 2029 LCT study**

The load forecast is higher by 1,001 MW. The LCR need has decreased by 176 MW primarily due to CAISO Board-approved transmission upgrades in the Western LA Basin.

### **J.3.2.10 San Diego-Imperial Valley Area**

#### **J.3.2.10.1 Area Definition:**

The transmission tie lines forming a boundary around the Greater San Diego-Imperial Valley area include:


- Imperial Valley – North Gila 500 kV Line
- Otay Mesa – Tijuana 230 kV Line
- San Onofre - San Luis Rey #1 230 kV Line
- San Onofre - San Luis Rey #2 230 kV Line
- San Onofre - San Luis Rey #3 230 kV Line
- San Onofre – Talega 230 kV Line
- San Onofre – Capistrano 230 kV Line
- Imperial Valley – Wixom 230 kV Line
- Imperial Valley – La Rosita 230 kV Line

The substations that delineate the Greater San Diego-Imperial Valley area are:

- Imperial Valley is in North Gila is out
- Otay Mesa is in Tijuana is out
- San Onofre is out San Luis Rey is in
- San Onofre is out San Luis Rey is in
- San Onofre is out San Luis Rey is in
- San Onofre is out Talega is in
- San Onofre is out Capistrano is in
- Imperial Valley is in Wixom is out
- Imperial Valley is in La Rosita is out

### J.3.2.10.1.1 San Diego-Imperial Valley LCR Area Diagram

Figure J.3.2-83 San Diego-Imperial Valley LCR Area



### J.3.2.10.1.2 San Diego-Imperial Valley LCR Area Load and Resources

Table J.3.2-69 provides the forecast load and resources in the San Diego-Imperial Valley LCR area in 2034. The list of generators within the San Diego-Imperial Valley area are provided in Attachment A.

In year 2034 the estimated time of local area peak is HE 6:00 P.M. (PDT) on September 5, 2034 per the CEC hourly demand forecast.

At the local area peak time the estimated, ISO metered solar output is 11.00%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.2-69 San Diego-Imperial Valley LCR Area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC     | At Peak     |
|------------------------------|-------------|--------------------------|-------------|-------------|
| Gross Load (inc ATE)         | 5499        | Market, Net Seller, Wind | 3707        | 3707        |
| AAEE, AAFS & AATE            | 437         | Battery, Hybrid          | 2527        | 2527        |
| Behind the meter DG          | -720        | MUNI, QF                 | 3           | 3           |
| <b>Net Load</b>              | <b>5216</b> | Solar                    | 169         | 169         |
| Transmission Losses          | 203         | Existing Demand Response | 0           | 0           |
| Pumps                        | 0           | Mothballed               | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>5419</b> | <b>Total</b>             | <b>6406</b> | <b>6406</b> |

**J.3.2.10.1.3 Approved transmission projects modeled:**

TL623C Reconductor (San Ysidro - Otay Tap)  
 TL649D Reconductor (San Ysidro - Otay Lake Tap)  
 Reconductor TL605 Silvergate – Urban  
 Re-conductor of Japanese Mesa–Basilone–Talega Tap 69 kV lines  
 TL632 Granite loop-in and TL6914 reconfiguration  
 Reconductor of Stuart Tap–Las Pulgas 69 kV line (TL690E)  
 Sweetwater Reliability Enhancement  
 Imperial Valley-El Centro 230 kV (“S”) line upgrade  
 Valley Center System Improvement  
 Miguel – Sycamore Canyon (TL23021) 230 kV Line Loop Into Suncrest  
 Rearrange TL23013 PQ - OT and TL6959 PQ – Mira Sorrento Lines  
 Reconductor TL680C San Marcos – Melrose Tap  
 Install 3-Ohm Series Reactor on Sycamore – Penasquitos 230 kV Line  
 Upgrade TL13820 Sycamore – Chicarita 138 kV Line  
 Construct North Gila – Imperial Valley 500 kV Line #2  
 Construct Imperial Valley – North of SONGS 500 kV Line and Substation

Also the 500kV line series capacitors on the Southwest Powerlink and Sunrise Powerlink lines are bypassed in the study case.

**J.3.2.10.2 El Cajon Sub-area**


El Cajon sub-area will be eliminated due to the TL632 Granite loop-in and TL6914 reconfiguration project and change in LCR criteria.

**J.3.2.10.3 Border Sub-area**

Border is a Sub-area of the San Diego-Imperial Valley LCR Area.

**J.3.2.10.3.1 Border LCR Sub-area Diagram**

Figure J.3.2-84 Border LCR Sub-area



### J.3.2.10.3.2 Border LCR Sub-area Load and Resources

Table J.3.2-70 provides the forecast load and resources in Border LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-70 Border Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)    | Aug NQC    | At Peak    |
|------------------------------|------------|--------------------|------------|------------|
| Gross Load                   | 234        | Market, Net Seller | 149        | 149        |
| AAEE, AAFS & AATE            | -4         | Battery            | 0          | 0          |
| Behind the meter DG          | -28        | MUNI, QF/Self-gen  | 0          | 0          |
| <b>Net Load</b>              | <b>202</b> | Solar              | 0          | 0          |
| Transmission Losses          | 1          | Demand Response    | 0          | 0          |
| Pumps                        | 0          | Mothballed         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>203</b> | <b>Total</b>       | <b>149</b> | <b>149</b> |

### J.3.2.10.3.3 Border LCR Sub-area Hourly Profiles

Figure J.3.2-85 illustrates the forecasted 2034 profile for the peak day for the Border LCR sub-area with the normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-86 illustrates the forecasted 2034 hourly profile for Border LCR sub-area with the normal and emergency load serving capability without local capacity resources.

Figure J.3.2-85 Border LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-86 Border LCR Sub-area 2034 Forecast Hourly Profiles



### J.3.2.10.3.4 Border LCR Sub-area Requirement

Table J.3.2-71 identifies the sub-area requirements. The LCR requirement for Category P3 contingency is 124 MW.

Table J.3.2-71 Border 2034 LCR Sub-area Requirements

| Year | Category | Limiting Facility                       | Contingency  | LCR (MW)<br>(Deficiency) |
|------|----------|---|--|--------------------------|
| 2034 | P3       | Otay – Otay Lakes Tap<br>69 kV (TL649A) | Border unit out of service followed by the outage<br>of Miguel-Salt Creek 69 kV (TL6964) | 124                      |

### J.3.2.10.3.5 Effectiveness factors:

All units within the Border Sub-area have the same effectiveness factor.

### J.3.2.10.4 San Diego Sub-area

San Diego is a sub-area of the San Diego-Imperial Valley LCR area.

#### J.3.2.10.4.1 San Diego LCR Sub-area Diagram

Please refer to Figure J.3.2-83 above.

### J.3.2.10.4.2 San Diego LCR Sub-area Load and Resources

Table J.3.2-72 provides the forecast load and resources in San Diego LCR sub-area in 2034. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.2-72 San Diego Sub-area 2034 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC     | At Peak     |
|------------------------------|-------------|--------------------------|-------------|-------------|
| Gross Load                   | 5499        | Market, Net Seller, Wind | 2735        | 2735        |
| AAEE, AAFS & AATE            | 437         | Battery, Hybrid          | 2082        | 2082        |
| Behind the meter DG          | -720        | MUNI, QF                 | 3           | 3           |
| <b>Net Load</b>              | <b>5216</b> | Solar                    | 7           | 7           |
| Transmission Losses          | 203         | Existing Demand Response | 26          | 26          |
| Pumps                        | 0           | Mothballed               | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>5419</b> | <b>Total</b>             | <b>4853</b> | <b>4853</b> |

### J.3.2.10.4.3 San Diego LCR Sub-area Hourly Profiles

Figure J.3.2-87 illustrates the forecasted 2034 profile for the peak day for the San Diego LCR sub-area with the normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-88 illustrates the forecasted 2034 hourly profile for San Diego LCR sub-area with the normal and emergency load serving capability without local capacity resources.

Figure J.3.2-87 San Diego LCR Sub-area 2034 Peak Day Forecast Profiles





Figure J.3.2-88 San Diego LCR sub-area 2034 Forecast Hourly Profiles



#### J.3.2.10.4.4 San Diego LCR Sub-area Requirement

Table J.3.2-73 identifies the sub-area LCR requirements. The LCR requirement for Category P6 contingency is 1902 MW. The LCR decreases when compared with the 2029 LCR study results due to implementation of CAISO Board-approved transmission upgrades in the area.

Table J.3.2-73 San Diego LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility               | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|---------------------------------|--|--------------------------|
| 2034 | First Limit | P6       | San Onofre – Talega 230 kV line | Eco – Miguel 500 kV, followed by San Onofre - Capistrano 230 kV line (or vice versa) | 1902                     |

#### J.3.2.10.4.5 Effectiveness factors:

See Attachment B - Table titled [San Diego](#).

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7820 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.2.10.5 San Diego-Imperial Valley Overall

#### J.3.2.10.5.1 San Diego-Imperial Valley LCR area Hourly Profiles

Since the San Diego sub-area has all the substation loads, the overall San Diego-Imperial Valley area has the same load profile as the San Diego bulk sub-area. The Imperial Valley area has generating resources. Figure J.3.2-89 illustrates the forecasted 2034 profile for the peak day for the San Diego-Imperial Valley LCR area with the normal and emergency load serving capabilities

without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.2-90 illustrates the forecasted 2034 hourly profile for San Diego-Imperial Valley LCR area with the normal and emergency load serving capability without local capacity resources.

Figure J.3.2-89 San Diego-Imperial Valley LCR Area 2034 Peak Day Forecast Profile





Figure J.3.2-90 San Diego-Imperial Valley Area 2034 Forecast Hourly Profiles



The following is a summary of estimated amount of storage for the sub-areas and the overall area based on maximum charging capability perspective. Due to non-linearity of power system and the various critical contingencies and load shapes for each sub-area and the overall area, it is noted that the estimated maximum amount of storage for the sub-areas may not add up to be sum of the overall area. Since the San Diego sub-area has all the substation loads, the overall San Diego-Imperial Valley area has the same load profile as the San Diego bulk sub-area and therefore same amount of energy storage for the San Diego sub-area. The Imperial Valley area (of the overall San Diego-Imperial Valley) has generating resources only. The estimated maximum amount of storage for the LCR area is the amount listed in the last row in the table.

Table J.3.2-74 Estimated San Diego Sub-areas and Overall Area Energy Storage Capacity and Energy Based on Maximum Charging Capability Perspective

| Area/Sub-area                          | Estimated Energy Storage Maximum Capacity (MW) | Estimated Energy Storage Maximum Energy (MWh) | Estimated 4-Hour Energy Storage (MW) |
|--|--|---|--------------------------------------|
| Border sub-area                        | 56   | 234   | 53                                   |
| San Diego bulk sub-area                | 890  | 6380  | 470                                  |
| Overall San Diego-Imperial Valley area | 890  | 6380  | 470                                  |

#### J.3.2.10.5.2 San Diego-Imperial Valley LCR area Requirement

Table J.3.2-75 identifies the area LCR requirements. The LCR requirement for Category P6 contingency is 1902 MW, which is the same as the LCR need for the San Diego bulk sub-area.

Table J.3.2-75 San Diego-Imperial Valley LCR area Requirements

| Year | Limit       | Category | Limiting Facility               | Contingency   | LCR (MW) (Deficiency) |
|------|-------------|----------|---------------------------------|---|-----------------------|
| 2034 | First Limit | P6       | San Onofre – Talega 230 kV line | ECO – Miguel 500 kV line, followed by San Onofre – Capistrano 230 kV line (or vice versa) | 1902                  |

#### J.3.2.10.5.3 Effectiveness factors:

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7820 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.2.10.5.4 Changes compared to the 2029 LCT study

The demand forecast is higher by 373 MW. The overall LCR need for the San Diego – Imperial Valley area decreases by 1219 MW, due to implementation of CAISO Board-approved transmission upgrades in the area.

**J.3.2.11 Valley Electric Area**

Valley Electric Association LCR area has been eliminated on the basis of the following:

- No single-element contingency issues were observed in this area
- Multiple-element contingencies and beyond –
  - No common-mode N-2 issues were observed
  - No issues were observed for category B outage followed by a common-mode N-2 outage
  - All the N-1-1 issues that were observed can either be mitigated by the existing UVLS or by an operating procedure

### J.3.3 Summary of 2039 Results by Local Area

A few selected areas and sub-areas have been studied for year 2039 that have meaningful high retirement portfolio scenario versus what was already studied in year 2034. Each Local Capacity Area's overall requirement is determined by also achieving each sub-area requirement. Because these areas are a part of the interconnected electric system, the total for each Local Capacity Area is not simply a summation of the sub-area needs. For example, some sub-areas may overlap and therefore the same units may count for meeting the needs in both sub-areas.

#### J.3.3.1 Greater Bay Area

##### J.3.3.1.1 Area Definition:

The transmission tie lines into the Greater Bay Area are:

- Lakeville-Sobrante 230 kV
- Ignacio-Sobrante 230 kV
- Parkway-Moraga 230 kV
- Bahia-Moraga 230 kV
- Lambie SW Sta-Vaca Dixon 230 kV
- Peabody-Contra Costa P.P. 230 kV
- Tesla-Kelso 230 kV
- Tesla-Delta Switching Yard 230 kV
- Tesla-Pittsburg #1 230 kV
- Tesla-Pittsburg #2 230 kV
- Tesla-Newark #1 230 kV
- Tesla-Newark #2 230 kV
- Tesla-Ravenswood 230 kV
- Tesla-Metcalf 500 kV
- Moss Landing-Metcalf 500 kV
- Moss Landing-Metcalf #1 230 kV
- Moss Landing-Metcalf #2 230 kV
- Oakdale TID-Newark #1 115 kV
- Oakdale TID-Newark #2 115 kV


The substations that delineate the Greater Bay Area are:

- Lakeville is out Sobrante is in
- Ignacio is out Sobrante is in

Parkway is out Moraga is in  
 Bahia is out Moraga is in  
 Lambie SW Sta is in Vaca Dixon is out  
 Peabody is out Contra Costa P.P. is in  
 Tesla is out Kelso is in  
 Tesla is out Delta Switching Yard is in  
 Tesla is out Pittsburg is in  
 Tesla is out Pittsburg is in  
 Tesla is out Newark is in  
 Tesla is out Newark is in  
 Tesla is out Ravenswood is in  
 Tesla is out Metcalf is in  
 Moss Landing is out Metcalf is in  
 Moss Landing is out Metcalf is in  
 Moss Landing is out Metcalf is in  
 Oakdale TID is out Newark is in  
 Oakdale TID is out Newark is in

### J.3.3.1.1.1 Greater Bay LCR Area Diagram

Figure J.3.3-1 Greater Bay LCR Area



**J.3.3.1.1.2 Greater Bay LCR Area Load and Resources**

Table J.3.3-1 provides the forecasted load and resources. The list of generators within the LCR area are provided in Attachment A.

In year 2039 the estimated time of local area peak is 19:00 PM.

At the local area peak time the estimated, ISO metered, solar output is 0%.

If required, all technology type resources, including solar, are dispatched at NQC.

Table J.3.3-1 Greater Bay Area LCR Area 2039 Forecast Load and Resources

| Load (MW)                    |               | Generation (MW)                    | Aug NQC      | At Peak      |
|------------------------------|---------------|------------------------------------|--------------|--------------|
| Gross Load (inc. ATE)        | 17,938        | Market, Net Seller, Wind           | 4,785        | 4,785        |
| AAEE                         | -206          | Battery                            | 2,706        | 2,706        |
| Behind the meter DG          | -54           | MUNI, QF                           | 132          | 132          |
| <b>Net Load</b>              | <b>17,678</b> | Solar                              | 30           | 0            |
| Transmission Losses          | 762           | Existing 20-minute Demand Response | 65           | 0            |
| Pumps                        | 0             | Mothballed                         | 0            | 0            |
| <b>Load + Losses + Pumps</b> | <b>18,440</b> | <b>Total</b>                       | <b>8,071</b> | <b>8,041</b> |

**J.3.3.1.1.3 Approved transmission projects modeled**

Oakland Clean Energy Initiative Project (Oakland CTs are assumed retired)

Moraga – Oakland X lines rebuild project

Morgan Hill Area Reinforcement (revised scope)

Metcalf-Piercy & Swift and Newark-Dixon Landing 115 kV Upgrade

East Shore-Oakland J 115 kV Reconductoring Project

Vaca Dixon-Lakeville 230 kV Corridor Series Compensation

Lone Tree – Cayetano – Newark corridor Series Compensation

Metcalf-Evergreen 115 kV Line Reconductoring

South of San Mateo Capacity Increase

Newark - NRS 230 kV AC Line

San Jose Area HVDC Line (Metcalf – San Jose)

Series Compensation on Los Esteros-Nortech 115 kV Line


New Collinsville 500 kV substation

### J.3.3.1.2 Llagas Sub-area

Llagas is a sub-area of the Greater Bay LCR area.

#### J.3.3.1.2.1 Llagas LCR Sub-area Diagram

Figure J.3.3-2 Llagas LCR Sub-area



#### J.3.3.1.2.2 Llagas LCR Sub-area Load and Resources

Table J.3.3-2 provides the forecasted load and resources. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-2 Llagas LCR Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|------------|------------------------------------|------------|------------|
| Gross Load (inc. ATE)        | 569        | Market, Net Seller                 | 256        | 256        |
| AAEE                         | -5         | Battery                            | 64         | 64         |
| Behind the meter DG          | -2         | MUNI, QF                           | 0          | 0          |
| <b>Net Load</b>              | <b>562</b> | Solar                              | 0          | 0          |
| Transmission Losses          | 2          | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0          | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>564</b> | <b>Total</b>                       | <b>320</b> | <b>320</b> |

### J.3.3.1.2.3 Llagas LCR Sub-area Hourly Profiles

Figure J.3.3-3 illustrates the forecast 2039 profile for the peak day for the Llagas LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.3-4 illustrates the forecast 2039 hourly profile for Llagas LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.3-3 Llagas LCR Sub-area 2039 Peak Day Forecast Profiles





Figure J.3.3-4 Llagas LCR Sub-area 2039 Forecast Hourly Profiles



**J.3.3.1.2.4 Llagas LCR Sub-area Requirement**

Table J.3.3-3 identifies the sub-area LCR requirements. The LCR requirement for the Category P6 contingency is 428 MW including a 108 MW of deficiency.

Table J.3.3-3 Llagas LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility          | Contingency   | LCR (MW)  |
|------|-------------|----------|----------------------------|---|-----------|
| 2039 | First limit | P6       | Metcalf-Llagas 115 kV line | Metcalf-Morgan Hill 115 kV &<br>Morgan Hill-Green Valley 115 kV | 428 (108) |

**J.3.3.1.2.5 Effectiveness factors:**

All units within the Llagas Sub-area have the same effectiveness factor.

**J.3.3.1.3 San Jose Sub-area**

San Jose is a sub-area of the Greater Bay LCR area.

**J.3.3.1.3.1 San Jose LCR Sub-area Diagram**

The San Jose LCR sub-area is identified in Figure J.3.2-23.

**J.3.3.1.3.2 San Jose LCR Sub-area Load and Resources**

Table J.3.3-4 provides the forecast load and resources in San Jose LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-4 San Jose LCR Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                    | Aug NQC    | At Peak    |
|------------------------------|--------------|------------------------------------|------------|------------|
| Gross Load (inc. ATE)        | 4,965        | Market, Net Seller                 | 556        | 556        |
| AAEE                         | -45          | Battery                            | 345        | 345        |
| Behind the meter DG          | -11          | MUNI, QF                           | 0          | 0          |
| <b>Net Load</b>              | <b>4,909</b> | Solar                              | 0          | 0          |
| Transmission Losses          | 237          | Existing 20-minute Demand Response | 0          | 0          |
| Pumps                        | 0            | Mothballed                         | 0          | 0          |
| <b>Load + Losses + Pumps</b> | <b>5,146</b> | <b>Total</b>                       | <b>902</b> | <b>902</b> |

**J.3.3.1.3.3 San Jose LCR Sub-area Hourly Profiles**

Figure J.3.3-5 illustrates the forecast 2039 profile for the peak day for the San Jose LCR sub-area with the Category P2 normal and emergency load serving capabilities without local capacity

resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.3-6 illustrates the forecast 2039 hourly profile for San Jose LCR sub-area with the Category P2 emergency load serving capability without local capacity resources.

Figure J.3.3-5 San Jose LCR Sub-area 2039 Peak Day Forecast Profiles





Figure J.3.3-6 San Jose LCR Sub-area 2039 Forecast Hourly Profiles



**J.3.3.1.3.4 San Jose Sub-area Requirement**

Table J.3.3-5 identifies the sub-area LCR requirements. The LCR requirement for the Category P6 contingency is 2,092 MW including 1,190 MW of deficiency.

Table J.3.3-5 San Jose LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                 | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-----------------------------------|---|--------------------------|
| 2039 | First limit | P6       | Metcalf 230/115 kV transformer #2 | Metcalf 230/115 kV transformer #3 and Metcalf 230/115 kV transformer #4 | 2,092 (1,190)            |

**J.3.3.1.3.5 Effectiveness factors:**

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7320 posted at: <http://www.aiso.com/Documents/2210Z.pdf>

**J.3.3.1.4 South Bay-Moss Landing Sub-area**

South Bay-Moss Landing is a sub-area of the Greater Bay LCR area.

**J.3.3.1.4.1 South Bay-Moss Landing LCR Sub-area Diagram**

The South Bay-Moss Landing LCR sub-area is identified in Figure J.3.2-23.

**J.3.3.1.4.2 South Bay-Moss Landing LCR Sub-area Load and Resources**

Table J.3.3-6 provides the forecast load and resources in South Bay-Moss Landing LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-6 South Bay-Moss Landing LCR Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                    | Aug NQC      | At Peak      |
|------------------------------|--------------|------------------------------------|--------------|--------------|
| Gross Load (inc. ATE)        | 7,581        | Market, Net Seller                 | 2,175        | 2,175        |
| AAEE                         | -82          | Battery                            | 2,097        | 2,097        |
| Behind the meter DG          | -21          | MUNI, QF                           | 0            | 0            |
| <b>Net Load</b>              | <b>7,478</b> | Solar                              | 0            | 0            |
| Transmission Losses          | 352          | Existing 20-minute Demand Response | 0            | 0            |
| Pumps                        | 0            | Mothballed                         | 0            | 0            |
| <b>Load + Losses + Pumps</b> | <b>7,830</b> | <b>Total</b>                       | <b>4,273</b> | <b>4,273</b> |

**J.3.3.1.4.3 South Bay-Moss Landing LCR Sub-area Hourly Profiles**

Figure J.3.3-7 illustrates the forecast 2039 profile for the peak day for the South Bay-Moss Landing LCR sub-area with the Category P6 normal and emergency load serving capabilities

without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. The energy storage amount is incremental to the existing system and doesn't include approved energy storage. Figure J.3.3-8 illustrates the forecast 2039 hourly profile for South Bay-Moss Landing LCR sub-area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.3-7 South Bay-Moss Landing LCR Sub-area 2039 Peak Day Forecast Profiles





Figure J.3.3-8 South Bay-Moss Landing LCR Sub-area 2039 Forecast Hourly Profiles



#### J.3.3.1.4.4 South Bay-Moss Landing LCR Sub- Requirement

Table J.3.3-7 identifies the sub-area LCR requirements. The LCR requirement for the Category P6 contingency is 6,170 MW including 1,263 MW of deficiency.

Table J.3.3-7 South Bay-Moss Landing LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility               | Contingency   | LCR (MW)         |
|------|-------------|----------|---------------------------------|---|------------------|
| 2039 | First Limit | P6       | Moss Landing-Las Aguilas 230 kV | Tesla-Metcalf 500 kV and<br>Moss Landing-Los Banos 500 kV | 6,170<br>(1,263) |

#### J.3.3.1.4.5 Effectiveness factors:

Effectiveness factors for generators in the South Bay-Moss Landing LCR sub-area are in Attachment B table titled [South Bay-Moss Landing](#).


For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7230 posted at: <http://www.caiso.com/Documents/2210Z.pdf>.

#### J.3.3.1.5 Oakland Sub-area

Oakland is a sub-area of the Greater Bay LCR area.

##### J.3.3.1.5.1 Oakland LCR Sub-area Diagram

Figure J.3.3-9 Oakland LCR Sub-area



##### J.3.3.1.5.2 Oakland LCR Sub-area Load and Resources

Table J.3.3-8 provides the forecast load and resources in Oakland LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-8 Oakland LCR Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |            | Generation (MW)                    | Aug NQC  | At Peak  |
|------------------------------|------------|------------------------------------|----------|----------|
| Gross Load (inc. ATE)        | 450        | Market, Net Seller                 | 0        | 0        |
| AAEE                         | -4         | Battery                            | 0        | 0        |
| Behind the meter DG          | -1         | MUNI, QF                           | 2        | 2        |
| <b>Net Load</b>              | <b>445</b> | Solar                              | 0        | 0        |
| Transmission Losses          | 2          | Existing 20-minute Demand Response | 0        | 0        |
| Pumps                        | 0          | Mothballed                         | 0        | 0        |
| <b>Load + Losses + Pumps</b> | <b>447</b> | <b>Total</b>                       | <b>2</b> | <b>2</b> |

### J.3.3.1.5.3 Oakland LCR Sub-area Hourly Profiles

Figure J.3.3-10 illustrates the forecast 2039 profile for the peak day for the Oakland LCR sub-area with the Category P2 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. The energy storage amount is incremental to the existing system and doesn't include approved energy storage. Figure J.3.3-11 illustrates the forecast 2039 hourly profile for Oakland LCR sub-area with the Category P2 emergency load serving capability without local capacity resources.

Figure J.3.3-10 Oakland LCR Sub-area 2039 Peak Day Forecast Profiles





Figure J.3.3-11 Oakland LCR Sub-area 2039 Forecast Hourly Profiles



#### J.3.3.1.5.4 Oakland LCR Sub-area Requirement

Table J.3.3-9 identifies the sub-area requirements. The LCR requirement for the Category P2 contingency is 215 MW including a 213 MW deficiency.

Table J.3.3-9 Oakland LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility           | Contingency                         | LCR (MW)               |
|------|-------------|----------|-----------------------------|-------------------------------------|------------------------|
| 2039 | First limit | P2       | Oakland C-X #2 115 kV cable | Claremont 115 kV Section<br>1D & 2D | 215 (213) <sup>6</sup> |

#### J.3.3.1.5.5 Effectiveness factors:

All units within the Oakland sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7320 posted at: <http://www.caiso.com/Documents/2210Z.pdf>


#### J.3.3.1.6 Ames-Pittsburg-Oakland Sub-areas Combined

Ames-Pittsburg-Oakland is a sub-area of the Greater Bay LCR area.

<sup>6</sup> This requirement doesn't reflect potential load transfer that could occur following the first contingency. An approved operating procedure including this load transfer could reduce this requirement.

### J.3.3.1.6.1 Ames-Pittsburg-Oakland LCR Sub-area Diagram

Figure J.3.3-12 Ames-Pittsburg-Oakland LCR Sub-area



### J.3.3.1.6.2 Ames-Pittsburg-Oakland LCR Sub-area Load and Resources

Table J.3.3-10 provides the forecast load and resources in Ames-Pittsburg-Oakland LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-10 Ames-Pittsburg-Oakland LCR Sub-area 2039 Forecast Load and Resources

| Load (MW)  | Generation (MW)                    | Aug NQC      | At Peak      |
|--|------------------------------------|--------------|--------------|
| The Ames-Pittsburg-Oakland Sub-area does not has a defined load pocket with the limits based upon power flow through the area. | Market, Net Seller, Wind           | 1,494        | 1,494        |
|  | Battery                            | 200          | 200          |
|  | MUNI, QF                           | 4            | 4            |
|  | Solar                              | 2            | 0            |
|  | Existing 20-minute Demand Response | 0            | 0            |
|  | Mothball                           | 0            | 0            |
|  | <b>Total</b>                       | <b>1,700</b> | <b>1,698</b> |

### J.3.3.1.6.3 Ames-Pittsburg-Oakland LCR Sub-area Hourly Profiles

The Ames-Pittsburg-Oakland sub-area does not has a defined load pocket with the limits based upon power flow through the area. As such, no load profile is provided for this sub-area.

### J.3.3.1.6.4 Ames-Pittsburg-Oakland LCR Sub-area Requirement

Table J.3.3-11 identifies the sub-area LCR requirements. The LCR requirement for the Category P7 or P2 contingency is 3,920MW including 2,220 MW of NQC deficiency.

Table J.3.3-11 Ames-Pittsburg-Oakland LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility              | Contingency  | LCR (MW)                         |
|------|-------------|----------|--------------------------------|--|----------------------------------|
| 2039 | First limit | P6       | Ames-Ravenswood #1 115 kV line | Newark-Ravenswood 230 kV & Tesla-Ravenswood 230 kV | 3,920<br>(2,220 NQC/ 2,222 Peak) |

### J.3.3.1.6.5 Effectiveness factors:

Effectiveness factors for generators in the Ames-Pittsburg-Oakland LCR sub-area are in Attachment B table titled [Ames/Pittsburg/Oakland](#).


For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7320 (T-165Z) posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.3.1.7 Contra Costa Sub-area

Contra Costa is a sub-area of the Greater Bay LCR area.

#### J.3.3.1.7.1 Contra Costa LCR Sub-area Diagram

Figure J.3.3-13 Contra Costa LCR Sub-area



#### J.3.3.1.7.2 Contra Costa LCR Sub-area Load and Resources

Table J.3.3-12 provides the forecast load and resources in Contra Costa LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-12 Contra Costa LCR Sub-area 2039 Forecast Load and Resources

| Load (MW)   | Generation (MW)                    | Aug NQC      | At Peak      |
|---|------------------------------------|--------------|--------------|
| The Contra Costa Sub-area does not have a defined load pocket with the limits based upon power flow through the area. | Market, Net Seller, Wind           | 1,468        | 1,468        |
|   | Battery                            | 138          | 138          |
|   | MUNI, QF                           | 127          | 127          |
|   | Solar                              | 24           | 0            |
|   | Existing 20-minute Demand Response | 0            | 0            |
|   | Mothballed                         | 0            | 0            |
|   | <b>Total</b>                       | <b>1,757</b> | <b>1,733</b> |

### J.3.3.1.7.3 Contra Costa LCR Sub-area Hourly Profiles

The Contra Costa sub-area does not have a defined load pocket with the limits based upon power flow through the area. As such, no load profile is provided for this sub-area.

### J.3.3.1.7.4 Contra Costa LCR Sub-area Requirement

Table J.3.3-13 identifies the sub-area LCR requirements. The LCR requirement for the Category P3 contingency is 1,920 MW including a 163 MW NQC deficiency.

Table J.3.3-13 Contra Costa LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                        | Contingency                      | LCR (MW)                     |
|------|-------------|----------|--|----------------------------------|------------------------------|
| 2039 | First limit | P2       | Tesla – Delta Switching Yard 230 kV line | Tesla E 230 kV – Section 2E & 1E | 1,920<br>(163 NQC/ 187 Peak) |

### J.3.3.1.7.5 Effectiveness factors:

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7230 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.3.1.8 Bay Area overall

#### J.3.3.1.8.1 Bay Area LCR Area Hourly Profiles

Figure J.3.3-14 illustrates the forecast 2039 profile for the peak day for the Bay Area LCR area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.3-15 illustrates the forecast 2039 hourly profile for Bay Area LCR area with the Category P6 emergency load serving capability without local capacity resources.

Figure J.3.3-14 Bay Area LCR Area 2039 Peak Day Forecast Profiles





Figure J.3.3-15 Bay Area LCR Area 2039 Forecast Hourly Profiles



### J.3.3.1.8.2 Greater Bay LCR Area Overall Requirement

Table J.3.3-14 identifies the area LCR requirements. The LCR requirement for the Category P6 contingency is 12,865 MW including a 4,794 MW NQC deficiency.

Table J.3.3-14 Bay Area LCR Overall area Requirements

| Year | Limit       | Category | Limiting Facility                  | Contingency                               | LCR (MW)                         |
|------|-------------|----------|------------------------------------|---|----------------------------------|
| 2039 | First limit | P6       | Metcalf 500/230 kV #13 transformer | Metcalf 500/230 kV #11 & #12 transformers | 12,865<br>(4,794 NQC/4,824 Peak) |

**J.3.3.1.8.3 Changes compared to the 2029 LCT study**

Load forecast went up by 6,107 MW and total LCR need went up by 6,606 MW mainly due to the load increase.

**J.3.3.2 LA Basin Area****J.3.3.2.1 Area Definition:**

The transmission tie lines into the LA Basin Area are:

San Onofre - San Luis Rey #1, #2, and #3 230 kV Lines

San Onofre - Talega #2 230 kV Line

San Onofre - Capistrano #1 230 kV Line

Lugo - Mira Loma #2 & #3 500 kV Lines

Lugo - Rancho Vista #1 500 kV Line

Vincent – Mesa 500 kV Line

North of SONGS – Imperial Valley 500 kV Line

Sylmar - Eagle Rock 230 kV Line

Sylmar - Gould 230 kV Line

Vincent - Mesa #1 & #2 230 kV Lines

Vincent - Rio Hondo #1 & #2 230 kV Lines

Devers - Red Bluff 500 kV #1 and #2 Lines

Mirage – Coachella Valley # 1 230 kV Line

Mirage - Ramon # 1 & #2 230 kV Line

Mirage - Julian Hinds 230 kV Line

Devers – Ramon 230 kV Line

The substations that delineate the LA Basin Area are:

San Onofre is in San Luis Rey is out

San Onofre is in Talega is out

San Onofre is in Capistrano is out

Mira Loma is in Lugo is out


Rancho Vista is in Lugo is out

Eagle Rock is in Sylmar is out

Gould is in Sylmar is out  
 Mira Loma is in Vincent is out  
 Mesa is in Vincent is out  
 North of SONGS is in Imperial Valley is out  
 Rio Hondo is in Vincent is out  
 Devers is in Red Bluff is out  
 Mirage is in Coachela Valley is out  
 Mirage is in Ramon is out  
 Mirage is in Julian Hinds is out  
 Devers is in Ramon is out

### J.3.3.2.1.1 LA Basin LCR Area Diagram

Figure J.3.3-16 LA Basin LCR Area



### J.3.3.2.1.2 LA Basin LCR Area Load and Resources

Table J.3.3-15 provides the forecast load and resources in the LA Basin LCR area in 2039. The list of generators within the LCR area are provided in Attachment A and does not include LTPP Preferred resources or DR.

In year 2039 the estimated time of local area peak is 6:00 PM (PDT) on September 7, 2039.

At the local area peak time the estimated, ISO metered, solar output is 11%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.3-15 LA Basin LCR Area 2039 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                                 | Aug NQC     | At Peak     |
|------------------------------|--------------|---|-------------|-------------|
| Gross Load (inc. ATE & FS)   | 18937        | Market, Net Seller, Wind                        | 3777        | 3777        |
| AAEE, AAFS & AATE            | 3632         | Battery, Hybrid                                 | 4739        | 4739        |
| Behind the meter DG          | -626         | MUNI, QF  | 486         | 486         |
| <b>Net Load</b>              | <b>21943</b> | Solar   | 115         | 115         |
| Transmission Losses          | 331          | Existing Demand Response                        | 428         | 428         |
| Pumps                        | 0            | LTPP Preferred Resources (BTM BESS, EE, DR, PV) | 173         | 173         |
| <b>Load + Losses + Pumps</b> | <b>22274</b> | <b>Total</b>                                    | <b>9718</b> | <b>9718</b> |

**J.3.3.2.1.3 Approved transmission projects modeled:**

Mesa Loop-In Project and Laguna Bell Corridor 230 kV line upgrades

Delaney – Colorado River 500 kV Line (Ten West Link Project) and Cielo Azul 500 kV Switchyard

Hassayampa – North Gila #2 500 kV Line (APS)

West of Devers 230 kV line upgrades

Lugo – Victorville 500 kV Upgrade

Alberhill 500 kV Method of Service

Laguna Bell – Mesa No. 1 230 kV Line Rating Increase Project

Pardee – Sylmar 230 kV Line Rating Increase Project

Serrano 4AA 500/230 kV Transformer Bank Addition

Sylmar Transformer Replacement Project

Antelope – Whirlwind 500 kV Line Upgrade Project

Devers – Red Bluff 500 kV Lines #1 and 2 Upgrade

Colorado River – Red Bluff 500 kV Line #1 Upgrade

Devers – Valley 500 kV Line #1 Upgrade

Serrano – Alberhill – Valley 500 kV Line #1 Upgrade

Mira Loma – Mesa 500 kV Underground Third Cable

San Bernardino – Etiwanda 230 kV Line #1 Upgrade

Serrano – Del Amo – Mesa 500 kV Transmission Reinforcement

Antelope – Whirlwind 500 kV Line Upgrade Project

Serrano – North of SONGS 500 kV Line

Imperial Valley – North of SONGS 500 kV Line and Substation

Retirement of 1,356 MW of the existing Redondo Beach OTC generation

Alamitos repowering (640 MW)

Alamitos Battery Energy Storage System (179 MW)

Retirement of 2,010 MW of the existing Alamitos OTC generation

Huntington Beach repowering (644 MW)

Retirement of 452 MW of the existing Huntington Beach OTC generation

Stanton Energy Reliability Center (98 MW)

### J.3.3.2.2 *El Nido Sub-area*

El Nido is a sub-area of the LA Basin LCR area.

#### J.3.3.2.2.1 **El Nido LCR Sub-area Diagram**

Please refer to Figure J.3.2-74 above.

#### J.3.3.2.2.2 **El Nido LCR Sub-area Load and Resources**

Table J.3.3-16 provides the forecast load and resources in El Nido LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-16 El Nido LCR Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC    | At Peak    |
|------------------------------|-------------|--------------------------|------------|------------|
| Gross Load                   | 974         | Market, Net Seller, Wind | 546        | 546        |
| AAEE, AAFS and AATE          | 178         | Battery                  | 133        | 133        |
| Behind the meter DG          | -27         | MUNI, QF                 | 0          | 0          |
| <b>Net Load</b>              | <b>1125</b> | Solar                    | 0          | 0          |
| Transmission Losses          | 2           | Existing Demand Response | 12         | 12         |
| Pumps                        | 0           | LTPP Preferred Resources | 10         | 10         |
| <b>Load + Losses + Pumps</b> | <b>1127</b> | <b>Total</b>             | <b>701</b> | <b>701</b> |

#### J.3.3.2.2.3 **El Nido LCR Sub-area Hourly Profiles**

Figure J.3.3-17 illustrates the forecasted 2039 profile for the peak day for the El Nido LCR sub-area with the Category P7 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.3-18 illustrates the

forecasted 2039 hourly profile for El Nido LCR sub-area with the Category P7 normal and emergency load serving capability without local capacity resources.

Figure J.3.3-17 El Nido LCR Sub-area 2039 Peak Day Forecast Profile





Figure J.3.3-18 El Nido LCR Sub-area 2039 Forecast Hourly Profile



#### J.3.3.2.2.4 El Nido LCR Sub-area Requirement

Table J.3.3-17 identifies the sub-area requirements. The LCR requirement for Category P7 contingency is 545 MW. The LCR need increases by 261 MW when compared with the 2029 LCR need due to higher demand forecast for the El Nido sub-area.

Table J.3.3-17 El Nido LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility          | Contingency                       | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|----------------------------|-----------------------------------|--------------------------|
| 2039 | First Limit | P7       | La Fresa-La Cienega 230 kV | La Fresa – El Nido #3 & #4 230 kV | 545                      |

**J.3.3.2.2.5 Effectiveness factors:**

All units within the El Nido Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7630 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

**J.3.3.2.3 Western LA Basin Sub-area**

Western LA Basin is a sub-area of the LA Basin LCR area.

**J.3.3.2.3.1 Western LA Basin LCR Sub-area Diagram**

Please refer to Figure J.3.2-74 above.

**J.3.3.2.3.2 Western LA Basin LCR Sub-area Load and Resources**

Table J.3.3-18 provides the forecast load and resources in Western LA Basin LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-18 Western LA Basin Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |              | Generation (MW)                                 | Aug NQC     | At Peak     |
|------------------------------|--------------|---|-------------|-------------|
| Gross Load                   | 11134        | Market, Net Seller, Wind                        | 709         | 709         |
| AAEE, AAFS and AATE          | 2249         | Battery, Hybrid                                 | 2191        | 2191        |
| Behind the meter DG          | -3766        | MUNI, QF  | 202         | 202         |
| <b>Net Load</b>              | <b>13007</b> | Solar   | 8           | 8           |
| Transmission Losses          | 195          | Existing Demand Response                        | 355         | 355         |
| Pumps                        |              | LTPP Preferred Resources (BTM BESS, EE, DR, PV) | 135         | 135         |
| <b>Load + Losses + Pumps</b> | <b>13202</b> | <b>Total</b>                                    | <b>3600</b> | <b>3600</b> |

**J.3.3.2.3.3 Western LA Basin LCR Sub-area Hourly Profiles**

Figure J.3.3-19 illustrates the forecasted 2039 profile for the peak day for the Western LCR sub-area with the Category P6 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be

added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.3-20 illustrates the forecasted 2039 hourly profile for Western LCR sub-area with the Category P6 normal and emergency load serving capability without local capacity resources.

Figure J.3.3-19 Western LA Basin LCR Sub-area 2039 Peak Day Forecast Profile





Figure J.3.3-20 Western LA Basin LCR Sub-area 2039 Forecast Hourly Profiles



#### J.3.3.2.3.4 Western LA Basin LCR Sub-area Requirement

Table J.3.3-19 identifies the sub-area LCR requirements. The LCR requirement for Category P6 contingency is 3351 MW. The 2039 LCR need is higher by 298 MW than 2029 LCR need due to higher load forecast for the Western LA Basin sub-area.

Table J.3.3-19 Western LA Basin LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility | Contingency   | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|-------------------|---|--------------------------|
| 2039 | First Limit | P6       | Voltage stability | Imperial Valley – North of SONGS 500 kV line, followed by Alberhill – Serrano 500 kV line (or vice versa) | 3351                     |

**J.3.3.2.3.5 Effectiveness factors:**

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7630 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

There are other combinations of contingencies in the area that could overload a significant number of 230 kV lines in this sub-area have less LCR need. As such, anyone of them (combination of contingencies) could become binding for any given set of procured resources. As a result, these effectiveness factors may not be the best indicator towards informed procurement.

**J.3.3.2.4 West of Devers Sub-area**

West of Devers is a sub-area of the LA Basin LCR area.

There are no local capacity requirements due to implementation of the Mesa Loop-in as well as West of Devers reconductoring projects.

**J.3.3.2.5 Valley-Devers Sub-area**

Valley-Devers is a sub-area of the LA Basin LCR area.

There are no local capacity requirements due to implementation of the Colorado River-Delaney 500 kV line project.

**J.3.3.2.6 Valley Sub-area**

Valley is a sub-area of the LA Basin LCR area.

There are no local capacity requirements due to implementation of the Colorado River-Delaney 500 kV line project.

**J.3.3.2.7 Eastern LA Basin Sub-area**

Eastern LA Basin is a sub-area of the LA Basin LCR area.

**J.3.3.2.7.1 Eastern LA Basin LCR Sub-area Diagram**

Please refer to Figure J.3.3-16 above.

**J.3.3.2.7.2 Eastern LA Basin LCR Sub-area Load and Resources**

Table J.3.3-20 provides the forecast load and resources in Eastern LA Basin LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-20 Eastern LA Basin Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC     | At Peak     |
|------------------------------|-------------|--------------------------|-------------|-------------|
| Gross Load                   | 7803        | Market, Net Seller, Wind | 1039        | 1039        |
| AAEE, AAFS and AATE          | 1383        | Battery, Hybrid          | 2436        | 2436        |
| Behind the meter DG          | -250        | MUNI, QF                 | 218         | 218         |
| <b>Net Load</b>              | <b>8936</b> | Solar                    | 107         | 107         |
| Transmission Losses          | 136         | Existing Demand Response | 205         | 205         |
| Pumps                        | 0           | LTPP Preferred Resources | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>9072</b> | <b>Total</b>             | <b>4005</b> | <b>4005</b> |

### J.3.3.2.7.3 Eastern LA Basin LCR Sub-area Hourly Profiles

Figure J.3.3-21 illustrates the forecasted 2039 profile for the peak day for the Eastern LCR sub-area with the Category P1+P7 normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MWh basis. Figure J.3.3-22 illustrates the forecasted 2039 hourly profile for Eastern LCR sub-area with the Category P1+P7 normal and emergency load serving capability without local capacity resources.

Figure J.3.3-21 Eastern LA Basin LCR Sub-area 2039 Peak Day Forecast Profile





Figure J.3.3-22 Eastern LA Basin LCR Sub-area 2039 Forecast Hourly Profiles



#### J.3.3.2.7.4 Eastern LA Basin LCR Sub-area Requirement

Table J.3.3-21 identifies the sub-area LCR requirements. The LCR requirement for Category P1+P7 contingency is 2026 MW. The 2039 LCR need for the Eastern LA Basin is about the same as the 2029 local capacity need (2023 MW) due to higher demand forecast as well as having higher LCR need in the Western LA Basin. Both the Eastern and Western LA Basin sub-areas interact with each other. When the LCR need is lower in the Western LA Basin, the LCR need in the Eastern LA Basin increases to provide voltage support under critical contingency condition, or vice versa. In this case, higher LCR need in the Western LA Basin enables the Eastern LA Basin to have lower LCR need compared to its 2034 LCR results.

Table J.3.3-21 Eastern LA Basin LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility                | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|----------------------------------|--|--------------------------|
| 2039 | First Limit | P1+P7    | Post transient voltage stability | Lugo-Rancho Vista 500 kV, followed by Lugo-Mira Loma #2 and #3 500 kV lines (common structure) | 2026                     |

#### J.3.3.2.7.5 Effectiveness factors:

All units within the Eastern LA Basin Sub-area have the same effectiveness factor.

For most helpful procurement information please read procedure 2210Z Effectiveness Factors under 7750 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

### J.3.3.2.8 LA Basin Overall

#### J.3.3.2.8.1 LA Basin LCR area Hourly Profiles

Figure J.3.3-23 illustrates the forecasted 2039 profile for the peak day for the LA Basin LCR area with the approximate total normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.3-24 illustrates the forecasted 2039 hourly profile for LA Basin LCR area with the normal and emergency load serving transmission capability without local capacity resources.

Figure J.3.3-23 Overall LA Basin LCR Area 2039 Peak Day Forecast Profile





Figure J.3.3-24 Overall LA Basin LCR area 2039 Forecast Hourly Profiles



The following is a summary of estimated amount of storage for the sub-areas and the overall area based on maximum charging capability perspective. Due to non-linearity of power system and the various critical contingencies and load shapes for each sub-area and the overall area, it is noted that the estimated maximum amount of storage for the sub-areas may not add up to be sum of the overall area. The estimated maximum amount of storage for the LCR area is the amount listed in the last row in the table.

Table J.3.3-22 Estimated LA Basin Sub-areas and Overall Area Energy Storage Capacity and Energy Based on Maximum Charging Capability Perspective

| Area/Sub-area                      | Estimated Energy Storage Maximum Capacity (MW) | Estimated Energy Storage Maximum Energy (MWh) | Estimated Maximum 4-hour Energy Storage |
|------------------------------------|--|---|---|
| El Nido sub-area                   | 204  | 1534  | 47                                      |
| Western LA Basin sub-area          | 2540   | 16364   | 1330                                    |
| Eastern LA Basin sub-area          | 1740   | 11177   | 900                                     |
| Overall LA Basin area <sup>7</sup> | 4280   | 27176   | 2230                                    |

#### J.3.3.2.8.2 Overall LA Basin LCR area Requirement

Table J.3.3-23 identifies the area's LCR requirement. The LCR requirement is driven by the sum of the LCR needs for the Western LA Basin and Eastern LA Basin sub-areas, at 5377 MW.

Table J.3.3-23 LA Basin LCR area Requirements

| Year | Limit       | Category | Limiting Facility           | Contingency | LCR (MW) (Deficiency) |
|------|-------------|----------|-----------------------------|-------------|-----------------------|
| 2039 | First Limit | N/A      | Sum of Western and Eastern. |             | 5377                  |

#### J.3.3.2.8.3 Effectiveness factors:

See Attachment B - Table titled [LA Basin](#).

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7550, 7570, 7580, 7590, 7590, 7680 and 7750 posted at: <http://www.aiso.com/Documents/2210Z.pdf>

There are other combinations of contingencies in the area that could overload a significant number of 230 kV lines in this sub-area have less LCR need. As such, anyone of them (combination of contingencies) could become binding for any given set of procured resources.

<sup>7</sup> Total for the overall LA Basin includes the addition of the Western and Eastern LA Basin storage capacity charging capability values. The El Nido sub-area is located within the Western LA Basin sub-area.

As a result, these effectiveness factors may not be the best indicator towards informed procurement.

#### **J.3.3.2.8.4 Changes compared to the 2029 LCT study**

The load forecast is higher by 2,693 MW. The LCR need has increased by 301 MW primarily due to load forecast increase combined with the CAISO Board-approved transmission upgrades in the Western LA Basin.

### **J.3.3.3 San Diego-Imperial Valley Area**

#### **J.3.3.3.1 Area Definition:**

The transmission tie lines forming a boundary around the Greater San Diego-Imperial Valley area include:


- Imperial Valley – North Gila 500 kV Line
- Otay Mesa – Tijuana 230 kV Line
- San Onofre - San Luis Rey #1 230 kV Line
- San Onofre - San Luis Rey #2 230 kV Line
- San Onofre - San Luis Rey #3 230 kV Line
- San Onofre – Talega 230 kV Line
- San Onofre – Capistrano 230 kV Line
- Imperial Valley – Wixom 230 kV Line
- Imperial Valley – La Rosita 230 kV Line

The substations that delineate the Greater San Diego-Imperial Valley area are:

- Imperial Valley is in North Gila is out
- Otay Mesa is in Tijuana is out
- San Onofre is out San Luis Rey is in
- San Onofre is out San Luis Rey is in
- San Onofre is out San Luis Rey is in
- San Onofre is out Talega is in
- San Onofre is out Capistrano is in
- Imperial Valley is in Wixom is out
- Imperial Valley is in La Rosita is out

### J.3.3.3.1.1 San Diego-Imperial Valley LCR Area Diagram

Figure J.3.3-25 San Diego-Imperial Valley LCR Area



### J.3.3.3.1.2 San Diego-Imperial Valley LCR Area Load and Resources

Table J.3.3-24 provides the forecast load and resources in the San Diego-Imperial Valley LCR area in 2039. The list of generators within the San Diego-Imperial Valley area are provided in Attachment A.

In year 2039 the estimated time of local area peak is HE 6:00 P.M. (PDT) on September 6, 2039 per the CEC hourly demand forecast.

At the local area peak time the estimated, ISO metered solar output is 11.00%.

If required, all non-solar technology type resources are dispatched at NQC.

Table J.3.3-24 San Diego-Imperial Valley LCR Area 2039 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC     | At Peak     |
|------------------------------|-------------|--------------------------|-------------|-------------|
| Gross Load (inc ATE)         | 5707        | Market, Net Seller, Wind | 3707        | 3707        |
| AAEE, AAFS & AATE            | 732         | Battery, Hybrid          | 2619        | 2619        |
| Behind the meter DG          | -778        | MUNI, QF                 | 3           | 3           |
| <b>Net Load</b>              | <b>5661</b> | Solar                    | 169         | 169         |
| Transmission Losses          | 229         | Existing Demand Response | 0           | 0           |
| Pumps                        | 0           | Mothballed               | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>5890</b> | <b>Total</b>             | <b>6498</b> | <b>6498</b> |

**J.3.3.3.1.3 Approved transmission projects modeled:**

TL623C Reconductor (San Ysidro - Otay Tap)  
TL649D Reconductor (San Ysidro - Otay Lake Tap)  
Reconductor TL605 Silvergate – Urban  
Re-conductor of Japanese Mesa–Basilone–Talega Tap 69 kV lines  
TL632 Granite loop-in and TL6914 reconfiguration  
Reconductor of Stuart Tap–Las Pulgas 69 kV line (TL690E)  
Sweetwater Reliability Enhancement  
Imperial Valley-El Centro 230 kV (“S”) line upgrade  
Valley Center System Improvement  
Miguel – Sycamore Canyon (TL23021) 230 kV Line Loop Into Suncrest  
Rearrange TL23013 PQ - OT and TL6959 PQ – Mira Sorrento Lines  
Reconductor TL680C San Marcos – Melrose Tap  
Install 3-Ohm Series Reactor on Sycamore – Penasquitos 230 kV Line  
Upgrade TL13820 Sycamore – Chicarita 138 kV Line  
Construct North Gila – Imperial Valley 500 kV Line #2  
Construct Imperial Valley – North of SONGS 500 kV Line and Substation

Also the 500kV line series capacitors on the Southwest Powerlink and Sunrise Powerlink lines are bypassed in the study case.

**J.3.3.3.2 *El Cajon Sub-area***

El Cajon sub-area will be eliminated due to the TL632 Granite loop-in and TL6914 reconfiguration project and change in LCR criteria.

**J.3.3.3.3 *Border Sub-area***

Border is a Sub-area of the San Diego-Imperial Valley LCR Area.

This sub-area was not studied for year 2039.

**J.3.3.3.4 *San Diego Sub-area***

San Diego is a sub-area of the San Diego-Imperial Valley LCR area.

**J.3.3.3.4.1 San Diego LCR Sub-area Diagram**

Please refer to Figure J.3.3-25 above.

### J.3.3.3.4.2 San Diego LCR Sub-area Load and Resources

Table J.3.3-25 provides the forecast load and resources in San Diego LCR sub-area in 2039. The list of generators within the LCR sub-area are provided in Attachment A.

Table J.3.3-25 San Diego Sub-area 2039 Forecast Load and Resources

| Load (MW)                    |             | Generation (MW)          | Aug NQC     | At Peak     |
|------------------------------|-------------|--------------------------|-------------|-------------|
| Gross Load                   | 5707        | Market, Net Seller, Wind | 2735        | 2735        |
| AAEE, AAFS & AATE            | 732         | Battery, Hybrid          | 2174        | 2174        |
| Behind the meter DG          | -778        | MUNI, QF                 | 3           | 3           |
| <b>Net Load</b>              | <b>5661</b> | Solar                    | 7           | 7           |
| Transmission Losses          | 229         | Existing Demand Response | 26          | 26          |
| Pumps                        | 0           | Mothballed               | 0           | 0           |
| <b>Load + Losses + Pumps</b> | <b>5890</b> | <b>Total</b>             | <b>4945</b> | <b>4945</b> |

### J.3.3.3.4.3 San Diego LCR Sub-area Hourly Profiles

Figure J.3.3-26 illustrates the forecasted 2039 profile for the peak day for the San Diego LCR sub-area with the normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.3-27 illustrates the forecasted 2039 hourly profile for San Diego LCR sub-area with the normal and emergency load serving capability without local capacity resources.

Figure J.3.3-26 San Diego LCR Sub-area 2039 Peak Day Forecast Profiles





Figure J.3.3-27 San Diego LCR sub-area 2039 Forecast Hourly Profiles



#### J.3.3.3.4.4 San Diego LCR Sub-area Requirement

Table J.3.3-26 identifies the sub-area LCR requirements. The LCR requirement for Category P6 contingency is 2563 MW. The LCR decreases by 558 MW compared with the 2029 LCR study results due to implementation of CAISO Board-approved transmission upgrades in the area despite the increase in load by 844 MW.

Table J.3.3-26 San Diego LCR Sub-area Requirements

| Year | Limit       | Category | Limiting Facility               | Contingency  | LCR (MW)<br>(Deficiency) |
|------|-------------|----------|---------------------------------|--|--------------------------|
| 2039 | First Limit | P6       | San Onofre – Talega 230 kV line | Eco – Miguel 500 kV, followed by San Onofre - Capistrano 230 kV line (or vice versa) | 2563                     |

#### J.3.3.3.4.5 Effectiveness factors:

See Attachment B - Table titled [San Diego](#).

For other helpful procurement information please read procedure 2210Z Effectiveness Factors under 7820 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.3.3.5 San Diego-Imperial Valley Overall

##### J.3.3.3.5.1 San Diego-Imperial Valley LCR area Hourly Profiles

Since the San Diego sub-area has all the substation loads, the overall San Diego-Imperial Valley area has the same load profile as the San Diego bulk sub-area. The Imperial Valley area has generating resources. Figure J.3.3-28 illustrates the forecasted 2039 profile for the peak day for

the San Diego-Imperial Valley LCR area with the normal and emergency load serving capabilities without local capacity resources. The chart also includes an estimated amount of energy storage that can be added to this local area from charging restriction perspective and the amount of 4-hour storage that can be added to replace local capacity on a 1 MW for 1 MW basis. Figure J.3.3-29 illustrates the forecasted 2039 hourly profile for San Diego-Imperial Valley LCR area with the normal and emergency load serving capability without local capacity resources.

Figure J.3.3-28 San Diego-Imperial Valley LCR Area 2039 Peak Day Forecast Profile





Figure J.3.3-29 San Diego-Imperial Valley Area 2039 Forecast Hourly Profiles



The following is a summary of estimated amount of storage for the sub-areas and the overall area based on maximum charging capability perspective. Due to non-linearity of power system and the various critical contingencies and load shapes for each sub-area and the overall area, it is noted that the estimated maximum amount of storage for the sub-areas may not add up to be sum of the overall area. Since the San Diego sub-area has all the substation loads, the overall San Diego-Imperial Valley area has the same load profile as the San Diego bulk sub-area and therefore same amount of energy storage for the San Diego sub-area. The Imperial Valley area (of the overall San Diego-Imperial Valley) has generating resources only. The estimated maximum amount of storage for the LCR area is the amount listed in the last row in the table.

Table J.3.3-27 Estimated San Diego Sub-areas and Overall Area Energy Storage Capacity and Energy Based on Maximum Charging Capability Perspective

| Area/Sub-area                          | Estimated Energy Storage Maximum Capacity (MW) | Estimated Energy Storage Maximum Energy (MWh) | Estimated 4-Hour Energy Storage (MW) |
|--|--|---|--------------------------------------|
| Border sub-area                        | N/A  | N/A   | N/A                                  |
| San Diego bulk sub-area                | 750  | 5857  | 310                                  |
| Overall San Diego-Imperial Valley area | 750  | 5857  | 310                                  |

#### J.3.3.3.5.2 San Diego-Imperial Valley LCR area Requirement

Table J.3.3-28 identifies the area LCR requirements. The LCR requirement for Category P6 contingency is 2563 MW, which is the same as the LCR need for the San Diego bulk sub-area.

Table J.3.3-28 San Diego-Imperial Valley LCR area Requirements

| Year | Limit       | Category | Limiting Facility               | Contingency   | LCR (MW) (Deficiency) |
|------|-------------|----------|---------------------------------|---|-----------------------|
| 2039 | First Limit | P6       | San Onofre – Talega 230 kV line | ECO – Miguel 500 kV line, followed by San Onofre – Capistrano 230 kV line (or vice versa) | 2563                  |

#### J.3.3.3.5.3 Effectiveness factors:

For helpful procurement information please read procedure 2210Z Effectiveness Factors under 7820 posted at: <http://www.caiso.com/Documents/2210Z.pdf>

#### J.3.3.3.5.4 Changes compared to the 2029 LCT study

The demand forecast is higher by 844 MW. The overall LCR need for the San Diego – Imperial Valley area decreases by 558 MW, due to implementation of CAISO Board-approved transmission upgrades in the area.

Attachment A - List of physical resources by PTO, local area and market ID

## Attachment A – List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME    | kV       | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments         | CAISO<br>Tag |
|------|--------------------------|--------|-------------|----------|--------|------------|------------------|----------------------|-------------------------|--------------|
| PG&E | ALMEGT_1_UNIT 1          | 38118  | ALMDACT1    | 13.8     | 23.40  | 1          | Bay Area         | Oakland              | Could retire<br>by 2039 | MUNI         |
| PG&E | ALMEGT_1_UNIT 2          | 38119  | ALMDACT2    | 13.8     | 23.50  | 1          | Bay Area         | Oakland              | Could retire<br>by 2039 | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38820  | DELTA A     | 13.2     | 11.55  | 1          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38820  | DELTA A     | 13.2     | 11.55  | 2          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38820  | DELTA A     | 13.2     | 11.55  | 3          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38815  | DELTA B     | 13.2     | 11.55  | 4          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38815  | DELTA B     | 13.2     | 11.55  | 5          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38770  | DELTA C     | 13.2     | 11.55  | 6          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38770  | DELTA C     | 13.2     | 11.55  | 7          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38765  | DELTA D     | 13.2     | 11.55  | 8          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38765  | DELTA D     | 13.2     | 11.55  | 9          | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38760  | DELTA E     | 13.2     | 11.55  | 10         | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BANKPP_2_NSPIN           | 38760  | DELTA E     | 13.2     | 11.55  | 11         | Bay Area         | Contra Costa         | Pumps                   | MUNI         |
| PG&E | BLKDIA_2_BDEBT1          | 365773 | Q1111BES    | 0.69     | 200.00 | 1          | Bay Area         | Pittsburg            |                         | Battery      |
| PG&E | BRDSLD_2_HIWIND          | 32172  | HIGHWINDS   | 34.5     | 34.28  | 1          | Bay Area         | Contra Costa         | Aug NQC                 | Wind         |
| PG&E | BRDSLD_2_MTZUM2          | 32179  | MONTEZUM    | 0.69     | 16.55  | 1          | Bay Area         | Contra Costa         | Aug NQC                 | Wind         |
| PG&E | BRDSLD_2_MTZUMA          | 32188  | MONTEZUM    | 0.69     | 7.79   | 1          | Bay Area         | Contra Costa         | Aug NQC                 | Wind         |
| PG&E | BRDSLD_2_SHILO1          | 32181  | SHILOH1W    | 34.5     | 31.74  | 1          | Bay Area         | Contra Costa         | Aug NQC                 | Wind         |
| PG&E | BRDSLD_2_SHILO2          | 365749 | SHILOH2WIND | 0.58     | 31.74  | 1          | Bay Area         | Contra Costa         | Aug NQC                 | Wind         |
| PG&E | BRDSLD_2_SHLO3A          | 32191  | SHILOH3W    | 0.5<br>8 | 21.69  | 1          | Bay Area         | Contra Costa         | Aug NQC                 | Wind         |
| PG&E | BRDSLD_2_SHLO3B          | 32194  | SHILOH4W    | 0.58     | 21.16  | 1          | Bay Area         | Contra Costa         | Aug NQC                 | Wind         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                | NQC<br>Comments                      | CAISO<br>Tag |
|------|--------------------------|-------|----------|------|--------|------------|------------------|-------------------------------------|--------------------------------------|--------------|
| PG&E | CALPIN_1_AGNEW           | 35860 | AGNEWCOG | 13.8 | 6.85   | 2          | Bay Area         | San Jose, South<br>Bay-Moss Landing | Could retired<br>by 2039. Aug<br>NQC | Market       |
| PG&E | CALPIN_1_AGNEW           | 35860 | AGNEWCOG | 13.8 | 21.71  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing | Could retired<br>by 2039. Aug<br>NQC | Market       |
| PG&E | CAYTNO_2_VASCO           |       |          |      | 4.30   |            | Bay Area         | Contra Costa                        | Aug NQC                              | Market       |
| PG&E | CLRMTK_1_QF              |       |          |      | 0.00   |            | Bay Area         | Oakland                             | Not modeled                          | QF/Selfgen   |
| PG&E | COCOPP_2_CTG1            | 33188 | MARSHCT1 | 16.4 | 193.09 | 1          | Bay Area         | Contra Costa                        | Aug NQC                              | Market       |
| PG&E | COCOPP_2_CTG2            | 33188 | MARSHCT2 | 16.4 | 192.32 | 2          | Bay Area         | Contra Costa                        | Aug NQC                              | Market       |
| PG&E | COCOPP_2_CTG3            | 33189 | MARSHCT3 | 16.4 | 191.57 | 3          | Bay Area         | Contra Costa                        | Aug NQC                              | Market       |
| PG&E | COCOPP_2_CTG4            | 33189 | MARSHCT4 | 16.4 | 192.89 | 4          | Bay Area         | Contra Costa                        | Aug NQC                              | Market       |
| PG&E | COCOSB_6_SOLAR           |       |          |      | 0.00   |            | Bay Area         | Contra Costa                        | Not modeled<br>Energy Only           | Solar        |
| PG&E | CROKET_7_UNIT            | 32900 | CRCKTCOG | 18   | 223.00 | 1          | Bay Area         | Pittsburg                           | Could retire<br>by 2039. Aug<br>NQC  | QF/Selfgen   |
| PG&E | CSCCOG_1_UNIT 1          |       |          |      | 0.00   |            | Bay Area         | San Jose, South<br>Bay-Moss Landing | Could retired<br>by 2034             | MUNI         |
| PG&E | CSCGNR_1_UNIT 1          | 36858 | Gia100   | 13.8 | 24.00  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing | Could retire<br>by 2039              | MUNI         |
| PG&E | CSCGNR_1_UNIT 2          | 36895 | Gia200   | 13.8 | 24.00  | 2          | Bay Area         | San Jose, South<br>Bay-Moss Landing | Could retire<br>by 2039              | MUNI         |
| PG&E | CUMBIA_1_SOLAR           | 33102 | COLUMBIA | 0.38 | 2.36   | 1          | Bay Area         | Pittsburg                           | Aug NQC                              | Solar        |
| PG&E | DELTA_2_PL1X4            | 33108 | DEC CTG1 | 18   | 194.50 | 1          | Bay Area         | Pittsburg                           | Aug NQC                              | Market       |
| PG&E | DELTA_2_PL1X4            | 33109 | DEC CTG2 | 18   | 194.50 | 1          | Bay Area         | Pittsburg                           | Aug NQC                              | Market       |
| PG&E | DELTA_2_PL1X4            | 33110 | DEC CTG3 | 18   | 194.50 | 1          | Bay Area         | Pittsburg                           | Aug NQC                              | Market       |
| PG&E | DELTA_2_PL1X4            | 33107 | DEC STG1 | 24   | 289.49 | 1          | Bay Area         | Pittsburg                           | Aug NQC                              | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME   | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                     | NQC<br>Comments               | CAISO<br>Tag |
|------|--------------------------|--------|------------|------|--------|------------|------------------|--|-------------------------------|--------------|
| PG&E | DIXNLD_1_LNDFL           |        |            |      | 0.87   |            | Bay Area         | San Jose, South Bay-Moss Landing         | Not modeled Aug NQC           | Market       |
| PG&E | DUANE_1_PL1X3            | 36865  | DVRaST3    | 13.8 | 46.96  | 1          | Bay Area         | San Jose, South Bay-Moss Landing         | Could retired by 2039         | MUNI         |
| PG&E | DUANE_1_PL1X3            | 36863  | DVRaGT1    | 13.8 | 48.27  | 1          | Bay Area         | San Jose, South Bay-Moss Landing         | Could retired by 2039         | MUNI         |
| PG&E | DUANE_1_PL1X3            | 36864  | DVRbGT2    | 13.8 | 48.27  | 1          | Bay Area         | San Jose, South Bay-Moss Landing         | Could retired by 2039         | MUNI         |
| PG&E | ELKHRN_1_EESX3           | 366108 | Q1374BESS2 | 0.51 | 60.00  | 2          | Bay Area         | South Bay-Moss Landing                   |                               | Battery      |
| PG&E | ELKHRN_1_EESX3           | 366109 | Q1374BESS3 | 0.51 | 60.00  | 3          | Bay Area         | South Bay-Moss Landing                   |                               | Battery      |
| PG&E | ELKHRN_1_EESX3           | 366107 | Q1374BESS1 | 0.51 | 62.50  | 1          | Bay Area         | South Bay-Moss Landing                   |                               | Battery      |
| PG&E | GATWAY_2_PL1X3           | 33119  | GATEWAY2   | 18   | 163.61 | 1          | Bay Area         | Contra Costa                             | Could retire by 2039. Aug NQC | Market       |
| PG&E | GATWAY_2_PL1X3           | 33120  | GATEWAY3   | 18   | 163.61 | 1          | Bay Area         | Contra Costa                             | Could retire by 2039. Aug NQC | Market       |
| PG&E | GATWAY_2_PL1X3           | 33118  | GATEWAY1   | 18   | 172.79 | 1          | Bay Area         | Contra Costa                             | Could retire by 2039. Aug NQC | Market       |
| PG&E | GILROY_1_UNIT            | 35871  | GILROYEN   | 13.8 | 39.43  | 2          | Bay Area         | Llagas, San Jose, South Bay-Moss Landing | Aug NQC                       | Market       |
| PG&E | GILROY_1_UNIT            | 35850  | GILROYEN   | 13.8 | 75.57  | 1          | Bay Area         | Llagas, San Jose, South Bay-Moss Landing | Aug NQC                       | Market       |
| PG&E | GILRPP_1_PL1X2           | 35851  | GROYPKR1   | 13.8 | 47.60  | 1          | Bay Area         | Llagas, San Jose, South Bay-Moss Landing | Aug NQC                       | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME    | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                           | NQC<br>Comments                     | CAISO<br>Tag |
|------|--------------------------|-------|-------------|------|--------|------------|------------------|--|-------------------------------------|--------------|
| PG&E | GILRPP_1_PL1X2           | 35852 | GROYPKR2    | 13.8 | 47.60  | 1          | Bay Area         | Llagas, San Jose,<br>South Bay-Moss<br>Landing | Aug NQC                             | Market       |
| PG&E | GILRPP_1_PL3X4           | 35853 | GROYPKR3    | 13.8 | 46.20  | 1          | Bay Area         | Llagas, San Jose,<br>South Bay-Moss<br>Landing | Aug NQC                             | Market       |
| PG&E | GRZZLY_1_BERKLY          | 32741 | HILLSIDE_12 | 12.5 | 0.31   | 1          | Bay Area         |  | Aug NQC                             | Net Seller   |
| PG&E | KELSO_2_UNITS            | 33813 | MARIPCT1    | 13.8 | 49.51  | 1          | Bay Area         | Contra Costa                                   | Aug NQC                             | Market       |
| PG&E | KELSO_2_UNITS            | 33815 | MARIPCT2    | 13.8 | 49.51  | 2          | Bay Area         | Contra Costa                                   | Aug NQC                             | Market       |
| PG&E | KELSO_2_UNITS            | 33817 | MARIPCT3    | 13.8 | 49.51  | 3          | Bay Area         | Contra Costa                                   | Aug NQC                             | Market       |
| PG&E | KELSO_2_UNITS            | 33819 | MARIPCT4    | 13.8 | 49.51  | 4          | Bay Area         | Contra Costa                                   | Aug NQC                             | Market       |
| PG&E | KIRKER_7_KELCYN          |       |             |      | 3.41   |            | Bay Area         | Pittsburg                                      | Not modeled                         | Market       |
| PG&E | LAWRNC_7_SUNYVL          |       |             |      | 0.15   |            | Bay Area         |  | Not modeled<br>Aug NQC              | Market       |
| PG&E | LECEF_1_UNITS            | 35854 | LECEFGT1    | 13.8 | 46.72  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing            | Aug NQC                             | Market       |
| PG&E | LECEF_1_UNITS            | 35855 | LECEFGT2    | 13.8 | 46.72  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing            | Aug NQC                             | Market       |
| PG&E | LECEF_1_UNITS            | 35856 | LECEFGT3    | 13.8 | 46.72  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing            | Aug NQC                             | Market       |
| PG&E | LECEF_1_UNITS            | 35857 | LECEFGT4    | 13.8 | 46.72  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing            | Aug NQC                             | Market       |
| PG&E | LECEF_1_UNITS            | 35858 | LECEfst1    | 13.8 | 112.13 | 1          | Bay Area         | San Jose, South Bay-Moss<br>Landing            |                                     | Market       |
| PG&E | LMBEPK_2_UNITA1          | 32173 | LAMBIE      | 13.8 | 47.50  | 1          | Bay Area         | Contra Costa                                   | Aug NQC                             | Market       |
| PG&E | LMBEPK_2_UNITA2          | 32174 | GOOSEHAV    | 13.8 | 47.60  | 3          | Bay Area         | Contra Costa                                   | Aug NQC                             | Market       |
| PG&E | LMBEPK_2_UNITA3          | 32175 | CREED       | 13.8 | 47.75  | 2          | Bay Area         | Contra Costa                                   | Aug NQC                             | Market       |
| PG&E | LMEC_1_PL1X3             | 33111 | LMECCT2     | 18   | 166.98 | 1          | Bay Area         | Pittsburg                                      | Could retire<br>by 2039. Aug<br>NQC | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME  | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                | NQC<br>Comments                     | CAISO<br>Tag |
|------|--------------------------|-------|-----------|------|--------|------------|------------------|-------------------------------------|-------------------------------------|--------------|
| PG&E | LMEC_1_PL1X3             | 33112 | LMECCT1   | 18   | 166.98 | 1          | Bay Area         | Pittsburg                           | Could retire<br>by 2039. Aug<br>NQC | Market       |
| PG&E | LMEC_1_PL1X3             | 33113 | LMECST1   | 18   | 246.03 | 1          | Bay Area         | Pittsburg                           | Could retire<br>by 2039. Aug<br>NQC | Market       |
| PG&E | MARTIN_1_SUNSET          |       |           |      | 0.56   |            | Bay Area         |                                     | Not modeled<br>Aug NQC              | QF/Selfgen   |
| PG&E | METEC_2_PL1X3            | 35881 | MEC CTG1  | 18   | 186.90 | 1          | Bay Area         | South Bay-Moss<br>Landing           | Aug NQC                             | Market       |
| PG&E | METEC_2_PL1X3            | 35882 | MEC CTG2  | 18   | 186.90 | 1          | Bay Area         | South Bay-Moss<br>Landing           | Aug NQC                             | Market       |
| PG&E | METEC_2_PL1X3            | 35883 | MEC STG1  | 18   | 223.24 | 1          | Bay Area         | South Bay-Moss<br>Landing           | Aug NQC                             | Market       |
| PG&E | MISSIX_1_QF              | 33250 | MISSON_D4 | 12.5 | 0.01   | 1          | Bay Area         | Ames                                | Aug NQC                             | QF/Selfgen   |
| PG&E | MLPTAS_7_QFUNTS          |       |           |      | 0.00   |            | Bay Area         | San Jose, South<br>Bay-Moss Landing | Not modeled<br>Aug NQC              | QF/Selfgen   |
| PG&E | MOSSLD_2_PSP1            | 36221 | DUKMOSS1  | 18   | 163.20 | 1          | Bay Area         | South Bay-Moss<br>Landing           |                                     | Market       |
| PG&E | MOSSLD_2_PSP1            | 36222 | DUKMOSS2  | 18   | 163.20 | 1          | Bay Area         | South Bay-Moss<br>Landing           |                                     | Market       |
| PG&E | MOSSLD_2_PSP1            | 36223 | DUKMOSS3  | 18   | 183.60 | 1          | Bay Area         | South Bay-Moss<br>Landing           |                                     | Market       |
| PG&E | MOSSLD_2_PSP2            | 36224 | DUKMOSS4  | 18   | 163.20 | 1          | Bay Area         | South Bay-Moss<br>Landing           |                                     | Market       |
| PG&E | MOSSLD_2_PSP2            | 36225 | DUKMOSS5  | 18   | 163.20 | 1          | Bay Area         | South Bay-Moss<br>Landing           |                                     | Market       |
| PG&E | MOSSLD_2_PSP2            | 36226 | DUKMOSS6  | 18   | 183.60 | 1          | Bay Area         | South Bay-Moss<br>Landing           |                                     | Market       |
| PG&E | NEWARK_1_QF              |       |           |      | 0.03   |            | Bay Area         |                                     | Not modeled<br>Aug NQC              | QF/Selfgen   |
| PG&E | OAK C_1_EBMUD            |       |           |      | 1.70   |            | Bay Area         | Oakland                             | Not modeled<br>Aug NQC              | MUNI         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments                         | CAISO<br>Tag |
|------|--------------------------|-------|----------|------|--------|------------|------------------|----------------------|---|--------------|
| PG&E | OAK C_7_UNIT 1           | 32901 | OAKLND 1 | 13.8 | 55.00  | 1          | Bay Area         | Oakland              | Could retire<br>by 2039                 | Market       |
| PG&E | OAK C_7_UNIT 3           | 32903 | OAKLND 3 | 13.8 | 55.00  | 1          | Bay Area         | Oakland              | Could retire<br>by 2026                 | Market       |
| PG&E | OAK L_1_GTG1             |       |          |      | 0.00   |            | Bay Area         | Oakland              | Not modeled<br>Energy Only              | Market       |
| PG&E | OXMTN_6_LNDFIL           | 33469 | OX_MTN   | 4.16 | 1.47   | 1          | Bay Area         | Ames                 |   | Market       |
| PG&E | OXMTN_6_LNDFIL           | 33469 | OX_MTN   | 4.16 | 1.47   | 2          | Bay Area         | Ames                 |   | Market       |
| PG&E | OXMTN_6_LNDFIL           | 33469 | OX_MTN   | 4.16 | 1.47   | 3          | Bay Area         | Ames                 |   | Market       |
| PG&E | OXMTN_6_LNDFIL           | 33469 | OX_MTN   | 4.16 | 1.47   | 4          | Bay Area         | Ames                 |   | Market       |
| PG&E | OXMTN_6_LNDFIL           | 33469 | OX_MTN   | 4.16 | 1.47   | 5          | Bay Area         | Ames                 |   | Market       |
| PG&E | OXMTN_6_LNDFIL           | 33469 | OX_MTN   | 4.16 | 1.47   | 6          | Bay Area         | Ames                 |   | Market       |
| PG&E | OXMTN_6_LNDFIL           | 33469 | OX_MTN   | 4.16 | 1.47   | 7          | Bay Area         | Ames                 |   | Market       |
| PG&E | PALALT_7_COBUG           |       |          |      | 4.50   |            | Bay Area         |                      | Could retire<br>by 2039. Not<br>modeled | MUNI         |
| PG&E | RICHMN_1_CHVSR2          |       |          |      | 1.05   |            | Bay Area         |                      | Not modeled<br>Aug NQC                  | Solar        |
| PG&E | RICHMN_1_SOLAR           |       |          |      | 0.25   |            | Bay Area         |                      | Not modeled<br>Aug NQC                  | Solar        |
| PG&E | RICHMN_7_BAYENV          |       |          |      | 0.37   |            | Bay Area         |                      | Not modeled<br>Aug NQC                  | Market       |
| PG&E | RUSCTY_2_UNITS           | 35304 | RUSELCT1 | 15   | 180.15 | 1          | Bay Area         | Ames                 | No NQC -<br>Pmax                        | Market       |
| PG&E | RUSCTY_2_UNITS           | 35305 | RUSELCT2 | 15   | 180.15 | 2          | Bay Area         | Ames                 | No NQC -<br>Pmax                        | Market       |
| PG&E | RUSCTY_2_UNITS           | 35306 | RUSELST1 | 15   | 237.09 | 3          | Bay Area         | Ames                 | No NQC -<br>Pmax                        | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME    | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments                     | CAISO<br>Tag |
|------|--------------------------|--------|-------------|------|-------|------------|------------------|----------------------|-------------------------------------|--------------|
| PG&E | RVRVIEW_1_UNITA1         | 33178  | RVEC_GEN    | 13.8 | 47.60 | 1          | Bay Area         | Contra Costa         | Could retire<br>by 2039. Aug<br>NQC | Market       |
| PG&E | SHELRF_1_UNITS           | 33141  | SHELL 1     | 12.5 | 0.00  | 1          | Bay Area         | Pittsburg            | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| PG&E | SHELRF_1_UNITS           | 33142  | SHELL 2     | 12.5 | 0.00  | 1          | Bay Area         | Pittsburg            | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| PG&E | SHELRF_1_UNITS           | 33143  | SHELL 3     | 12.5 | 0.00  | 1          | Bay Area         | Pittsburg            | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| PG&E | SRINTL_6_UNIT            | 33468  | SRI INTL    | 9.11 | 0.96  | 1          | Bay Area         |                      | Could retire<br>by 2039. Aug<br>NQC | QF/Selfgen   |
| PG&E | STOILS_1_UNITS           | 32923  | CHEVGEN3    | 13.8 | 1.77  | 3          | Bay Area         | Pittsburg            | Aug NQC                             | Market       |
| PG&E | STOILS_1_UNITS           | 32921  | CHEVGEN1    | 13.8 | 3.83  | 1          | Bay Area         | Pittsburg            | Aug NQC                             | Market       |
| PG&E | STOILS_1_UNITS           | 32922  | CHEVGEN2    | 13.8 | 3.83  | 1          | Bay Area         | Pittsburg            | Aug NQC                             | Market       |
| PG&E | TIDWTR_2_UNITS           | 33151  | FOSTER W    | 12.5 | 22.57 | 3          | Bay Area         | Pittsburg            | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| PG&E | TIDWTR_2_UNITS           | 33151  | FOSTER W    | 12.5 | 29.66 | 1          | Bay Area         | Pittsburg            | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| PG&E | TIDWTR_2_UNITS           | 33151  | FOSTER W    | 12.5 | 29.66 | 2          | Bay Area         | Pittsburg            | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| PG&E | UNOCAL_1_UNITS           | 32910  | UNOCAL      | 12   | 0.73  | 2          | Bay Area         | Pittsburg            | Aug NQC                             | QF/Selfgen   |
| PG&E | UNOCAL_1_UNITS           | 32910  | UNOCAL      | 12   | 0.73  | 3          | Bay Area         | Pittsburg            | Aug NQC                             | QF/Selfgen   |
| PG&E | UNOCAL_1_UNITS           | 32910  | UNOCAL      | 12   | 0.73  | 1          | Bay Area         | Pittsburg            | Aug NQC                             | QF/Selfgen   |
| PG&E | USWNR_2_LABWD1           | 365729 | LABRISAWIND | 0.58 | 1.90  | 1          | Bay Area         | Contra Costa         | Aug NQC                             | Wind         |
| PG&E | USWNR_2_SMUD             | 365566 | SOLANO1W    | 0.69 | 3.24  | 1          | Bay Area         | Contra Costa         | Aug NQC                             | Wind         |
| PG&E | USWNR_2_SMUD             | 365574 | SOLANO2W    | 1    | 18.38 | 2          | Bay Area         | Contra Costa         | Aug NQC                             | Wind         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME    | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                | NQC<br>Comments        | CAISO<br>Tag |
|------|--------------------------|--------|-------------|------|--------|------------|------------------|-------------------------------------|------------------------|--------------|
| PG&E | USWNDR_2_SMUD2           | 365600 | SOLANO3W    | 1    | 27.04  | 3          | Bay Area         | Contra Costa                        | Aug NQC                | Wind         |
| PG&E | USWPFK_6_FRICK           | 365608 | FRICKWIND   | 0.69 | 2.12   | 1          | Bay Area         | Contra Costa                        | Aug NQC                | Wind         |
| PG&E | USWPJR_2_UNITS           | 39233  | GRNRDG      | 0.69 | 16.55  | 1          | Bay Area         | Contra Costa                        | Aug NQC                | Wind         |
| PG&E | VISTRA_5_DALBT1          | 366711 | DALLASBESS1 | 34.5 | 100.00 | 1          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | VISTRA_5_DALBT2          | 366712 | DALLASBESS2 | 34.5 | 100.00 | 2          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | VISTRA_5_DALBT3          | 366713 | DALLASBESS3 | 34.5 | 100.00 | 3          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | VISTRA_5_DALBT4          | 366715 | DALLASBESS4 | 34.5 | 100.00 | 4          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | VISTRA_5_PLABT1          | 366244 | PLANOBESS4  | 34.5 | 100.40 | 4          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | VISTRA_5_PLABT2          | 366243 | PLANOBESS3  | 34.5 | 100.40 | 3          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | VISTRA_5_PLABT3          | 366242 | PLANOBESS2  | 34.5 | 74.60  | 2          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | VISTRA_5_PLABT4          | 366241 | PLANOBESS1  | 34.5 | 74.60  | 1          | Bay Area         | South Bay-Moss<br>Landing           |                        | Battery      |
| PG&E | WNDMAS_2_UNIT 1          | 33173  | BVISTAWND   | 0.6  | 8.04   | 1          | Bay Area         | Contra Costa                        | Aug NQC                | Wind         |
| PG&E | ZOND_6_UNIT              |        |             |      | 3.62   |            | Bay Area         | Contra Costa                        | Not modeled<br>Aug NQC | Wind         |
| PG&E | ZZ_FLOWD1_6_ALTPP1       | 35318  | FLOWPTR     | 9.11 | 1.80   | 1          | Bay Area         | Contra Costa                        | No NQC -<br>est. data  | Wind         |
| PG&E | ZZ_IMHOFF_1_UNIT 1       | 33136  | CCCSD       | 12.5 | 0.00   | 1          | Bay Area         | Pittsburg                           | No NQC -<br>hist. data | QF/Selfgen   |
| PG&E | ZZ_MOSSLD_1_QF           |        |             |      | 0.00   |            | Bay Area         |                                     | Not modeled<br>Aug NQC | QF/Selfgen   |
| PG&E | ZZ_NA                    | 35861  | SJ-SCL W    | 4.3  | 0.00   | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing | No NQC -<br>hist. data | QF/Selfgen   |
| PG&E | ZZ_NA                    | 36209  | SLD ENRG    | 12.5 | 0.00   | 1          | Bay Area         | South Bay-Moss<br>Landing           |                        | QF/Selfgen   |
| PG&E | ZZ_ZANKER_1_UNIT 1       | 35861  | SJ-SCL W    | 4.3  | 0.00   | RN         | Bay Area         | San Jose, South<br>Bay-Moss Landing | No NQC -<br>hist. data | QF/Selfgen   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                | NQC<br>Comments           | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|-------------------------------------|---------------------------|--------------|
| PG&E | ZZZ_New Unit             | 365540 | CHEVRONS         | 12.5 | 0.00  | 1          | Bay Area         |                                     | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 365685 | P66RODEO_1       | 12   | 0.00  | 1          | Bay Area         | Pittsburg                           | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 38921  | SPJ              | 60   | 0.00  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing | Waiting TPD<br>allocation | Battery      |
| PG&E | ZZZ_New Unit             | 366328 | Q1349SPV         | 0.55 | 0.00  | 1          | Bay Area         | Contra Costa                        | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 32741  | HILLSIDE_12      | 12.5 | 0.00  | 2          | Bay Area         |                                     | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 32172  | HIGHWINDS        | 34.5 | 0.00  | 2          | Bay Area         | Contra Costa                        | Energy Only               | Wind         |
| PG&E | ZZZ_New Unit             | 365617 | OAKLANDES3       | 13.8 | 0.00  | 3          | Bay Area         | Oakland                             | On Hold                   | Battery      |
| PG&E | ZZZ_New Unit             | 32788  | STATIN L         | 115  | 0.00  | ES         | Bay Area         | Oakland                             | Energy Only               | Battery      |
| PG&E | ZZZ_New Unit             | 92296  | 2296-WD          | 230  | 0.00  | EW         | Bay Area         | Contra Costa                        | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 92154  | 2154-WD          | 230  | 0.00  | EW         | Bay Area         | Contra Costa                        | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 92849  | 2849-WD          | 115  | 0.00  | EW         | Bay Area         |                                     | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 92848  | 2848-WD          | 115  | 0.00  | EW         | Bay Area         |                                     | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 92598  | 2598-WD          | 230  | 0.00  | EW         | Bay Area         | Contra Costa                        | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 92333  | 2333-WD          | 230  | 0.00  | EW         | Bay Area         | Contra Costa                        | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 33103  | TASSAJARA_<br>D1 | 21.6 | 0.00  | RE         | Bay Area         | Pittsburg                           | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 36232  | CAMPEVERS_<br>D1 | 21.6 | 0.00  | RE         | Bay Area         | South Bay-Moss<br>Landing           | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 33450  | FACEBOOKBH       | 12   | 0.00  | RE         | Bay Area         | Ames                                | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 365688 | 2509-RD-SPV      | 0.63 | 0.00  | RE         | Bay Area         | Pittsburg                           | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 35863  | CATALYST         | 12.5 | 0.00  | RE         | Bay Area         | San Jose, South<br>Bay-Moss Landing | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 365338 | GRANITEROC<br>K  | 4.16 | 0.00  | RE         | Bay Area         | South Bay-Moss<br>Landing           | Energy Only               | Solar        |
| PG&E | ZZZ_New Unit             | 32741  | HILLSIDE_12      | 12.5 | 0.00  | RN         | Bay Area         |                                     | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 365559 | STANFORD         | 12.5 | 0.00  | RN         | Bay Area         |                                     | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 35302  | NUMMI-LV         | 12.6 | 0.00  | RN         | Bay Area         |                                     | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 35859  | HGST-LV          | 12.4 | 0.00  | RN         | Bay Area         |                                     | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 35307  | A100US-L         | 12.6 | 0.00  | RN         | Bay Area         |                                     | Energy Only               | Market       |
| PG&E | ZZZ_New Unit             | 365348 | HOLLISTER_D<br>1 | 21   | 10.00 | 1          | Bay Area         | South Bay-Moss<br>Landing           | No NQC -<br>est. data     | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                           | NQC<br>Comments       | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|--------|------------|------------------|--|-----------------------|--------------|
| PG&E | ZZZ_New Unit             | 365342 | MGRNHILL_D1      | 21   | 20.00  | 1          | Bay Area         | Llagas, San Jose,<br>South Bay-Moss<br>Landing | No NQC -<br>est. data | Battery      |
| PG&E | ZZZ_New Unit             | 366394 | Q1454B           | 0.69 | 75.00  | 1          | Bay Area         | San Jose, South<br>Bay-Moss Landing            | No NQC -<br>est. data | Battery      |
| PG&E | ZZZ_New Unit             | 366330 | Q1349BESS        | 0.55 | 100.00 | 2          | Bay Area         | Contra Costa                                   | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit           | 399999 | BODEGAENER<br>GY | 60   | 0.00   | EW         | Bay Area         | South Bay-Moss<br>Landing                      | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 399998 | GREENVALLE<br>YR | 60   | 0.00   | EW         | Bay Area         | South Bay-Moss<br>Landing                      | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 92597  | 2597-WD          | 115  | 0.00   | EW         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397072 | MARTIN C1-25     | 25   | 0.11   | VS         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397062 | DUMBARTN1-<br>25 | 25   | 0.12   | VS         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397070 | LONETREE1-<br>25 | 25   | 0.12   | VS         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397083 | SANRAMON1-<br>25 | 25   | 0.24   | VS         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397061 | DIXON LD1-25     | 25   | 0.29   | VS         | Bay Area         | San Jose, South<br>Bay-Moss Landing            | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397081 | RICHMOND1-<br>25 | 25   | 0.33   | VS         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397067 | KIRKER 1-25      | 25   | 0.48   | VS         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397087 | SOBRANTE1-<br>25 | 25   | 0.62   | VS         | Bay Area         |  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397005 | BRENTWOD1-<br>25 | 25   | 0.92   | VB         | Bay Area         |  | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397026 | MTCALF D1-25     | 25   | 1.67   | VB         | Bay Area         | South Bay-Moss<br>Landing                      | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 92495  | 2495-WD          | 115  | 10.00  | FW         | Bay Area         | South Bay-Moss<br>Landing                      | No NQC -<br>est. data | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID  | BUS #  | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                           | NQC<br>Comments       | CAISO<br>Tag |
|------|---------------------------|--------|------------------|------|--------|------------|------------------|--|-----------------------|--------------|
| PG&E | ZZZZA_New Unit            | 366380 | SOLANO4WIN<br>D  | 0.72 | 19.74  | 4          | Bay Area         | Contra Costa                                   | No NQC -<br>est. data | Wind         |
| PG&E | ZZZZA_New Unit            | 397117 | KIRKER 1-25      | 25   | 20.00  | E4         | Bay Area         |  | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit            | 397111 | BDLSWSTA1-<br>25 | 25   | 38.40  | E8         | Bay Area         | Contra Costa                                   | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit            | 397043 | KELSO 1-25       | 25   | 41.47  | VW         | Bay Area         | Contra Costa                                   | No NQC -<br>est. data | Wind         |
| PG&E | ZZZZA_New Unit            | 397118 | LLAGAS 1-25      | 25   | 44.00  | E8         | Bay Area         | Llagas, San Jose,<br>South Bay-Moss<br>Landing | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit            | 397037 | BDLSWSTA1-<br>25 | 25   | 44.44  | VW         | Bay Area         | Contra Costa                                   | No NQC -<br>est. data | Wind         |
| PG&E | ZZZZA_New Unit            | 397120 | LS ESTRS1-25     | 25   | 206.00 | En         | Bay Area         | San Jose, South<br>Bay-Moss Landing            | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit            | 397121 | MARTIN C1-25     | 25   | 250.00 | En         | Bay Area         |  | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit            | 397122 | MTCALF E1-25     | 25   | 300.00 | En         | Bay Area         | South Bay-Moss<br>Landing                      | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZAB_New Unit           | 397298 | BDLSWSTA1-<br>25 | 25   | 23.56  | VS         | Bay Area         | Contra Costa                                   | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZAB_New Unit           | 397352 | MOSSLAND1-<br>25 | 25   | 500.00 | VE         | Bay Area         | South Bay-Moss<br>Landing                      | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZZ_MARKHM_1_CATL<br>ST | 35863  | CATALYST         | 12.5 | 0.00   | 1          | Bay Area         | San Jose, South Bay-Moss<br>Landing            |                       | QF/Selfgen   |
| PG&E | ZZZZZ_STAUFF_1_UNIT       | 33139  | STAUFER          | 9.11 | 0.00   | 1          | Bay Area         |  | Retired               | QF/Selfgen   |
| PG&E | ZZZZZ_UNCHEM_1_UNIT       | 32920  | UNION CH         | 9.11 | 0.00   | 1          | Bay Area         | Pittsburg                                      | Retired               | QF/Selfgen   |
| PG&E | ADERA_1_SOLAR1            | 34319  | ADERASLR         | 0.48 | 0.00   | 1          | Fresno           | Herndon, Panoche<br>115 kV, Wilson<br>115 kV   | Energy Only           | Solar        |
| PG&E | ADMEST_6_SOLAR            | 34315  | ADAMS_E          | 12.5 | 2.36   | 1          | Fresno           | Herndon  |                       | Solar        |
| PG&E | AGRICO_6_PL3N5            | 34608  | AGRICO           | 13.8 | 22.69  | 3          | Fresno           | Herndon  |                       | Market       |
| PG&E | AGRICO_7_UNIT             | 34608  | AGRICO           | 13.8 | 7.47   | 2          | Fresno           | Herndon  |                       | Market       |
| PG&E | AGRICO_7_UNIT             | 34608  | AGRICO           | 13.8 | 43.13  | 4          | Fresno           | Herndon  |                       | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                         | NQC<br>Comments                    | CAISO<br>Tag |
|------|--------------------------|--------|-----------------|------|-------|------------|------------------|--|------------------------------------|--------------|
| PG&E | AKINGS_6_AMESR1          | 34688  | AMRCNKNK        | 0.36 | 15.25 | 1          | Fresno           | Hanford                                      | Aug NQC                            | Solar        |
| PG&E | AVENAL_6_AVPARK          | 34265  | AVENAL_P        | 12   | 0.74  | 1          | Fresno           | Coalinga                                     | Aug NQC                            | Solar        |
| PG&E | AVENAL_6_AVSLR1          | 34691  | AVENAL_D        | 21   | 0.00  | 1          | Fresno           | Coalinga                                     | Energy Only                        | Solar        |
| PG&E | AVENAL_6_AVSLR2          | 34691  | AVENAL_D        | 21   | 0.00  | 1          | Fresno           | Coalinga                                     | Energy Only                        | Solar        |
| PG&E | AVENAL_6_SANDDG          | 34263  | SANDDRAG        | 12   | 1.97  | 1          | Fresno           | Coalinga                                     | Aug NQC                            | Solar        |
| PG&E | AVENAL_6_SUNCTY          | 34257  | SUNCTY D        | 12   | 2.48  | 1          | Fresno           | Coalinga                                     | Aug NQC                            | Solar        |
| PG&E | BALCHS_7_UNIT 1          | 34624  | BALCH 1         | 13.2 | 31.00 | 1          | Fresno           | Herndon                                      | Aug NQC                            | Market       |
| PG&E | BALCHS_7_UNIT 2          | 34612  | BLCH 2-3        | 13.8 | 52.50 | 1          | Fresno           | Herndon                                      | Aug NQC                            | Market       |
| PG&E | BALCHS_7_UNIT 3          | 34614  | BLCH 2-3        | 13.8 | 54.60 | 1          | Fresno           | Herndon                                      | Aug NQC                            | Market       |
| PG&E | CABALO_2_M2BSR1          | 365524 | MUSTANG4        | 0.36 | 6.20  | 2          | Fresno           |  | Aug NQC                            | Solar        |
| PG&E | CABALO_2_M2WSR2          | 365523 | MUSTANG3        | 0.36 | 12.40 | 1          | Fresno           |  | Aug NQC                            | Solar        |
| PG&E | CANTUA_1_SOLAR           | 34349  | CANTUA_D        | 12.5 | 1.24  | 1          | Fresno           | Panoche 115 kV                               | Aug NQC                            | Solar        |
| PG&E | CANTUA_1_SOLAR           | 34349  | CANTUA_D        | 12.5 | 1.24  | 2          | Fresno           | Panoche 115 kV                               | Aug NQC                            | Solar        |
| PG&E | CHEVCO_6_UNIT 1          | 34652  | CHV.COAL        | 9.11 | 0.00  | 1          | Fresno           | Coalinga, Panoche<br>115 kV                  | Potential<br>Retirement<br>by 2034 | QF/Selfgen   |
| PG&E | CHEVCO_6_UNIT 2          | 34652  | CHV.COAL        | 9.11 | 0.73  | 2          | Fresno           | Coalinga, Panoche<br>115 kV                  | Aug NQC                            | QF/Selfgen   |
| PG&E | CHWCHL_1_UNIT            | 34301  | CHOWCOGN        | 13.8 | 0.00  | 1          | Fresno           | Herndon, Panoche<br>115 kV, Wilson<br>115 kV | Potential<br>Retirement<br>by 2034 | Market       |
| PG&E | CORCAN_1_SOLAR1          | 34690  | CORCORAN_<br>D3 | 12.5 | 2.48  | 1          | Fresno           | Herndon, Hanford                             | Aug NQC                            | Solar        |
| PG&E | CORCAN_1_SOLAR2          | 34692  | CORCORAN_<br>D4 | 12.5 | 1.36  | 1          | Fresno           | Herndon, Hanford                             | Aug NQC                            | Solar        |
| PG&E | CRESSY_1_PARKER          | 34140  | CRESSEY         | 115  | 1.03  |            | Fresno           |  | Not modeled<br>Aug NQC             | MUNI         |
| PG&E | CRNEVL_6_CRNVA           | 34634  | CRANEVLY        | 12   | 0.00  | 1          | Fresno           | Borden                                       | Aug NQC                            | Market       |
| PG&E | CRNEVL_6_SJQN 2          | 34631  | SJ2GEN          | 9.11 | 0.00  | 1          | Fresno           | Borden                                       | Aug NQC                            | Market       |
| PG&E | CURTIS_1_CANLCK          |        |                 |      | 0.00  |            | Fresno           |  | Not modeled<br>Aug NQC             | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME             | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|-------|-----------------|------|-------|------------|------------------|----------------------------------|----------------------------|--------------|
| PG&E | CURTIS_1_FARFLD          |       |                 |      | 0.28  |            | Fresno           |                                  | Not modeled<br>Aug NQC     | Market       |
| PG&E | DAIRLD_1_MD1SL1          |       |                 |      | 0.00  |            | Fresno           | Panoche 115 kV                   | Not modeled<br>Energy Only | Solar        |
| PG&E | DAIRLD_1_MD2BM1          |       |                 |      | 0.00  |            | Fresno           | Panoche 115 kV                   | Not modeled<br>Energy Only | Market       |
| PG&E | EEKTMN_6_SOLAR1          | 34629 | KETTLEMN        | 0.8  | 0.00  | 1          | Fresno           |                                  | Energy Only                | Solar        |
| PG&E | ELCAP_1_SOLAR            |       |                 |      | 0.00  |            | Fresno           |                                  | Not Modeled<br>Aug NQC     | Solar        |
| PG&E | EXCHEC_7_UNIT 1          | 34306 | EXCHQUER        | 13.8 | 94.50 | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | Aug NQC                    | MUNI         |
| PG&E | EXCLSG_1_SOLAR           | 34623 | EXCLSRSL        | 0.5  | 7.44  | 1          | Fresno           | Panoche 115 kV                   | Aug NQC                    | Solar        |
| PG&E | FRESHW_1_SOLAR1          | 34699 | FRSHWTRSLR      | 0.39 | 0.00  | 1          | Fresno           | Herndon                          | Energy Only                | Solar        |
| PG&E | FRIANT_6_UNITS           | 34636 | FRIANTDAM       | 6.6  | 0.35  | 4          | Fresno           | Borden                           | Aug NQC                    | Net Seller   |
| PG&E | FRIANT_6_UNITS           | 34636 | FRIANTDAM       | 6.6  | 1.32  | 3          | Fresno           | Borden                           | Aug NQC                    | Net Seller   |
| PG&E | FRIANT_6_UNITS           | 34636 | FRIANTDAM       | 6.6  | 2.47  | 2          | Fresno           | Borden                           | Aug NQC                    | Net Seller   |
| PG&E | GIFENS_6_BUGSL1          | 34644 | BRFRDGFNSP<br>V | 0.55 | 2.48  | 1          | Fresno           |                                  | Aug NQC                    | Solar        |
| PG&E | GIFFEN_6_SOLAR           | 34467 | GIFFEN_DIST     | 12.5 | 1.24  | 1          | Fresno           | Herndon                          | Aug NQC                    | Solar        |
| PG&E | GIFFEN_6_SOLAR1          |       |                 |      | 0.00  |            | Fresno           | Herndon                          | Not modeled<br>Energy Only | Solar        |
| PG&E | GUERNS_6_HD3BM3          |       |                 |      | 0.00  |            | Fresno           |                                  | Not modeled<br>Energy Only | Market       |
| PG&E | GUERNS_6_SOLAR           | 34463 | GUERNSEY_D<br>2 | 12.5 | 1.24  | 5          | Fresno           |                                  | Aug NQC                    | Solar        |
| PG&E | GUERNS_6_SOLAR           | 34461 | GUERNSEY_D<br>1 | 12.5 | 1.24  | 8          | Fresno           |                                  | Aug NQC                    | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME        | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|-------|------------------|------|--------|------------|------------------|-----------------------------|----------------------------|--------------|
| PG&E | GUERNS_6_VH2BM1          |       |                  |      | 0.00   |            | Fresno           |                             | Not modeled<br>Energy Only | Market       |
| PG&E | GWFPWR_1_UNITS           | 34431 | HANFORDPPC<br>T1 | 13.8 | 49.23  | 1          | Fresno           | Herndon, Hanford            |                            | Market       |
| PG&E | GWFPWR_1_UNITS           | 34433 | HANFORDPPC<br>T2 | 13.8 | 49.23  | 1          | Fresno           | Herndon, Hanford            |                            | Market       |
| PG&E | HAASPH_7_PL1X2           | 34610 | HAAS             | 13.8 | 72.00  | 1          | Fresno           | Herndon                     | Aug NQC                    | Market       |
| PG&E | HAASPH_7_PL1X2           | 34610 | HAAS             | 13.8 | 72.00  | 2          | Fresno           | Herndon                     | Aug NQC                    | Market       |
| PG&E | HARDWK_6_STWBM1          |       |                  |      | 0.00   |            | Fresno           |                             | Not modeled<br>Energy Only | Market       |
| PG&E | HELMPG_7_UNIT 1          | 34600 | HELMS            | 18   | 407.00 | 1          | Fresno           |                             | Aug NQC                    | Market       |
| PG&E | HELMPG_7_UNIT 2          | 34602 | HELMS            | 18   | 407.00 | 2          | Fresno           |                             | Aug NQC                    | Market       |
| PG&E | HELMPG_7_UNIT 3          | 34604 | HELMS            | 18   | 404.00 | 3          | Fresno           |                             | Aug NQC                    | Market       |
| PG&E | HENRTA_6_HDEBT1          | 34654 | HENRIETT         | 12.5 | 10.00  | 1          | Fresno           |                             |                            | Battery      |
| PG&E | HENRTA_6_SOLAR1          |       |                  |      | 0.19   |            | Fresno           |                             | Not modeled<br>Aug NQC     | Solar        |
| PG&E | HENRTA_6_SOLAR2          |       |                  |      | 0.00   |            | Fresno           |                             | Not modeled<br>Energy Only | Solar        |
| PG&E | HENRTA_6_UNITA1          | 34539 | GWF_GT1          | 13.8 | 49.98  | 1          | Fresno           |                             |                            | Market       |
| PG&E | HENRTA_6_UNITA2          | 34541 | GWF_GT2          | 13.8 | 49.42  | 1          | Fresno           |                             |                            | Market       |
| PG&E | HENRTS_1_SOLAR           | 34617 | HRNTASLR         | 0.38 | 12.40  | 1          | Fresno           | Herndon                     | Aug NQC                    | Solar        |
| PG&E | HURON_6_SOLAR            | 34557 | HURON_DI         | 12.5 | 1.24   | 1          | Fresno           | Coalinga, Panoche<br>115 kV | Aug NQC                    | Solar        |
| PG&E | HURON_6_SOLAR            | 34557 | HURON_DI         | 12.5 | 1.24   | 2          | Fresno           | Coalinga, Panoche<br>115 kV | Aug NQC                    | Solar        |
| PG&E | INTTRB_6_UNIT            | 34342 | INT.TURB         | 9.11 | 3.89   | 1          | Fresno           |                             | Aug NQC                    | Market       |
| PG&E | JAVASR_1_JAVSR1          | 34649 | JAVASLRSPV       | 0.6  | 1.67   | 1          | Fresno           | Herndon, Hanford            | Aug NQC                    | Solar        |
| PG&E | JAYNE_6_WLSLR            | 34639 | WESTLNDs         | 0.48 | 2.23   | 1          | Fresno           | Coalinga                    | Energy Only                | Solar        |
| PG&E | KANSAS_6_SOLAR           | 34666 | KANSASS_S        | 12.5 | 2.48   | F          | Fresno           |                             | Energy Only                | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME             | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|--------|----------|------|-------|------------|------------------|----------------------------------|----------------------------|--------------|
| PG&E | KERKH2_7_UNIT 1          | 34308  | KERCKHOF | 13.8 | 75.00 | 1          | Fresno           | Herndon, Wilson<br>115 kV        | Aug NQC                    | Market       |
| PG&E | KERMAN_6_SOLAR1          |        |          |      | 0.00  |            | Fresno           |                                  | Not modeled<br>Energy Only | Solar        |
| PG&E | KERMAN_6_SOLAR2          |        |          |      | 0.00  |            | Fresno           |                                  | Not modeled<br>Energy Only | Solar        |
| PG&E | KINGCO_1_KINGBR          | 34642  | KINGSBUR | 13.8 | 12.77 | 2          | Fresno           | Herndon, Hanford                 | Aug NQC                    | Net Seller   |
| PG&E | KINGCO_1_KINGBR          | 34642  | KINGSBUR | 13.8 | 21.74 | 1          | Fresno           | Herndon, Hanford                 | Aug NQC                    | Net Seller   |
| PG&E | KINGRV_7_UNIT 1          | 34616  | KINGSRIV | 13.8 | 40.80 | 1          | Fresno           | Herndon, Reedley                 | Aug NQC                    | Market       |
| PG&E | KNGBRG_1_KBSLR1          |        |          |      | 0.00  |            | Fresno           |                                  | Not modeled<br>Energy Only | Solar        |
| PG&E | KNGBRG_1_KBSLR2          |        |          |      | 0.00  |            | Fresno           |                                  | Not modeled<br>Energy Only | Solar        |
| PG&E | KNTSTH_6_SOLAR           | 34694  | KENT_S   | 0.8  | 2.48  | 1          | Fresno           |                                  | Energy Only                | Solar        |
| PG&E | LEPRFD_1_KANSAS          | 34680  | KANSAS   | 12.5 | 2.48  | 1          | Fresno           | Herndon, Hanford                 | Aug NQC                    | Solar        |
| PG&E | LOTUS_6_LSFSR1           | 34335  | LOTUSSFS | 0.32 | 6.20  | 1          | Fresno           | Borden                           | Aug NQC                    | Solar        |
| PG&E | LTBEAR_1_LB3SR3          | 365663 | LILBEAR3 | 0.36 | 2.48  | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | Aug NQC                    | Solar        |
| PG&E | LTBEAR_1_LB4SR4          | 365673 | LILBEAR4 | 0.36 | 6.20  | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | Aug NQC                    | Solar        |
| PG&E | LTBEAR_1_LB4SR5          | 365675 | LILBEAR5 | 0.36 | 6.20  | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | Aug NQC                    | Solar        |
| PG&E | LTBERA_1_LB1SR1          | 365604 | Q1028Q10 | 0.36 | 4.96  | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | Aug NQC                    | Solar        |
| PG&E | MALAGA_1_PL1X2           | 34671  | KRCDPCT1 | 13.8 | 48.31 | 1          | Fresno           | Herndon                          |                            | Market       |
| PG&E | MALAGA_1_PL1X2           | 34672  | KRCDPCT2 | 13.8 | 48.31 | 1          | Fresno           | Herndon                          |                            | Market       |
| PG&E | MCCALL_1_QF              | 34219  | MCCALL 4 | 12.5 | 0.20  | QF         | Fresno           | Herndon                          | Aug NQC                    | QF/Selfgen   |
| PG&E | MCSWAN_6_UNITS           | 34320  | MCSWAIN  | 9.11 | 9.00  | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | Aug NQC                    | MUNI         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                         | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|-------|------------------|------|-------|------------|------------------|--|----------------------------|--------------|
| PG&E | MENBIO_6_RENEW1          | 34339 | CALRENEW         | 12.5 | 0.62  | 1          | Fresno           | Herndon, Panoche<br>115 kV, Wilson<br>115 kV | Aug NQC                    | Net Seller   |
| PG&E | MERCED_1_SOLAR1          |       |                  |      | 0.00  |            | Fresno           |  | Not modeled<br>Energy Only | Solar        |
| PG&E | MERCED_1_SOLAR2          |       |                  |      | 0.00  |            | Fresno           |  | Not modeled<br>Energy Only | Solar        |
| PG&E | MERCFL_6_UNIT            | 34322 | MERCEDFL         | 9.11 | 3.50  | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV             | Aug NQC                    | Market       |
| PG&E | MNDOTA_1_SOLAR1          | 34313 | NORTHSTA         | 0.2  | 7.44  | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV             | Aug NQC                    | Solar        |
| PG&E | MNDOTA_1_SOLAR2          |       |                  |      | 0.00  |            | Fresno           |  | Not modeled<br>Energy Only | Solar        |
| PG&E | MSTANG_2_MTGBT1          | 34685 | MUSTANGBES       | 0.8  | 75.00 | 2          | Fresno           |  |                            | Battery      |
| PG&E | MSTANG_2_SOLAR           | 34683 | REMUSTANGS<br>PV | 0.36 | 0.00  | 1          | Fresno           |  | Aug NQC                    | Solar        |
| PG&E | MSTANG_2_SOLAR3          | 34683 | REMUSTANGS<br>PV | 0.36 | 1.85  | 1          | Fresno           |  | Aug NQC                    | Solar        |
| PG&E | MSTANG_2_SOLAR4          | 34683 | REMUSTANGS<br>PV | 0.36 | 3.72  | 1          | Fresno           |  | Aug NQC                    | Solar        |
| PG&E | ONLLPP_6_UNITS           | 34316 | ONEILPMP         | 9.11 | 0.63  | 1          | Fresno           |  | Aug NQC                    | MUNI         |
| PG&E | OROLOM_1_SOLAR1          | 34689 | OROLOMA_D3       | 12.5 | 0.00  | 1          | Fresno           | Panoche 115 kV                               | Energy Only                | Solar        |
| PG&E | OROLOM_1_SOLAR2          | 34689 | OROLOMA_D3       | 12.5 | 0.00  | 1          | Fresno           | Panoche 115 kV                               | Energy Only                | Solar        |
| PG&E | ORTGA_6_ME1SL1           |       |                  |      | 0.37  |            | Fresno           |  | Not modeled<br>Energy Only | Solar        |
| PG&E | PAIGES_6_SOLAR           | 34653 | PAIGESLR         | 0.55 | 0.00  | 1          | Fresno           | Coalinga, Panoche<br>115 kV                  | Energy Only                | Solar        |
| PG&E | PINFLT_7_UNITS           | 38720 | PINEFLAT         | 13.8 | 40.28 | 1          | Fresno           | Herndon                                      | Aug NQC                    | MUNI         |
| PG&E | PINFLT_7_UNITS           | 38720 | PINEFLAT         | 13.8 | 40.28 | 2          | Fresno           | Herndon                                      | Aug NQC                    | MUNI         |
| PG&E | PINFLT_7_UNITS           | 38720 | PINEFLAT         | 13.8 | 40.28 | 3          | Fresno           | Herndon                                      | Aug NQC                    | MUNI         |
| PG&E | PNCHPP_1_PL1X2           | 34328 | STRWDPNC         | 13.8 | 59.96 | 1          | Fresno           | Panoche 115 kV                               |                            | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME    | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME        | NQC<br>Comments                    | CAISO<br>Tag |
|------|--------------------------|--------|-------------|------|-------|------------|------------------|-----------------------------|------------------------------------|--------------|
| PG&E | PNCHPP_1_PL1X2           | 34329  | STRWDPNC    | 13.8 | 59.96 | 2          | Fresno           | Panoche 115 kV              |                                    | Market       |
| PG&E | PNOCHE_1_PL1X2           | 34142  | WHD_PAN2    | 13.8 | 0.00  | 1          | Fresno           | Herndon, Panoche<br>115 kV  | Potential<br>retirement by<br>2034 | Market       |
| PG&E | PNOCHE_1_UNITA1          | 34186  | CALPEAKP    | 13.8 | 52.01 | 1          | Fresno           | Panoche 115 kV              |                                    | Market       |
| PG&E | REEDLY_6_SOLAR           |        |             |      | 0.00  |            | Fresno           | Herndon, Reedley            | Not modeled<br>Energy Only         | Solar        |
| PG&E | S_RITA_6_SOLAR1          |        |             |      | 0.00  |            | Fresno           |                             | Not modeled<br>Energy Only         | Solar        |
| PG&E | SCHNDR_1_FIVPTS          | 34353  | SCHINDLER_D | 12.5 | 0.62  | 2          | Fresno           | Coalinga, Panoche<br>115 kV | Aug NQC                            | Solar        |
| PG&E | SCHNDR_1_FIVPTS          | 34353  | SCHINDLER_D | 12.5 | 1.24  | 1          | Fresno           | Coalinga, Panoche<br>115 kV | Aug NQC                            | Solar        |
| PG&E | SCHNDR_1_WSTSDE          | 34353  | SCHINDLER_D | 12.5 | 0.62  | 4          | Fresno           | Coalinga, Panoche<br>115 kV | Aug NQC                            | Solar        |
| PG&E | SCHNDR_1_WSTSDE          | 34353  | SCHINDLER_D | 12.5 | 1.24  | 3          | Fresno           | Coalinga, Panoche<br>115 kV | Aug NQC                            | Solar        |
| PG&E | SGREGY_6_SANGER          | 34646  | SANGERC2    | 13.8 | 9.31  | 2          | Fresno           | Herndon                     | Aug NQC                            | Market       |
| PG&E | SGREGY_6_SANGER          | 34646  | SANGERC1    | 13.8 | 38.77 | 1          | Fresno           | Herndon                     | Aug NQC                            | Market       |
| PG&E | SLATE_2_SLASR1           | 365694 | SLATESPV1   | 0.65 | 40.29 | 1          | Fresno           |                             | Aug NQC                            | Hybrid       |
| PG&E | SLATE_2_SLASR2           | 365695 | SLATEBESS1  | 0.66 | 55.39 | 2          | Fresno           |                             | Aug NQC                            | Hybrid       |
| PG&E | SLATE_2_SLASR3           |        |             |      | 40.20 |            | Fresno           |                             | Aug NQC                            | Hybrid       |
| PG&E | SLATE_2_SLASR4           | 365698 | SLATESPV2   | 0.65 | 54.97 | 3          | Fresno           |                             | Aug NQC                            | Hybrid       |
| PG&E | SLATE_2_SLASR5           | 365699 | SLATEBESS2  | 0.66 | 12.66 | 4          | Fresno           |                             | Aug NQC                            | Hybrid       |
| PG&E | STOREY_2_MDRCH2          |        |             |      | 0.04  |            | Fresno           |                             | Not modeled<br>Aug NQC             | Market       |
| PG&E | STOREY_2_MDRCH3          |        |             |      | 0.02  |            | Fresno           |                             | Not modeled<br>Aug NQC             | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME        | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|-----------------------------|----------------------------|--------------|
| PG&E | STOREY_2_MDRCH4          |        |                  |      | 0.01  |            | Fresno           |                             | Not modeled<br>Aug NQC     | Market       |
| PG&E | STOREY_7_MDRCHW          | 34209  | STOREY D         | 12.5 | 0.06  | 1          | Fresno           |                             | Aug NQC                    | Net Seller   |
| PG&E | STROUD_6_SOLAR           | 34563  | STROUD_D         | 12.5 | 1.24  | 1          | Fresno           | Herndon                     | Aug NQC                    | Solar        |
| PG&E | STROUD_6_SOLAR           | 34563  | STROUD_D         | 12.5 | 1.24  | 2          | Fresno           | Herndon                     | Aug NQC                    | Solar        |
| PG&E | STROUD_6_WWHSR1          |        |                  |      | 0.00  |            | Fresno           | Herndon                     | Energy Only                | Solar        |
| PG&E | SUMWHT_6_SWSSR1          |        |                  |      | 2.29  |            | Fresno           |                             | Aug NQC                    | Solar        |
| PG&E | TRNQL8_2_AMASR1          | 365514 | Q1032G1          | 0.55 | 2.48  | 1          | Fresno           |                             | Aug NQC                    | Solar        |
| PG&E | TRNQL8_2_AZUSR1          | 365517 | Q1032G2          | 0.55 | 2.48  | 2          | Fresno           |                             | Aug NQC                    | Solar        |
| PG&E | TRNQL8_2_ROJSR1          | 365520 | Q1032G3          | 0.55 | 12.40 | 3          | Fresno           |                             | Aug NQC                    | Solar        |
| PG&E | TRNQL8_2_VERSR1          | 365520 | Q1032G3          | 0.55 | 7.44  | 3          | Fresno           |                             | Aug NQC                    | Solar        |
| PG&E | TRNQLT_2_RETBT1          | 34343  | Q643XBES         | 0.8  | 72.00 | 2          | Fresno           |                             |                            | Battery      |
| PG&E | TRNQLT_2_SOLAR           | 34340  | Q643X            | 0.8  | 20.42 | 1          | Fresno           |                             | Aug NQC                    | Solar        |
| PG&E | TVYVLY_6_KRSHY1          |        |                  |      | 0.32  |            | Fresno           |                             | Not modeled<br>Aug NQC     | Market       |
| PG&E | ULTPFR_1_UNIT 1          | 34640  | RIOBRVOF         | 12.5 | 16.10 | 1          | Fresno           | Herndon                     | Aug NQC                    | Market       |
| PG&E | VEGA_6_SOLAR1            | 34314  | VEGA             | 34.5 | 0.00  | 1          | Fresno           |                             | Energy Only                | Solar        |
| PG&E | WAUKNA_1_SOLAR           | 34696  | CORCORANP<br>V S | 0.41 | 2.48  | 1          | Fresno           | Herndon, Hanford            | Aug NQC                    | Solar        |
| PG&E | WAUKNA_1_SOLAR2          | 34677  | CORCORAN2S<br>PV | 0.41 | 2.45  | 1          | Fresno           | Herndon, Hanford            | No NQC -<br>Pmax           | Solar        |
| PG&E | WFRESN_1_SOLAR           |        |                  |      | 0.00  |            | Fresno           |                             | Not modeled<br>Energy Only | Solar        |
| PG&E | WHITNY_6_SOLAR           | 34673  | WHTNYPTSPV       | 0.55 | 0.00  | 1          | Fresno           | Coalinga, Panoche<br>115 kV | Energy Only                | Solar        |
| PG&E | WISHON_6_UNITS           | 34658  | WISHON           | 2.3  | 0.00  | 1          | Fresno           | Borden                      | Aug NQC                    | Market       |
| PG&E | WISHON_6_UNITS           | 34658  | WISHON           | 2.3  | 0.00  | 2          | Fresno           | Borden                      | Aug NQC                    | Market       |
| PG&E | WISHON_6_UNITS           | 34658  | WISHON           | 2.3  | 0.00  | 3          | Fresno           | Borden                      | Aug NQC                    | Market       |
| PG&E | WISHON_6_UNITS           | 34658  | WISHON           | 2.3  | 0.00  | 4          | Fresno           | Borden                      | Aug NQC                    | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC  | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                         | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|------|------------|------------------|--|----------------------------|--------------|
| PG&E | WISHON_6_UNITS           | 34658  | WISHON           | 2.3  | 0.00 | SJ         | Fresno           | Borden                                       | Aug NQC                    | Market       |
| PG&E | WOODWR_1_HYDRO           |        |                  |      | 0.00 |            | Fresno           | Herndon                                      | Not modeled<br>Energy Only | Market       |
| PG&E | ZZ_BORDEN_2_QF           | 34253  | BORDEN D         | 12.5 | 0.00 | QF         | Fresno           |  | No NQC -<br>hist. data     | Net Seller   |
| PG&E | ZZ_BULLRD_7_SAGNES       | 34213  | BULLD 12         | 12.5 | 0.00 | 1          | Fresno           | Herndon                                      | Aug NQC                    | QF/Selfgen   |
| PG&E | ZZ_CHWCHL_1_BIOMAS       | 34305  | CHWCHLA2         | 13.8 | 0.00 | 1          | Fresno           | Herndon, Panoche<br>115 kV, Wilson<br>115 kV | Aug NQC                    | Market       |
| PG&E | ZZ_DINUBA_6_UNIT         | 34648  | DINUBA E         | 13.8 | 0.00 | MB         | Fresno           | Herndon, Reedley                             | Mothballed                 | Market       |
| PG&E | ZZ_ELNIDP_6_BIOMAS       | 34330  | ELNIDOBM         | 13.8 | 0.00 | 1          | Fresno           | Panoche 115 kV,<br>Wilson 115 kV             | Aug NQC                    | Market       |
| PG&E | ZZ_KERKH1_7_UNIT 2       | 34343  | KERCK1-2         | 6.6  | 0.00 | 2          | Fresno           | Herndon, Wilson<br>115 kV                    | No NQC -<br>hist. data     | Market       |
| PG&E | ZZ_NA                    | 34485  | FRESNOWW         | 12.5 | 0.00 | RE         | Fresno           |  | No NQC -<br>hist. data     | QF/Selfgen   |
| PG&E | ZZ_NA                    | 34651  | JACALITO         | 0.55 | 0.00 | RN         | Fresno           | Coalinga                                     | No NQC -<br>hist. data     | Market       |
| PG&E | ZZ_SCHNDR_1_OS2BM2       |        |                  |      | 0.00 |            | Fresno           | Coalinga                                     | Energy Only                | Market       |
| PG&E | ZZ_WRGHTP_7_AMENGY       | 34207  | WRIGHT D         | 12.5 | 0.00 | QF         | Fresno           |  |                            | QF/Selfgen   |
| PG&E | ZZZ_New Unit             | 92799  | 2799-WD          | 115  | 0.00 | EW         | Fresno           | Panoche 115 kV                               | Energy Only                | Solar        |
| PG&E | ZZZ_New Unit             | 92007  | 2007-RD          | 70   | 0.00 | RN         | Fresno           | Borden                                       | Energy Only                | Market       |
| PG&E | ZZZ_New Unit             | 365340 | LEPRINOFDL<br>MR | 21   | 0.00 | RN         | Fresno           | Herndon, Hanford                             | Energy Only                | Market       |
| PG&E | ZZZ_New Unit             | 34603  | JGBSWLT          | 12.5 | 0.00 | ST         | Fresno           | Herndon                                      | Energy Only                | Market       |
| PG&E | ZZZ_New Unit             | 92142  | 2142-WD          | 70   | 0.08 | FW         | Fresno           |  | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZ_New Unit             | 34668  | KEARNEY_D1       | 12.5 | 0.90 | 1          | Fresno           |  | No NQC -<br>hist. data     | Solar        |
| PG&E | ZZZ_New Unit             | 365679 | WSTALMOND<br>SPV | 0.63 | 2.28 | 1          | Fresno           |  | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZ_New Unit             | 365504 | SCULINS          | 0.55 | 2.34 | 1          | Fresno           |  | No NQC -<br>est. data      | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments       | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|----------------------|-----------------------|--------------|
| PG&E | ZZZ_New Unit             | 365325 | MUSTANGSPV<br>3  | 0.36 | 3.70  | 3          | Fresno           |                      | No NQC -<br>est. data | Solar        |
| PG&E | ZZZ_New Unit             | 365327 | MUSTANGSPV<br>4  | 0.36 | 4.10  | 4          | Fresno           |                      | No NQC -<br>est. data | Solar        |
| PG&E | ZZZ_New Unit             | 92484  | 2484-WD          | 21   | 9.90  | FW         | Fresno           | Coalinga             | No NQC -<br>est. data | Battery      |
| PG&E | ZZZ_New Unit             | 365706 | FSNOCGNBES<br>S2 | 6.9  | 16.40 | 5          | Fresno           | Herndon              | No NQC -<br>est. data | Battery      |
| PG&E | ZZZ_New Unit             | 366340 | Q1378WIND        | 0.75 | 16.93 | 1          | Fresno           |                      | No NQC -<br>est. data | Wind         |
| PG&E | ZZZ_New Unit             | 365341 | MERCED_D1        | 21   | 20.00 | 1          | Fresno           |                      | No NQC -<br>est. data | Battery      |
| PG&E | ZZZ_New Unit             | 397125 | MUSTANGS2-<br>25 | 25   | 50.00 | E8         | Fresno           |                      | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZ_New Unit            | 34500  | DINUBA           | 70   | 0.00  | TA         | Fresno           | Reedley              | Transmission<br>Asset | Battery      |
| PG&E | ZZZZA_New Unit           | 346912 | AVENAPSPV1       | 0.39 | 0.00  | 1          | Fresno           | Coalinga             | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 365226 | Q1135SPV1        | 34.5 | 0.00  | 1          | Fresno           |                      | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 366004 | Q1391SPV         | 0.6  | 0.00  | 2          | Fresno           |                      | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 346914 | AVENAPSPV2       | 0.39 | 0.00  | 2          | Fresno           | Coalinga             | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 365228 | Q1135SPV2        | 34.5 | 0.00  | 2          | Fresno           |                      | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 92080  | 2080-WD          | 115  | 0.00  | EW         | Fresno           | Herndon, Reedley     | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 92649  | 2649-WD          | 70   | 0.00  | EW         | Fresno           |                      | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 92796  | 2796-WD          | 230  | 0.00  | EW         | Fresno           |                      | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 92226  | 2226-WD          | 115  | 0.00  | EW         | Fresno           | Panoche 115 kV       | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 93057  | 3057-WD          | 115  | 0.00  | EW         | Fresno           | Panoche 115 kV       | Energy Only           | Solar        |
| PG&E | ZZZZA_New Unit           | 397084 | SANGER 1-25      | 25   | 0.25  | VS         | Fresno           | Herndon              | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397085 | SCHINDLR1-<br>25 | 25   | 0.25  | VS         | Fresno           | Panoche 115 kV       | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397059 | CORCORAN1-<br>25 | 25   | 0.50  | VS         | Fresno           | Herndon, Hanford     | No NQC -<br>est. data | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME          | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME             | NQC<br>Comments       | CAISO<br>Tag |
|------|--------------------------|--------|-------------------|------|-------|------------|------------------|----------------------------------|-----------------------|--------------|
| PG&E | ZZZZA_New Unit           | 397074 | MERCED 1-25       | 25   | 0.50  | VS         | Fresno           |                                  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397056 | BORDEN 1-25       | 25   | 0.56  | VS         | Fresno           |                                  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397060 | DAIRYLND1-25      | 25   | 0.62  | VS         | Fresno           | Panoche 115 kV                   | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397073 | MC CALL 1-25      | 25   | 0.72  | VS         | Fresno           | Herndon                          | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397075 | PANOCH1-25        | 25   | 0.74  | VS         | Fresno           | Panoche 115 kV                   | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397058 | CHWCHLLA1-<br>25  | 25   | 0.87  | VS         | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397035 | WILSON A1-25      | 25   | 0.91  | VB         | Fresno           |                                  | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397003 | BLCH 2-21-25      | 25   | 2.73  | VB         | Fresno           | Herndon                          | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397016 | EXCHEQUR1-<br>25  | 25   | 4.73  | VB         | Fresno           | Panoche 115 kV,<br>Wilson 115 kV | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397030 | PINEFLAT1-25      | 25   | 7.28  | VB         | Fresno           | Herndon                          | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397098 | HELM 1-25         | 25   | 7.44  | VS         | Fresno           |                                  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397116 | HELM 1-25         | 25   | 20.00 | E8         | Fresno           |                                  | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit           | 397106 | TRANQLTY 1-<br>25 | 25   | 22.94 | VS         | Fresno           |                                  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397103 | MUSTANG 1-<br>25  | 25   | 24.80 | VS         | Fresno           |                                  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397127 | TRANQLTY 1-<br>25 | 25   | 29.00 | E8         | Fresno           |                                  | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit           | 397042 | GREGG 1-25        | 25   | 29.62 | VW         | Fresno           |                                  | No NQC -<br>est. data | Wind         |
| PG&E | ZZZZA_New Unit           | 365767 | Q1713BESS         | 0.69 | 32.00 | 1          | Fresno           | Herndon, Hanford                 | No NQC -<br>est. data | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME      | NQC<br>Comments        | CAISO<br>Tag |
|------|--------------------------|--------|-----------------|------|--------|------------|------------------|---------------------------|------------------------|--------------|
| PG&E | ZZZZA_New Unit           | 365225 | Q1135BESS1      | 34.5 | 40.00  | 1          | Fresno           |                           | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZZA_New Unit           | 397051 | WILSON 1-25     | 25   | 42.32  | VW         | Fresno           |                           | No NQC -<br>est. data  | Wind         |
| PG&E | ZZZZA_New Unit           | 397102 | HELM X1-25      | 25   | 43.15  | VS         | Fresno           |                           | No NQC -<br>est. data  | Solar        |
| PG&E | ZZZZA_New Unit           | 397124 | HELM X1-15      | 25   | 81.00  | En         | Fresno           |                           | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZZA_New Unit           | 365227 | Q1135BESS2      | 34.5 | 100.00 | 2          | Fresno           |                           | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZZA_New Unit           | 397129 | GREGG 1-25      | 25   | 130.00 | VE         | Fresno           |                           | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZZA_New Unit           | 365740 | Q1129SBDC       | 34.5 | 168.50 | 1          | Fresno           |                           | No NQC -<br>est. data  | Hybrid       |
| PG&E | ZZZZA_New Unit           | 366003 | Q1391SPVBD<br>C | 0.6  | 184.00 | 1          | Fresno           |                           | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZZA_New Unit           | 365229 | Q1135BESS3      | 34.5 | 260.00 | 3          | Fresno           |                           | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZZZ_CRNEVL_6_SJQN<br>3 | 34633  | SJ3GEN          | 9.11 | 0.00   | 1          | Fresno           | Borden                    | Retired                | Market       |
| PG&E | ZZZZZ_GATES_6_PL1X2      | 34553  | WHD_GAT2        | 13.8 | 0.00   | RT         | Fresno           | Coalinga                  | Retired                | Market       |
| PG&E | ZZZZZ_KERKH1_7_UNIT 3    | 34345  | KERCK1-3        | 6.6  | 0.00   | 3          | Fresno           | Herndon, Wilson<br>115 kV | Retired                | Market       |
| PG&E | BRDGLV_7_BAKER           |        |                 |      | 0.00   |            | Humboldt         |                           | Not modeled<br>Aug NQC | Net Seller   |
| PG&E | FTSWRD_6_TRFORK          |        |                 |      | 0.11   |            | Humboldt         |                           | Not modeled<br>Aug NQC | Market       |
| PG&E | FTSWRD_7_QFUNTS          |        |                 |      | 0.00   |            | Humboldt         |                           | Not modeled<br>Aug NQC | QF/Selfgen   |
| PG&E | HUMBPP_1_UNITS3          | 31180  | HMBOBAYPPB      | 13.8 | 15.85  | 4          | Humboldt         |                           |                        | Market       |
| PG&E | HUMBPP_1_UNITS3          | 31180  | HMBOBAYPPB      | 13.8 | 16.22  | 5          | Humboldt         |                           |                        | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments                     | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|----------------------------|-------------------------------------|--------------|
| PG&E | HUMBPP_1_UNITS3          | 31180  | HMBOBAYPPB       | 13.8 | 16.32 | 6          | Humboldt         |                            |                                     | Market       |
| PG&E | HUMBPP_1_UNITS3          | 31180  | HMBOBAYPPB       | 13.8 | 16.69 | 7          | Humboldt         |                            |                                     | Market       |
| PG&E | HUMBPP_6_UNITS           | 31182  | HMBOBAYPPC       | 13.8 | 15.95 | 10         | Humboldt         |                            |                                     | Market       |
| PG&E | HUMBPP_6_UNITS           | 31181  | HMBOBAYPPA       | 13.8 | 16.14 | 1          | Humboldt         |                            |                                     | Market       |
| PG&E | HUMBPP_6_UNITS           | 31181  | HMBOBAYPPA       | 13.8 | 16.24 | 2          | Humboldt         |                            |                                     | Market       |
| PG&E | HUMBPP_6_UNITS           | 31181  | HMBOBAYPPA       | 13.8 | 16.33 | 3          | Humboldt         |                            |                                     | Market       |
| PG&E | HUMBPP_6_UNITS           | 31182  | HMBOBAYPPC       | 13.8 | 16.33 | 9          | Humboldt         |                            |                                     | Market       |
| PG&E | HUMBPP_6_UNITS           | 31182  | HMBOBAYPPC       | 13.8 | 16.62 | 8          | Humboldt         |                            |                                     | Market       |
| PG&E | KEKAWK_6_UNIT            | 31166  | KEKAWAK          | 9.1  | 0.00  | 1          | Humboldt         |                            | Aug NQC                             | Net Seller   |
| PG&E | PACLUM_6_UNIT            | 31153  | HRCGENC          | 2.4  | 2.92  | 3          | Humboldt         |                            | Aug NQC                             | Net Seller   |
| PG&E | PACLUM_6_UNIT            | 31152  | HRCGENSAB        | 13.8 | 4.87  | 1          | Humboldt         |                            | Aug NQC                             | Net Seller   |
| PG&E | PACLUM_6_UNIT            | 31152  | HRCGENSAB        | 13.8 | 4.87  | 2          | Humboldt         |                            | Aug NQC                             | Net Seller   |
| PG&E | ZZ_BLULKE_6_BLUELK       | 31156  | BLUELKPP         | 12.5 | 0.00  | MB         | Humboldt         |                            | Mothballed                          | Market       |
| PG&E | ZZ_FAIRHV_6_UNIT         | 31150  | FAIRHAVN         | 13.8 | 0.00  | 1          | Humboldt         |                            | No NQC -<br>hist. data              | Net Seller   |
| PG&E | ZZ_LAPAC_6_UNIT          | 31158  | LP SAMOA         | 12.5 | 0.00  | 1          | Humboldt         |                            |                                     | Market       |
| PG&E | ZZZZA_New Unit           | 92400  | 2400-WD          | 60   | 0.00  | EW         | Humboldt         |                            | Energy Only                         | Solar        |
| PG&E | ZZZZA_New Unit           | 92399  | 2399-WD          | 60   | 0.00  | EW         | Humboldt         |                            | Energy Only                         | Solar        |
| PG&E | ZZZZA_New Unit           | 92622  | 2622-WD          | 60   | 0.00  | EW         | Humboldt         |                            | Energy Only                         | Solar        |
| PG&E | ZZZZA_New Unit           | 399997 | FAIRHAVEN<br>ES  | 60   | 0.00  | EW         | Humboldt         |                            | Energy Only                         | Solar        |
| PG&E | ZZZZA_New Unit           | 397022 | HUMBOLDT1-<br>25 | 25   | 2.28  | VB         | Humboldt         |                            | No NQC -<br>est. data               | Market       |
| PG&E | 7STDRD_1_SOLAR1          | 35065  | 7STNDRD_D1       | 21.6 | 2.48  | 1          | Kern             | South Kern PP,<br>Kern Oil | Aug NQC                             | Solar        |
| PG&E | BDGRCK_1_UNITS           | 35029  | BADGERCK         | 13.8 | 0.00  | 1          | Kern             | South Kern PP              | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| PG&E | BEARMT_1_UNIT            | 35066  | PSE-BEAR         | 13.8 | 0.00  | 1          | Kern             | South Kern PP,<br>Westpark | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME             | NQC<br>Comments                     | CAISO<br>Tag |
|------|--------------------------|-------|-----------------|------|-------|------------|------------------|----------------------------------|-------------------------------------|--------------|
| PG&E | BKRFLD_2_SOLAR1          |       |                 |      | 0.17  |            | Kern             | South Kern PP                    | Not modeled<br>Aug NQC              | Solar        |
| PG&E | DEXZEL_1_UNIT            | 35024 | DEXZEL          | 13.8 | 0.00  | 1          | Kern             | South Kern PP,<br>Kern Oil       | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| PG&E | DISCOV_1_CHEVRN          | 35062 | DISCOVERY       | 13.8 | 0.00  | 1          | Kern             | South Kern PP,<br>Kern Oil       | Could retire<br>by 2034. Aug<br>NQC | QF/Selfgen   |
| PG&E | DOUBLC_1_UNITS           | 35023 | DOUBLE C        | 13.8 | 0.00  | 1          | Kern             | South Kern PP                    | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| PG&E | DOUBLC_1_UNITS           | 35023 | DOUBLE C        | 13.8 | 0.00  | 2          | Kern             | South Kern PP                    | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| PG&E | KERNFT_1_UNITS           | 35026 | KERNFRNT        | 13.8 | 0.00  | 1          | Kern             | South Kern PP                    | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| PG&E | KERNFT_1_UNITS           | 35026 | KERNFRNT        | 13.8 | 0.00  | 2          | Kern             | South Kern PP                    | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| PG&E | LAMONT_1_SOLAR1          | 35019 | REGULUS         | 0.4  | 7.44  | 1          | Kern             | South Kern PP,<br>Kern PWR-Tevis | Aug NQC                             | Solar        |
| PG&E | LAMONT_1_SOLAR2          | 35092 | REDWOODSP<br>V  | 0.6  | 2.48  | 4          | Kern             | South Kern PP,<br>Kern PWR-Tevis | Aug NQC                             | Solar        |
| PG&E | LAMONT_1_SOLAR3          | 35087 | WOODMERES<br>PV | 0.4  | 1.86  | 3          | Kern             | South Kern PP,<br>Kern PWR-Tevis | Aug NQC                             | Solar        |
| PG&E | LAMONT_1_SOLAR4          | 35059 | HAYWORTH<br>PV  | 0.4  | 17.37 | 2          | Kern             | South Kern PP,<br>Kern PWR-Tevis | Aug NQC                             | Solar        |
| PG&E | LAMONT_1_SOLAR5          | 35054 | REDCRESTSP<br>V | 0.4  | 2.07  | 1          | Kern             | South Kern PP,<br>Kern PWR-Tevis | Aug NQC                             | Solar        |
| PG&E | LIVOAK_1_UNIT 1          | 35058 | PSE-LVOK        | 9.1  | 0.00  | 1          | Kern             | South Kern PP,<br>Kern Oil       | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments                     | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|------------------------------|-------------------------------------|--------------|
| PG&E | MAGUND_1_BKISR1          |        |                  |      | 0.12  |            | Kern             | South Kern PP,<br>Kern Oil   | Not modeled<br>Aug NQC              | Solar        |
| PG&E | MAGUND_1_BKSSR2          |        |                  |      | 0.65  |            | Kern             | South Kern PP,<br>Kern Oil   | Not modeled<br>Aug NQC              | Solar        |
| PG&E | MTNPOS_1_UNIT            | 35036  | MT POSO          | 13.8 | 40.55 | 1          | Kern             | South Kern PP,<br>Kern Oil   | Aug NQC                             | Net Seller   |
| PG&E | OLDRIV_6_BIOGAS          |        |                  |      | 1.75  |            | Kern             | South Kern PP,<br>Kern 70 kV | Not modeled<br>Aug NQC              | Market       |
| PG&E | OLDRIV_6_CESDBM          |        |                  |      | 0.93  |            | Kern             | South Kern PP,<br>Kern 70 kV | Not modeled<br>Aug NQC              | Market       |
| PG&E | OLDRIV_6_LKVBM1          |        |                  |      | 0.93  |            | Kern             | South Kern PP,<br>Kern 70 kV | Not modeled<br>Aug NQC              | Market       |
| PG&E | OLDRV1_6_SOLAR           | 35091  | OLDRIVER1SP<br>V | 0.69 | 2.48  | 1          | Kern             | South Kern PP,<br>Kern 70 kV | Aug NQC                             | Solar        |
| PG&E | SIERRA_1_UNITS           | 35027  | HISIERRA         | 13.8 | 0.00  | 1          | Kern             | South Kern PP                | Could retire<br>by 2034. Aug<br>NQC | Market       |
| PG&E | SIERRA_1_UNITS           | 35027  | HISIERRA         | 13.8 | 0.00  | 2          | Kern             | South Kern PP                | Could retire<br>by 2034. Aug<br>NQC | Market       |
| PG&E | SKERN_6_SOLAR1           | 35089  | S_KERN           | 0.48 | 2.48  | 1          | Kern             | South Kern PP,<br>Kern 70 kV | Aug NQC                             | Solar        |
| PG&E | SKERN_6_SOLAR2           | 365563 | SKICSPV          | 0.4  | 1.24  | 1          | Kern             | South Kern PP,<br>Kern 70 kV | Aug NQC                             | Solar        |
| PG&E | VEDDER_1_SEKERN          | 35046  | SEKR             | 9.11 | 0.00  | 1          | Kern             | South Kern PP,<br>Kern Oil   | Could retire<br>by 2034. Aug<br>NQC | QF/Selfgen   |
| PG&E | ZZZ_New Unit             | 366955 | 2446-RD-SPV      | 0.65 | 0.00  | RE         | Kern             | South Kern PP,<br>Kern Oil   | Energy Only                         | Solar        |
| PG&E | ZZZ_New Unit             | 35068  | EANDB_D1         | 12.5 | 0.00  | RE         | Kern             | South Kern PP                | Energy Only                         | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME             | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|----------------------------------|----------------------------|--------------|
| PG&E | ZZZ_New Unit             | 365597 | Q744P5G5         | 0.6  | 1.48  | 5          | Kern             | South Kern PP,<br>Kern PWR-Tevis | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZ_New Unit             | 365347 | TEVIS_D1         | 21   | 20.00 | 1          | Kern             | South Kern PP,<br>Kern PWR-Tevis | No NQC -<br>est. data      | Battery      |
| PG&E | ZZZZA_New Unit           | 91783  | 1783-WD          | 0.65 | 0.00  | EW         | Kern             | South Kern PP                    | Energy Only                | Solar        |
| PG&E | ZZZZA_New Unit           | 397066 | KERN OIL1-25     | 25   | 0.12  | VS         | Kern             | South Kern PP,<br>Kern Oil       | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZZA_New Unit           | 397024 | LAMONT 1-25      | 25   | 0.15  | VS         | Kern             | South Kern PP,<br>Kern PWR-Tevis | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZZA_New Unit           | 397088 | Stockdale 1-25   | 25   | 0.25  | VS         | Kern             | South Kern PP                    | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZZA_New Unit           | 397054 | 7STNDRD 1-25     | 25   | 0.31  | VS         | Kern             | South Kern PP,<br>Kern Oil       | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZZA_New Unit           | 397079 | POSOMTJT1-<br>25 | 25   | 0.47  | VS         | Kern             | South Kern PP,<br>Kern Oil       | No NQC -<br>est. data      | Solar        |
| PG&E | ZZZZA_New Unit           | 397024 | LAMONT 1-25      | 25   | 4.60  | VB         | Kern             | South Kern PP,<br>Kern PWR-Tevis | No NQC -<br>Pmax           | Market       |
| PG&E | ADLIN_1_UNITS            | 31435  | AIDLINGYSR1      | 13.8 | 11.00 | 1          | NCNB             | Eagle Rock, Fulton               |                            | Market       |
| PG&E | ADLIN_1_UNITS            | 31437  | AIDLINGYSR2      | 13.8 | 11.00 | 2          | NCNB             | Eagle Rock, Fulton               |                            | Market       |
| PG&E | CLOVDL_1_SOLAR           |        |                  |      | 0.19  |            | NCNB             | Eagle Rock, Fulton               | Not modeled<br>Aug NQC     | Solar        |
| PG&E | CSTOGA_6_LNDFIL          |        |                  |      | 0.00  |            | NCNB             | Fulton                           | Not modeled<br>Energy Only | Market       |
| PG&E | FULTON_1_QF              |        |                  |      | 0.02  |            | NCNB             | Fulton                           | Not modeled<br>Aug NQC     | QF/Selfgen   |
| PG&E | GEYS11_7_UNIT11          | 31412  | GEYSER11         | 13.8 | 68.00 | 1          | NCNB             | Eagle Rock, Fulton               |                            | Market       |
| PG&E | GEYS12_7_UNIT12          | 31414  | GEYSER12         | 13.8 | 50.00 | 1          | NCNB             | Fulton                           |                            | Market       |
| PG&E | GEYS13_7_UNIT13          | 31416  | GEYSER13         | 13.8 | 56.00 | 1          | NCNB             |                                  |                            | Market       |
| PG&E | GEYS14_7_UNIT14          | 31418  | GEYSER14         | 13.8 | 70.00 | 1          | NCNB             | Fulton                           |                            | Market       |
| PG&E | GEYS16_7_UNIT16          | 31420  | GEYSER16         | 13.8 | 63.00 | 1          | NCNB             | Fulton                           |                            | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments             | CAISO<br>Tag |
|------|--------------------------|-------|----------|------|-------|------------|------------------|----------------------|-----------------------------|--------------|
| PG&E | GEYS17_7_UNIT17          | 31422 | GEYSER17 | 13.8 | 75.50 | 1          | NCNB             | Fulton               |                             | Market       |
| PG&E | GEYS18_7_UNIT18          | 31424 | GEYSER18 | 13.8 | 72.00 | 1          | NCNB             |                      |                             | Market       |
| PG&E | GEYS20_7_UNIT20          | 31426 | GEYSER20 | 13.8 | 50.00 | 1          | NCNB             |                      |                             | Market       |
| PG&E | GYS5X6_7_UNITS           | 31406 | GEYSR5-6 | 13.8 | 42.50 | 1          | NCNB             | Eagle Rock, Fulton   |                             | Market       |
| PG&E | GYS5X6_7_UNITS           | 31406 | GEYSR5-6 | 13.8 | 42.50 | 2          | NCNB             | Eagle Rock, Fulton   |                             | Market       |
| PG&E | GYS7X8_7_UNITS           | 31408 | GEYSER78 | 13.8 | 47.90 | 1          | NCNB             | Eagle Rock, Fulton   |                             | Market       |
| PG&E | GYS7X8_7_UNITS           | 31408 | GEYSER78 | 13.8 | 47.90 | 2          | NCNB             | Eagle Rock, Fulton   |                             | Market       |
| PG&E | GYSRVL_7_WSPRNG          |       |          |      | 0.00  |            | NCNB             | Fulton               | Not modeled<br>Aug NQC      | QF/Selfgen   |
| PG&E | HILAND_7_YOLOWD          |       |          |      | 0.00  |            | NCNB             | Eagle Rock, Fulton   | Not Modeled.<br>Energy Only | Market       |
| PG&E | IGNACO_1_QF              |       |          |      | 0.01  |            | NCNB             |                      | Not modeled<br>Aug NQC      | QF/Selfgen   |
| PG&E | INDVLY_1_UNITS           | 31436 | INDIAN V | 9.1  | 0.61  | 1          | NCNB             | Eagle Rock, Fulton   | Aug NQC                     | Net Seller   |
| PG&E | MONTPH_7_UNITS           | 32700 | MONTICLO | 9.1  | 0.89  | 3          | NCNB             | Fulton               | Aug NQC                     | Market       |
| PG&E | MONTPH_7_UNITS           | 32700 | MONTICLO | 9.1  | 2.96  | 1          | NCNB             | Fulton               | Aug NQC                     | Market       |
| PG&E | MONTPH_7_UNITS           | 32700 | MONTICLO | 9.1  | 2.96  | 2          | NCNB             | Fulton               | Aug NQC                     | Market       |
| PG&E | NCPA_7_GP1UN1            | 38106 | NCPA1GY1 | 13.8 | 38.85 | 1          | NCNB             |                      | Aug NQC                     | MUNI         |
| PG&E | NCPA_7_GP1UN2            | 38108 | NCPA1GY2 | 13.8 | 39.94 | 1          | NCNB             |                      | Aug NQC                     | MUNI         |
| PG&E | NCPA_7_GP2UN3            | 38110 | NCPA2GY1 | 13.8 | 0.00  | 1          | NCNB             | Fulton               | Aug NQC                     | MUNI         |
| PG&E | NCPA_7_GP2UN4            | 38112 | NCPA2GY2 | 13.8 | 52.73 | 1          | NCNB             | Fulton               | Aug NQC                     | MUNI         |
| PG&E | NOVATO_6_LNDFL           |       |          |      | 2.87  |            | NCNB             |                      | Not modeled<br>Aug NQC      | Market       |
| PG&E | POTTER_7_VECINO          |       |          |      | 0.00  |            | NCNB             | Eagle Rock, Fulton   | Not modeled<br>Aug NQC      | QF/Selfgen   |
| PG&E | SANTFG_7_UNITS           | 31400 | SANTA FE | 13.8 | 36.00 | 1          | NCNB             |                      |                             | Market       |
| PG&E | SANTFG_7_UNITS           | 31401 | SANTA FE | 13.8 | 36.00 | 2          | NCNB             |                      |                             | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments                  | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|----------------------|----------------------------------|--------------|
| PG&E | SMUDGO_7_UNIT 1          | 31430  | SONOMAPPG<br>EO  | 13.8 | 47.00 | 1          | NCNB             |                      |                                  | Market       |
| PG&E | SNMALF_6_UNITS           | 31446  | SONMA LF         | 9.1  | 3.05  | 1          | NCNB             | Fulton               | Aug NQC                          | QF/Selfgen   |
| PG&E | UKIAH_7_LAKEMN           | 38020  | CITY UKH         | 115  | 0.49  | 1          | NCNB             | Eagle Rock, Fulton   | Aug NQC                          | MUNI         |
| PG&E | UKIAH_7_LAKEMN           | 38020  | CITY UKH         | 115  | 1.21  | 2          | NCNB             | Eagle Rock, Fulton   | Aug NQC                          | MUNI         |
| PG&E | ZZ_GEYS17_2_BOTRCK       | 31421  | BOTTLERK         | 13.8 | 0.00  | 1          | NCNB             | Fulton               | Energy Only<br>and<br>Mothballed | Market       |
| PG&E | ZZZ_New Unit             | 366061 | Q1700BESS        | 0.39 | 0.00  | 1          | NCNB             |                      | Energy Only                      | Battery      |
| PG&E | ZZZ_New Unit             | 92287  | 2287-WD          | 60   | 0.00  | EW         | NCNB             |                      | Energy Only                      | Solar        |
| PG&E | ZZZ_New Unit             | 92606  | 2606-WD          | 115  | 0.00  | EW         | NCNB             |                      | Energy Only                      | Battery      |
| PG&E | ZZZ_New Unit             | 93077  | 3077-WD          | 115  | 0.00  | EW         | NCNB             |                      | Energy Only                      | Solar        |
| PG&E | ZZZ_New Unit             | 92365  | 2365-WD          | 60   | 0.00  | EW         | NCNB             | Fulton               | Energy Only                      | Solar        |
| PG&E | ZZZZA_New Unit           | 397057 | CALPELLA1-25     | 25   | 0.50  | VS         | NCNB             | Eagle Rock, Fulton   | No NQC -<br>est. data            | Solar        |
| PG&E | ZZZZA_New Unit           | 397025 | MENDOCNO1-<br>25 | 25   | 0.92  | VB         | NCNB             | Eagle Rock, Fulton   | No NQC -<br>est. data            | Market       |
| PG&E | ZZZZA_New Unit           | 397034 | UKIAH 1-25       | 25   | 0.92  | VB         | NCNB             | Eagle Rock, Fulton   | No NQC -<br>est. data            | Market       |
| PG&E | ZZZZA_New Unit           | 397015 | EGLE RCK1-25     | 25   | 1.84  | VB         | NCNB             | Eagle Rock, Fulton   | No NQC -<br>est. data            | Market       |
| PG&E | ZZZZA_New Unit           | 397017 | FULTON x1-25     | 25   | 1.84  | VB         | NCNB             | Fulton               | No NQC -<br>est. data            | Market       |
| PG&E | ZZZZA_New Unit           | 397107 | TULUCAY 1-25     | 25   | 3.10  | VS         | NCNB             |                      | No NQC -<br>est. data            | Solar        |
| PG&E | ZZZZA_New Unit           | 397128 | MENDOCNO1-<br>25 | 25   | 5.00  | VE         | NCNB             | Eagle Rock, Fulton   | No NQC -<br>est. data            | Battery      |
| PG&E | ZZZZA_New Unit           | 39185  | Q1097            | 0.4  | 13.00 | 1          | NCNB             | Fulton               | No NQC -<br>est. data            | Battery      |
| PG&E | ZZZZA_New Unit           | 397001 | FULTON 1-25      | 25   | 15.98 | VG         | NCNB             | Fulton               | No NQC -<br>est. data            | Market       |
| PG&E | ZZZZA_New Unit           | 366344 | WSTFRDFLTR<br>ES | 0.4  | 25.00 | 1          | NCNB             | Fulton               | No NQC -<br>est. data            | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME  | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|---|----------------------------|--------------|
| PG&E | ZZZZA_New Unit           | 397040 | EGLE RCK1-25     | 25   | 27.72 | VW         | NCNB             | Eagle Rock, Fulton  | No NQC -<br>est. data      | Wind         |
| PG&E | ZZZZA_New Unit           | 397000 | CLOVRDLE1-<br>25 | 25   | 30.08 | VG         | NCNB             | Eagle Rock, Fulton  | No NQC -<br>est. data      | Market       |
| PG&E | ZZZZA_New Unit           | 397002 | GEYSER121-<br>25 | 25   | 59.22 | VG         | NCNB             | Fulton  | No NQC -<br>est. data      | Market       |
| PG&E | ZZZZZ_BEARN_C2_UNITS     | 31402  | BEAR CAN         | 13.8 | 0.00  | 1          | NCNB             | Fulton  | Retired                    | Market       |
| PG&E | ZZZZZ_BEARN_C2_UNITS     | 31402  | BEAR CAN         | 13.8 | 0.00  | 2          | NCNB             | Fulton  | Retired                    | Market       |
| PG&E | ZZZZZ_POTTER_6_UNITS     | 31433  | POTTRVLY         | 2.4  | 0.00  | 1          | NCNB             | Eagle Rock, Fulton  | Retired                    | Market       |
| PG&E | ZZZZZ_POTTER_6_UNITS     | 31433  | POTTRVLY         | 2.4  | 0.00  | 3          | NCNB             | Eagle Rock, Fulton  | Retired                    | Market       |
| PG&E | ZZZZZ_POTTER_6_UNITS     | 31433  | POTTRVLY         | 2.4  | 0.00  | 4          | NCNB             | Eagle Rock, Fulton  | Retired                    | Market       |
| PG&E | ZZZZZ_WDFRDF_2_UNITS     | 31404  | WEST FOR         | 13.8 | 0.00  | 1          | NCNB             | Fulton  | Retired                    | Market       |
| PG&E | ZZZZZ_WDFRDF_2_UNITS     | 31404  | WEST FOR         | 13.8 | 0.00  | 2          | NCNB             | Fulton  | Retired                    | Market       |
| PG&E | ALLGNY_6_HYDRO1          |        |                  |      | 0.00  |            | Sierra           |   | Not modeled<br>Aug NQC     | Market       |
| PG&E | APLHIL_1_SFKHY1          |        |                  |      | 0.00  |            | Sierra           | South of Rio Oso,<br>South of Palermo   | Not modeled<br>Energy Only | Market       |
| PG&E | BELDEN_7_UNIT 1          | 31784  | BELDEN           | 13.8 | 93.95 | 1          | Sierra           | South of Palermo  | Aug NQC                    | Market       |
| PG&E | BIOMAS_1_UNIT 1          | 32156  | WOODLAND         | 13.8 | 8.07  | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC                    | Net Seller   |
| PG&E | BNNIEN_7_ALTAPH          | 32376  | BONNIE N         | 60   | 0.61  |            | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | Not modeled<br>Aug NQC     | Market       |
| PG&E | BOGUE_1_UNITA1           | 32451  | FREC             | 13.8 | 47.38 | 1          | Sierra           | Drum-Rio Oso  | Aug NQC                    | Market       |
| PG&E | BOWMN_6_HYDRO            | 32480  | BOWMAN           | 9.11 | 2.00  | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC                    | MUNI         |
| PG&E | BUCKCK_2_HYDRO           |        |                  |      | 0.08  |            | Sierra           | South of Palermo  | Not modeled<br>Aug NQC     | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME   | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME  | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|-------|------------|------|--------|------------|------------------|---|----------------------------|--------------|
| PG&E | BUCKCK_7_OAKFLT          |       |            |      | 0.38   |            | Sierra           | South of Palermo  | Not modeled<br>Aug NQC     | Market       |
| PG&E | BUCKCK_7_PL1X2           | 31820 | BCKS CRK   | 11   | 21.76  | 2          | Sierra           | South of Palermo  | Aug NQC                    | Market       |
| PG&E | BUCKCK_7_PL1X2           | 31820 | BCKS CRK   | 11   | 25.04  | 1          | Sierra           | South of Palermo  | Aug NQC                    | Market       |
| PG&E | CAMPFW_7_FARWST          | 32470 | CMP.FARW   | 9.11 | 2.94   | 1          | Sierra           |   | Aug NQC                    | MUNI         |
| PG&E | CHICPK_7_UNIT 1          | 32462 | CHI.PARK   | 11.5 | 28.04  | 1          | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | Aug NQC                    | MUNI         |
| PG&E | COLGAT_7_UNIT 1          | 32450 | COLGATE1   | 13.8 | 176.72 | 1          | Sierra           |   | Aug NQC                    | MUNI         |
| PG&E | COLGAT_7_UNIT 2          | 32452 | COLGATE2   | 13.8 | 175.67 | 1          | Sierra           |   | Aug NQC                    | MUNI         |
| PG&E | CRESTA_7_PL1X2           | 31812 | CRESTA     | 11.5 | 25.64  | 1          | Sierra           | South of Palermo  | Aug NQC                    | Market       |
| PG&E | CRESTA_7_PL1X2           | 31812 | CRESTA     | 11.5 | 26.14  | 2          | Sierra           | South of Palermo  | Aug NQC                    | Market       |
| PG&E | DAVIS_1_SOLAR1           |       |            |      | 0.00   |            | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Not modeled<br>Energy Only | Solar        |
| PG&E | DAVIS_1_SOLAR2           |       |            |      | 0.00   |            | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Not modeled<br>Aug NQC     | Solar        |
| PG&E | DAVIS_7_MNMETH           |       |            |      | 2.26   |            | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Not modeled<br>Aug NQC     | Market       |
| PG&E | DEADCK_1_UNIT            | 31862 | DEADWOOD   | 9.11 | 0.00   | 1          | Sierra           | Drum-Rio Oso  | Aug NQC                    | MUNI         |
| PG&E | DEERCR_6_UNIT 1          | 32474 | DEER CRK   | 2.4  | 3.41   | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC                    | Market       |
| PG&E | DRUM_7_PL1X2             | 32504 | DRUMPHU1U2 | 6.6  | 5.20   | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC                    | Market       |
| PG&E | DRUM_7_PL1X2             | 32504 | DRUMPHU1U2 | 6.6  | 5.20   | 2          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC                    | Market       |
| PG&E | DRUM_7_PL3X4             | 32506 | DRUMPHU3U4 | 6.6  | 5.87   | 3          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC                    | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME   | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME  | NQC<br>Comments | CAISO<br>Tag |
|------|--------------------------|-------|------------|------|-------|------------|------------------|---|-----------------|--------------|
| PG&E | DRUM_7_PL3X4             | 32506 | DRUMPHU3U4 | 6.6  | 6.93  | 4          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC         | Market       |
| PG&E | DRUM_7_UNIT 5            | 32454 | DRUM 5     | 13.8 | 47.74 | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC         | Market       |
| PG&E | DUTCH1_7_UNIT 1          | 32464 | DTCHFLT1   | 11   | 20.78 | 1          | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | Aug NQC         | Market       |
| PG&E | DUTCH2_7_UNIT 1          | 32502 | DTCHFLT2   | 6.9  | 16.76 | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC         | MUNI         |
| PG&E | ELDORO_7_UNIT 1          | 32513 | ELDRADO1   | 21.6 | 4.10  | 1          | Sierra           | Gold Hill-Drum, South of Rio Oso,<br>South of Palermo                                 |                 | Market       |
| PG&E | ELDORO_7_UNIT 2          | 32514 | ELDRADO2   | 21.6 | 5.19  | 1          | Sierra           | Gold Hill-Drum, South of Rio Oso,<br>South of Palermo                                 |                 | Market       |
| PG&E | FMEADO_6_HELLHL          | 32486 | HELLHOLE   | 9.11 | 0.40  | 1          | Sierra           | South of Rio Oso,<br>South of Palermo   | Aug NQC         | MUNI         |
| PG&E | FMEADO_7_UNIT            | 32508 | FRNCH MD   | 4.2  | 16.00 | 1          | Sierra           | South of Rio Oso,<br>South of Palermo   | Aug NQC         | MUNI         |
| PG&E | FORBST_7_UNIT 1          | 31814 | FORBSTWN   | 11.5 | 37.50 | 1          | Sierra           | Drum-Rio Oso  | Aug NQC         | MUNI         |
| PG&E | GRIDLY_6_SOLAR           | 38054 | GRIDLEY    | 60   | 0.00  | 1          | Sierra           | Pease   | Energy Only     | Solar        |
| PG&E | GRIZLY_1_UNIT 1          | 31900 | GRIZZLYG   | 6.9  | 5.82  | 1          | Sierra           | South of Palermo  | Aug NQC         | MUNI         |
| PG&E | GRNLF2_1_UNIT            | 32492 | GRNLEAF2   | 13.8 | 49.20 | 1          | Sierra           | Pease, Drum-Rio<br>Oso  | Aug NQC         | QF/Selfgen   |
| PG&E | HALSEY_6_UNIT            | 32478 | HALSEY F   | 6.6  | 5.52  | 1          | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | Aug NQC         | Market       |
| PG&E | HAYPRS_6_HAYHD1          | 32488 | HAYPRES+   | 9.11 | 1.21  | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC         | Market       |
| PG&E | HAYPRS_6_HAYHD2          | 32488 | HAYPRES+   | 9.11 | 1.40  | 2          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC         | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME       | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME  | NQC<br>Comments        | CAISO<br>Tag |
|------|--------------------------|-------|----------------|------|--------|------------|------------------|---|------------------------|--------------|
| PG&E | HIGGNS_1_COMBIE          |       |                |      | 0.01   |            | Sierra           | Drum-Rio Oso,<br>South of Rio Oso,<br>South of Palermo                                | Not modeled<br>Aug NQC | Market       |
| PG&E | HIGGNS_7_QFUNTS          |       |                |      | 0.24   |            | Sierra           | Drum-Rio Oso,<br>South of Rio Oso,<br>South of Palermo                                | Not modeled<br>Aug NQC | QF/Selfgen   |
| PG&E | KELYRG_6_UNIT            | 31834 | KELLYRDG       | 4.16 | 11.00  | 1          | Sierra           | Drum-Rio Oso  | Aug NQC                | MUNI         |
| PG&E | LIVEOK_6_SOLAR           |       |                |      | 0.06   |            | Sierra           | Pease   | Not modeled<br>Aug NQC | Solar        |
| PG&E | LODIEC_2_PL1X2           | 38124 | LODIECST       | 18   | 103.55 | 1          | Sierra           | South of Rio Oso, South of<br>Palermo   |                        | MUNI         |
| PG&E | LODIEC_2_PL1X2           | 38123 | LODIECCT       | 18   | 199.03 | 1          | Sierra           | South of Rio Oso, South of<br>Palermo   |                        | MUNI         |
| PG&E | MDFKRL_2_PROJCT          | 32456 | MIDLFORK       | 13.8 | 63.94  | 1          | Sierra           | South of Rio Oso,<br>South of Palermo   | Aug NQC                | MUNI         |
| PG&E | MDFKRL_2_PROJCT          | 32456 | MIDLFORK       | 13.8 | 63.94  | 2          | Sierra           | South of Rio Oso,<br>South of Palermo   | Aug NQC                | MUNI         |
| PG&E | MDFKRL_2_PROJCT          | 32458 | RALSTON        | 13.8 | 82.13  | 1          | Sierra           | South of Rio Oso,<br>South of Palermo   | Aug NQC                | MUNI         |
| PG&E | NAROW1_2_UNIT            | 32466 | NARROWS1       | 11   | 12.00  | 1          | Sierra           |   | Aug NQC                | Market       |
| PG&E | NAROW2_2_UNIT            | 32468 | NARROWSPH<br>2 | 13.8 | 55.00  | 1          | Sierra           |   | Aug NQC                | MUNI         |
| PG&E | NWCSTL_7_UNIT 1          | 32460 | NEWCSTLE       | 13.2 | 0.00   | 1          | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | Aug NQC                | Market       |
| PG&E | OROVIL_6_UNIT            | 31888 | OROVLENRG      | 4.16 | 7.50   | 1          | Sierra           | Drum-Rio Oso  | Aug NQC                | Market       |
| PG&E | OXBOW_6_DRUM             | 32484 | OXBOW F        | 9.11 | 2.41   | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Aug NQC                | MUNI         |
| PG&E | PEASE_1_TBEBT1           | 91902 | 1902-WD        | 115  | 5.00   | FW         | Sierra           | Pease, Drum-Rio<br>Oso  |                        | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME                                     | NQC<br>Comments        | CAISO<br>Tag |
|------|--------------------------|-------|----------|------|-------|------------|------------------|--|------------------------|--------------|
| PG&E | PLACVL_1_CHILIB          | 32510 | CHILIBAR | 4.2  | 1.89  | 1          | Sierra           | Gold Hill-Drum,<br>South of Rio Oso,<br>South of Palermo | Aug NQC                | Market       |
| PG&E | PLACVL_1_RCKCRE          |       |          |      | 0.00  |            | Sierra           | Gold Hill-Drum,<br>South of Rio Oso,<br>South of Palermo | Not modeled<br>Aug NQC | Market       |
| PG&E | PLSNTG_7_LNCLND          | 32408 | PLSNT GR | 60   | 3.78  |            | Sierra           | Drum-Rio Oso,<br>South of Rio Oso,<br>South of Palermo   | Not modeled<br>Aug NQC | Market       |
| PG&E | POEPH_7_UNIT 1           | 31790 | POE 1    | 13.8 | 45.18 | 1          | Sierra           | South of Palermo   | Aug NQC                | Market       |
| PG&E | POEPH_7_UNIT 2           | 31792 | POE 2    | 13.8 | 42.64 | 1          | Sierra           | South of Palermo   | Aug NQC                | Market       |
| PG&E | RCKCRK_7_UNIT 1          | 31786 | ROCK CK1 | 13.8 | 32.00 | 1          | Sierra           | South of Palermo   | Aug NQC                | Market       |
| PG&E | RCKCRK_7_UNIT 2          | 31788 | ROCK CK2 | 13.8 | 40.00 | 1          | Sierra           | South of Palermo   | Aug NQC                | Market       |
| PG&E | RIOOSO_1_QF              |       |          |      | 0.30  |            | Sierra           | Drum-Rio Oso,<br>South of Palermo                        | Not modeled<br>Aug NQC | QF/Selfgen   |
| PG&E | ROLLIN_6_UNIT            | 32476 | ROLLINSF | 6.6  | 6.20  | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo                        | Aug NQC                | MUNI         |
| PG&E | SLYCRK_1_UNIT 1          | 31832 | SLY.CR.  | 6.6  | 13.00 | 1          | Sierra           | Drum-Rio Oso   | Aug NQC                | MUNI         |
| PG&E | SPAULD_6_UNIT 3          | 32472 | SPAULDG  | 9.11 | 3.53  | 3          | Sierra           | Drum-Rio Oso,<br>South of Palermo                        | Aug NQC                | Market       |
| PG&E | SPAULD_6_UNIT12          | 32472 | SPAULDG  | 9.11 | 1.40  | 2          | Sierra           | Drum-Rio Oso,<br>South of Palermo                        | Aug NQC                | Market       |
| PG&E | SPAULD_6_UNIT12          | 32472 | SPAULDG  | 9.11 | 2.22  | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo                        | Aug NQC                | Market       |
| PG&E | SPI LI_2_UNIT 1          | 32498 | SPILINCF | 12.5 | 9.55  | 1          | Sierra           | Drum-Rio Oso,<br>South of Rio Oso,<br>South of Palermo   | Aug NQC                | Net Seller   |
| PG&E | STIGCT_2_LODI            | 38114 | STIG CC  | 13.8 | 49.50 | 1          | Sierra           | South of Rio Oso, South of<br>Palermo                    |                        | MUNI         |
| PG&E | ULTRCK_2_UNIT            | 32500 | RBROCKLI | 12.5 | 23.38 | 1          | Sierra           | Drum-Rio Oso,<br>South of Rio Oso,<br>South of Palermo   | Aug NQC                | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME     | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME  | NQC<br>Comments        | CAISO<br>Tag |
|------|--------------------------|--------|--------------|------|-------|------------|------------------|---|------------------------|--------------|
| PG&E | WDLEAF_7_UNIT 1          | 31794  | WOODLEAF     | 13.8 | 60.00 | 1          | Sierra           | Drum-Rio Oso  | Aug NQC                | MUNI         |
| PG&E | WHEATL_6_LNDFIL          | 32350  | WHEATLND     | 60   | 3.55  |            | Sierra           |   | Not modeled<br>Aug NQC | Market       |
| PG&E | WISE_1_UNIT 1            | 32512  | WISE         | 12   | 8.85  | 1          | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | Aug NQC                | Market       |
| PG&E | WISE_1_UNIT 2            | 32512  | WISE         | 12   | 0.00  | 1          | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | Aug NQC                | Market       |
| PG&E | YUBACT_1_SUNSWT          | 32494  | YUBA CTY     | 13.8 | 49.97 | 1          | Sierra           | Pease, Drum-Rio<br>Oso  | Aug NQC                | Net Seller   |
| PG&E | YUBACT_6_UNITA1          | 32496  | YCEC         | 13.8 | 47.16 | 1          | Sierra           | Pease, Drum-Rio<br>Oso  |                        | Market       |
| PG&E | ZZ_GRNLF1_1_PL1X2        | 32490  | GRNLEAF1     | 13.8 | 0.00  | 1          | Sierra           | Drum-Rio Oso  | Strategic<br>Reserve   | Market       |
| PG&E | ZZ_GRNLF1_1_PL1X3        | 32491  | GRNLEAF1     | 13.8 | 0.00  | 2          | Sierra           | Drum-Rio Oso  | Strategic<br>Reserve   | Market       |
| PG&E | ZZ_NA                    | 32162  | RIV.DLTA     | 9.11 | 0.00  | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | No NQC -<br>hist. data | QF/Selfgen   |
| PG&E | ZZ_UCDAVS_1_UNIT         | 32166  | UC DAVIS     | 9.11 | 0.00  | RN         | Sierra           | Drum-Rio Oso,<br>South of Palermo   | No NQC -<br>hist. data | QF/Selfgen   |
| PG&E | ZZZ_New Unit             | 365936 | Q653FSPV     | 0.12 | 0.00  | 1          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Energy Only            | Solar        |
| PG&E | ZZZ_New Unit             | 365940 | Q653FSPV     | 0.12 | 0.00  | 2          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Energy Only            | Solar        |
| PG&E | ZZZ_New Unit             | 365938 | Q653FC6B     | 0.48 | 0.00  | 3          | Sierra           | Drum-Rio Oso,<br>South of Palermo   | Energy Only            | Battery      |
| PG&E | ZZZZA_New Unit           | 397077 | PLCRVLT21-25 | 25   | 0.00  | VS         | Sierra           | Gold Hill-Drum,<br>South of Rio Oso,<br>South of Palermo                              | No NQC -<br>est. data  | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME  | NQC<br>Comments       | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|-------|------------|------------------|---|-----------------------|--------------|
| PG&E | ZZZZA_New Unit           | 397078 | PLSNT GR1-25     | 25   | 0.00  | VS         | Sierra           | Drum-Rio Oso,<br>South of Rio Oso,<br>South of Palermo                                | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397091 | WOODLD 1-25      | 25   | 0.00  | VS         | Sierra           | Drum-Rio Oso,<br>South of Palermo   | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397092 | WYANDTTE1-<br>25 | 25   | 0.00  | VS         | Sierra           | Drum-Rio Oso  | No NQC -<br>est. data | Solar        |
| PG&E | ZZZZA_New Unit           | 397021 | HONCUT 1-25      | 25   | 0.58  | VB         | Sierra           | Drum-Rio Oso  | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397031 | PLCRVLT11-25     | 25   | 0.58  | VB         | Sierra           | Gold Hill-Drum,<br>South of Rio Oso,<br>South of Palermo                              | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397027 | PALERMO 1-<br>25 | 25   | 1.19  | VB         | Sierra           | Drum-Rio Oso  | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397011 | COLGATE 1-25     | 25   | 1.45  | VB         | Sierra           |   | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397006 | BRNSWCKP1-<br>25 | 25   | 2.02  | VB         | Sierra           | Drum-Rio Oso,<br>South of Palermo   | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 397020 | HIGGINS 1-25     | 25   | 4.35  | VB         | Sierra           | Placer, Gold Hill-<br>Drum, Drum-Rio<br>Oso, South of Rio<br>Oso, South of<br>Palermo | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit           | 91902  | 1902-WD          | 115  | 5.00  | FW         | Sierra           | Pease, Drum-Rio<br>Oso  | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit           | 397115 | GOLDHILL1-25     | 25   | 50.00 | E4         | Sierra           | South of Rio Oso,<br>South of Palermo   | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZZ_GOLDHL_1_QF        |        |                  |      | 0.00  |            | Sierra           | South of Rio Oso,<br>South of Palermo   | Retired               | QF/Selfgen   |
| PG&E | ZZZZZ_KANAKA_1_UNIT      |        |                  |      | 0.00  |            | Sierra           | Drum-Rio Oso  | Retired               | MUNI         |
| PG&E | ZZZZZ_PACORO_6_UNIT      | 31890  | PO POWER         | 9.11 | 0.00  | 1          | Sierra           | Drum-Rio Oso  | Retired               | QF/Selfgen   |
| PG&E | ZZZZZ_PACORO_6_UNIT      | 31890  | PO POWER         | 9.11 | 0.00  | 2          | Sierra           | Drum-Rio Oso  | Retired               | QF/Selfgen   |
| PG&E | BEARDS_7_UNIT 1          | 34074  | BEARDSLY         | 6.9  | 5.94  | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus  | Aug NQC               | MUNI         |
| PG&E | CAMCHE_1_PL1X3           | 33850  | CAMANCHE         | 4.2  | 0.29  | 1          | Stockton         | Tesla-Bellota   | Aug NQC               | MUNI         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments            | CAISO<br>Tag |
|------|--------------------------|--------|-----------------|------|--------|------------|------------------|------------------------------|----------------------------|--------------|
| PG&E | CAMCHE_1_PL1X3           | 33850  | CAMANCHE        | 4.2  | 0.29   | 2          | Stockton         | Tesla-Bellota                | Aug NQC                    | MUNI         |
| PG&E | CAMCHE_1_PL1X3           | 33850  | CAMANCHE        | 4.2  | 0.29   | 3          | Stockton         | Tesla-Bellota                | Aug NQC                    | MUNI         |
| PG&E | CENT40_1_C40SR1          | 365683 | Q1103SPV        | 0.32 | 4.96   | 1          | Stockton         | Tesla-Bellota                | Aug NQC                    | Solar        |
| PG&E | CRWCKS_1_SOLAR1          | 34053  | CRWCRKSLR1<br>G | 0.8  | 0.00   | 1          | Stockton         | Tesla-Bellota                | Energy Only                | Solar        |
| PG&E | DONNLS_7_UNIT            | 34058  | DONNELLS        | 13.8 | 72.00  | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus | Aug NQC                    | MUNI         |
| PG&E | FROGTN_1_UTICAA          |        |                 |      | 0.23   |            | Stockton         | Tesla-Bellota,<br>Stanislaus | Not Modeled<br>Aug NQC     | Market       |
| PG&E | FROGTN_1_UTICAM          |        |                 |      | 1.26   |            | Stockton         | Tesla-Bellota,<br>Stanislaus | Not Modeled<br>Aug NQC     | Market       |
| PG&E | LOCKFD_1_BEARCK          |        |                 |      | 0.19   |            | Stockton         | Tesla-Bellota                | Not Modeled<br>Aug NQC     | Solar        |
| PG&E | LOCKFD_1_KSOLAR          |        |                 |      | 0.12   |            | Stockton         | Tesla-Bellota                | Not Modeled<br>Aug NQC     | Solar        |
| PG&E | LODI25_2_UNIT 1          | 38120  | LODI25CT        | 13.8 | 0.00   | 1          | Stockton         | Lockeford                    | Retired by<br>2034         | MUNI         |
| PG&E | MANTEC_1_ML1SR1          |        |                 |      | 0.00   |            | Stockton         | Tesla-Bellota                | Not modeled<br>Energy Only | Solar        |
| PG&E | NORCNV_1_NCVBT1          | 39343  | Q1109           | 0.48 | 132.00 | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus |                            | Battery      |
| PG&E | PEORIA_1_SOLAR           |        |                 |      | 0.19   |            | Stockton         | Tesla-Bellota,<br>Stanislaus | Not modeled<br>Aug NQC     | Solar        |
| PG&E | PHOENX_1_UNIT            |        |                 |      | 1.02   |            | Stockton         | Tesla-Bellota,<br>Stanislaus | Not modeled<br>Aug NQC     | Market       |
| PG&E | SCHLTE_1_PL1X3           | 33805  | GWFTRCY1        | 13.8 | 93.05  | 1          | Stockton         | Tesla-Bellota                |                            | Market       |
| PG&E | SCHLTE_1_PL1X3           | 33807  | GWFTRCY2        | 13.8 | 93.05  | 1          | Stockton         | Tesla-Bellota                |                            | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments        | CAISO<br>Tag |
|------|--------------------------|--------|------------------|------|--------|------------|------------------|------------------------------|------------------------|--------------|
| PG&E | SCHLTE_1_PL1X3           | 33811  | GWFTRCY3         | 13.8 | 149.94 | 1          | Stockton         | Tesla-Bellota                |                        | Market       |
| PG&E | SNDBAR_7_UNIT 1          | 34060  | SANDBAR          | 13.8 | 3.57   | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus | Aug NQC                | MUNI         |
| PG&E | SPIFBD_1_PL1X2           | 34055  | SPISONOR         | 13.8 | 3.78   | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus | Aug NQC                | Market       |
| PG&E | SPRGAP_1_UNIT 1          | 34078  | SPRNG GP         | 6    | 0.00   | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus | Aug NQC                | Market       |
| PG&E | STANIS_7_UNIT 1          | 34062  | STANISLS         | 13.8 | 70.02  | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus | Aug NQC                | Market       |
| PG&E | STNRES_1_UNIT            | 34056  | COVANTAS         | 13.8 | 19.79  | 1          | Stockton         | Tesla-Bellota                | Aug NQC                | Net Seller   |
| PG&E | TULLCK_7_UNITS           | 34076  | TULLOCH          | 6.9  | 4.68   | 3          | Stockton         | Tesla-Bellota                | Aug NQC                | MUNI         |
| PG&E | TULLCK_7_UNITS           | 34076  | TULLOCH          | 6.9  | 6.34   | 1          | Stockton         | Tesla-Bellota                | Aug NQC                | MUNI         |
| PG&E | TULLCK_7_UNITS           | 34076  | TULLOCH          | 6.9  | 7.13   | 2          | Stockton         | Tesla-Bellota                | Aug NQC                | MUNI         |
| PG&E | ULTPCH_1_UNIT 1          | 34050  | CHINESESTA       | 12.5 | 17.81  | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus | Aug NQC                | Market       |
| PG&E | VLYHOM_7_SSJID           |        |                  |      | 0.29   |            | Stockton         | Tesla-Bellota,<br>Stanislaus | Not modeled<br>Aug NQC | MUNI         |
| PG&E | ZZZ_New Unit             | 366130 | Q1350SPV1        | 34.5 | 0.00   | 1          | Stockton         | Tesla-Bellota                | No NQC -<br>est. data  | Solar        |
| PG&E | ZZZ_New Unit             | 366131 | Q1350SPV2        | 34.5 | 0.00   | 1          | Stockton         | Tesla-Bellota                | No NQC -<br>est. data  | Solar        |
| PG&E | ZZZ_New Unit             | 365556 | SAFEWAYB         | 12.5 | 0.00   | RN         | Stockton         | Tesla-Bellota                | Energy Only            | Market       |
| PG&E | ZZZ_New Unit             | 365769 | Q1116BES         | 12.5 | 10.00  | 2          | Stockton         | Tesla-Bellota                | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZ_New Unit             | 366966 | Q1350BES         | 34.5 | 15.00  | 1          | Stockton         | Tesla-Bellota                | No NQC -<br>est. data  | Battery      |
| PG&E | ZZZZA_New Unit           | 365558 | TESLAMTR         | 12.5 | 0.00   | RN         | Stockton         | Tesla-Bellota                | Energy Only            | Market       |
| PG&E | ZZZZA_New Unit           | 397068 | LAMMERS 1-<br>25 | 25   | 0.00   | VS         | Stockton         | Tesla-Bellota                | No NQC -<br>est. data  | Solar        |
| PG&E | ZZZZA_New Unit           | 397071 | MANTECA 1-<br>25 | 25   | 0.00   | VS         | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data  | Solar        |
| PG&E | ZZZZA_New Unit           | 397082 | RIPON 1-25       | 25   | 0.00   | VS         | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data  | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO  | MKT/SCHED<br>RESOURCE ID   | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments       | CAISO<br>Tag |
|------|----------------------------|--------|------------------|------|-------|------------|------------------|------------------------------|-----------------------|--------------|
| PG&E | ZZZZA_New Unit             | 397004 | BELLOTA 1-25     | 26   | 0.29  | VB         | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit             | 397029 | PEORIA 1-25      | 25   | 0.58  | VB         | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit             | 397014 | DONNELLS1-<br>25 | 25   | 0.87  | VB         | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit             | 397013 | CURTISS 1-25     | 25   | 1.45  | VB         | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data | Market       |
| PG&E | ZZZZA_New Unit             | 397126 | RIPON 2-25       | 25   | 50.00 | E4         | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZA_New Unit             | 366261 | Q1557BESS        | 0.39 | 99.00 | 1          | Stockton         | Tesla-Bellota,<br>Stanislaus | No NQC -<br>est. data | Battery      |
| PG&E | ZZZZZZ_NA                  | 33830  | GEN.MILL         | 9.11 | 0.00  | 1          | Stockton         | Lockeford                    | Retired               | QF/Selfgen   |
| PG&E | ZZZZZZ_NA                  | 365339 | SPICHINESES<br>T | 12.5 | 0.00  | RE         | Stockton         | Tesla-Bellota,<br>Stanislaus | Retired               | QF/Selfgen   |
| PG&E | ZZZZZZ_SANJOA_1_UNI<br>T 1 | 33808  | SJ COGEN         | 13.8 | 0.00  | 1          | Stockton         | Tesla-Bellota                | Retired               | QF/Selfgen   |
| PG&E | ZZZZZZ_SMPRIP_1_SMP<br>SON | 33810  | SP CMPNY         | 13.8 | 46.05 | 1          | Stockton         | Tesla-Bellota                | Aug NQC               | Market       |
| SCE  | ACACIA_6_SOLAR             | 29878  | ACACIA_G         | 0.48 | 2.48  | 1          | BC/Ventura       |                              | Aug NQC               | Solar        |
| SCE  | ALAMO_6_UNIT               | 25653  | ALAMO SC         | 13.8 | 14.00 | 1          | BC/Ventura       |                              | Aug NQC               | MUNI         |
| SCE  | BGSKYN_2_AS2SR1            | 29773  | ANT2_EXP         | 0.63 | 11.58 | EQ         | BC/Ventura       |                              | Aug NQC               | Solar        |
| SCE  | BGSKYN_2_AS2SR2            | 29776  | ANT2_SPA         | 0.6  | 11.03 | EQ         | BC/Ventura       |                              | Aug NQC               | Solar        |
| SCE  | BGSKYN_2_ASSR1B            |        |                  |      | 13.42 |            | BC/Ventura       |                              | Aug NQC               | Solar        |
| SCE  | BGSKYN_2_ASSR3A            | 29745  | BSKY_G_DSR<br>3  | 0.6  | 1.65  | 1          | BC/Ventura       |                              | Aug NQC               | Solar        |
| SCE  | BGSKYN_2_ASSR3B            | 29745  | BSKY_G_DSR<br>3  | 0.6  | 0.55  | 1          | BC/Ventura       |                              | Aug NQC               | Solar        |
| SCE  | BGSKYN_2_BS3SR3            | 29774  | ANTLP2_P45_<br>G | 0.44 | 2.21  | EQ         | BC/Ventura       |                              | Aug NQC               | Solar        |
| SCE  | BIGCRK_2_EXESWD            | 24323  | PORTAL           | 4.8  | 8.26  | 1          | BC/Ventura       | Rector, Vestal               | Aug NQC               | Market       |
| SCE  | BIGCRK_2_EXESWD            | 24310  | B CRK2-3         | 7.2  | 14.63 | 5          | BC/Ventura       | Rector, Vestal               | Aug NQC               | Market       |
| SCE  | BIGCRK_2_EXESWD            | 24310  | B CRK2-3         | 7.2  | 15.92 | 6          | BC/Ventura       | Rector, Vestal               | Aug NQC               | Market       |
| SCE  | BIGCRK_2_EXESWD            | 24309  | B CRK2-2         | 7.2  | 16.09 | 3          | BC/Ventura       | Rector, Vestal               | Aug NQC               | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments            | CAISO<br>Tag |
|-----|--------------------------|-------|-----------------|------|--------|------------|------------------|----------------------|----------------------------|--------------|
| SCE | BIGCRK_2_EXESWD          | 24309 | B CRK2-2        | 7.2  | 16.95  | 4          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24306 | B CRK1-1        | 7.2  | 17.12  | 1          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24306 | B CRK1-1        | 7.2  | 18.59  | 2          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24307 | B CRK1-2        | 13.8 | 18.59  | 3          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24315 | B CRK 8         | 13.8 | 21.00  | 81         | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24307 | B CRK1-2        | 13.8 | 26.85  | 4          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24311 | B CRK3-1        | 13.8 | 29.26  | 2          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24311 | B CRK3-1        | 13.8 | 30.12  | 1          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24312 | B CRK3-2        | 13.8 | 30.12  | 3          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24312 | B CRK3-2        | 13.8 | 30.98  | 4          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24313 | B CRK3-3        | 13.8 | 31.41  | 5          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24315 | B CRK 8         | 13.8 | 37.86  | 82         | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24314 | B CRK 4         | 11.5 | 43.37  | 41         | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24314 | B CRK 4         | 11.5 | 43.54  | 42         | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24308 | B CRK2-1        | 13.8 | 43.71  | 1          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24308 | B CRK2-1        | 13.8 | 44.74  | 2          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24317 | MAMOTH1G        | 13.8 | 80.45  | 1          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_2_EXESWD          | 24318 | MAMOTH2G        | 13.8 | 80.45  | 2          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | BIGCRK_7_DAM7            |       |                 |      | 0.00   |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only | Market       |
| SCE | BIGCRK_7_MAMRES          |       |                 |      | 0.00   |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only | Market       |
| SCE | BIGSKY_2_AS2BT1          |       |                 |      | 127.00 |            | BC/Ventura       |                      |                            | Battery      |
| SCE | BIGSKY_2_AS1BT2          |       |                 |      | 100.00 |            | BC/Ventura       |                      |                            | Battery      |
| SCE | BIGSKY_2_BSKSR6          | 29736 | BSKY_G_BA       | 0.65 | 2.21   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | BIGSKY_2_BSKSR7          | 29742 | BSKY_G_BC       | 0.65 | 2.21   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | BIGSKY_2_BSKSR8          | 29739 | BSKY_G_BB       | 0.65 | 2.21   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | BIGSKY_2_SOLAR1          | 29724 | BSKY_G_ABS<br>R | 0.42 | 2.48   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments            | CAISO<br>Tag |
|-----|--------------------------|-------|------------------|------|--------|------------|------------------|----------------------|----------------------------|--------------|
| SCE | BIGSKY_2_SOLAR2          |       |                  |      | 31.53  |            | BC/Ventura       |                      | Not modeled<br>Aug NQC     | Solar        |
| SCE | BIGSKY_2_SOLAR3          | 29727 | BSKY_G_SMR       | 0.42 | 2.48   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | BIGSKY_2_SOLAR4          | 29701 | BSKY_G_ESW<br>A  | 0.42 | 15.82  | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | BIGSKY_2_SOLAR5          | 29733 | BSKY_G_DR1<br>2  | 0.44 | 0.55   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | BIGSKY_2_SOLAR6          | 29730 | BSKY_G_SOL<br>V  | 0.42 | 9.37   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | BIGSKY_2_SOLAR7          | 29733 | BSKY_G_DSR<br>12 | 0.44 | 6.20   | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | CEDUCR_2_SOLAR1          | 25049 | DUCOR1           | 0.39 | 0.00   | EQ         | BC/Ventura       | Vestal               | Energy Only                | Solar        |
| SCE | CEDUCR_2_SOLAR2          | 25052 | DUCOR2           | 0.39 | 0.00   | EQ         | BC/Ventura       | Vestal               | Energy Only                | Solar        |
| SCE | CEDUCR_2_SOLAR3          | 25055 | DUCOR3           | 0.39 | 0.00   | EQ         | BC/Ventura       | Vestal               | Energy Only                | Solar        |
| SCE | CEDUCR_2_SOLAR4          | 25058 | DUCOR4           | 0.39 | 0.00   | EQ         | BC/Ventura       | Vestal               | Energy Only                | Solar        |
| SCE | CHARMN_2_PGONG1          | 24340 | CHARMIN          | 13.8 | 19.61  | 1          | BC/Ventura       | S.Clara, Moorpark    |                            | QF/Selfgen   |
| SCE | DELSUR_6_BSOLAR          | 25802 | DEL SUR FD2      | 12.5 | 0.37   | PV         | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | DELSUR_6_CREST           |       |                  |      | 0.00   |            | BC/Ventura       |                      | Not modeled<br>Energy Only | Market       |
| SCE | DELSUR_6_DRYFRB          | 25802 | DEL SUR FD2      | 12.5 | 0.62   | PV         | BC/Ventura       |                      | Aug NQC                    | Market       |
| SCE | DELSUR_6_SOLAR1          | 25803 | DEL SUR FD3      | 12.5 | 0.81   | EQ         | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | DELSUR_6_SOLAR4          |       |                  |      | 0.00   |            | BC/Ventura       |                      | Not modeled<br>Energy Only | Solar        |
| SCE | DELSUR_6_SOLAR5          |       |                  |      | 0.00   |            | BC/Ventura       |                      | Not modeled<br>Energy Only | Solar        |
| SCE | EASTWD_7_UNIT            | 24319 | EASTWOOD         | 13.8 | 199.00 | 1          | BC/Ventura       | Rector, Vestal       |                            | Market       |
| SCE | EDMONS_2_NSPIN           | 25605 | EDMON1AP         | 14.4 | 16.86  | 1          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25606 | EDMON2AP         | 14.4 | 16.86  | 2          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25607 | EDMON3AP         | 14.4 | 16.86  | 3          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25607 | EDMON3AP         | 14.4 | 16.86  | 4          | BC/Ventura       |                      | Pumps                      | MUNI         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME       | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments                          | CAISO<br>Tag |
|-----|--------------------------|-------|----------------|------|--------|------------|------------------|------------------------------|--|--------------|
| SCE | EDMONS_2_NSPIN           | 25608 | EDMON4AP       | 14.4 | 16.86  | 5          | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25608 | EDMON4AP       | 14.4 | 16.86  | 6          | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25609 | EDMON5AP       | 14.4 | 16.86  | 7          | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25609 | EDMON5AP       | 14.4 | 16.86  | 8          | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25610 | EDMON6AP       | 14.4 | 16.86  | 9          | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25610 | EDMON6AP       | 14.4 | 16.86  | 10         | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25611 | EDMON7AP       | 14.4 | 16.86  | 11         | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25611 | EDMON7AP       | 14.4 | 16.86  | 12         | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25612 | EDMON8AP       | 14.4 | 16.86  | 13         | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | EDMONS_2_NSPIN           | 25612 | EDMON8AP       | 14.4 | 16.86  | 14         | BC/Ventura       |                              | Pumps                                    | MUNI         |
| SCE | GLDFGR_6_SOLAR1          | 25079 | PRIDE B G      | 0.64 | 2.48   | 1          | BC/Ventura       |                              | Aug NQC                                  | Solar        |
| SCE | GLDFGR_6_SOLAR2          | 25169 | PRIDE C G      | 0.64 | 1.41   | 1          | BC/Ventura       |                              | Aug NQC                                  | Solar        |
| SCE | GLOW_6_SOLAR             | 29896 | APPINV         | 0.42 | 0.00   | 1          | BC/Ventura       |                              | Energy Only                              | Solar        |
| SCE | GOLETA_2_QF              | 25895 | GOLETA<br>EQFD | 12.5 | 0.11   | EQ         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | Aug NQC                                  | QF/Selfgen   |
| SCE | GOLETA_2_VALBT1          | 25726 | WDT1492_G      | 0.6  | 10.00  | EQ         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta |  | Battery      |
| SCE | GOLETA_6_ELLWOD          | 29004 | ELLWOOD        | 13.8 | 54.00  | 1          | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | Could retire<br>by 2039                  | Market       |
| SCE | GOLETA_6_EXGEN           | 24362 | EXGEN2         | 13.8 | 0.00   | G1         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | Aug NQC -<br>Currently out<br>of service | QF/Selfgen   |
| SCE | GOLETA_6_EXGEN           | 24326 | EXGEN1         | 13.8 | 0.00   | S1         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | Aug NQC -<br>Currently out<br>of service | QF/Selfgen   |
| SCE | LEBECS_2_UNITS           | 29055 | PSTRIAS2       | 18   | 85.55  | S2         | BC/Ventura       |                              | Could retire<br>by 2039. Aug<br>NQC      | Market       |
| SCE | LEBECS_2_UNITS           | 29051 | PSTRIAG1       | 18   | 171.10 | G1         | BC/Ventura       |                              | Could retire<br>by 2039. Aug<br>NQC      | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments                     | CAISO<br>Tag |
|-----|--------------------------|--------|-----------------|------|--------|------------|------------------|----------------------|-------------------------------------|--------------|
| SCE | LEBECS_2_UNITS           | 29052  | PSTRIAG2        | 18   | 171.10 | G2         | BC/Ventura       |                      | Could retire<br>by 2039. Aug<br>NQC | Market       |
| SCE | LEBECS_2_UNITS           | 29054  | PSTRIAG3        | 18   | 171.10 | G3         | BC/Ventura       |                      | Could retire<br>by 2039. Aug<br>NQC | Market       |
| SCE | LEBECS_2_UNITS           | 29053  | PSTRIAS1        | 18   | 176.14 | S1         | BC/Ventura       |                      | Could retire<br>by 2039. Aug<br>NQC | Market       |
| SCE | LITLRK_6_GBCSR1          | 25798  | OASIS FD        | 12.5 | 0.37   | PV         | BC/Ventura       |                      | Aug NQC                             | Solar        |
| SCE | LITLRK_6_SEPV01          |        |                 |      | 0.00   |            | BC/Ventura       |                      | Not modeled<br>Energy Only          | Market       |
| SCE | LITLRK_6_SOLAR1          | 25840  | LITLRCK FD      | 12.5 | 0.62   | EQ         | BC/Ventura       |                      | Aug NQC                             | Solar        |
| SCE | LITLRK_6_SOLAR2          | 25840  | LITLRCK FD      | 12.5 | 0.25   | EQ         | BC/Ventura       |                      | Aug NQC                             | Solar        |
| SCE | LITLRK_6_SOLAR3          | 25840  | LITLRCK FD      | 12.5 | 0.25   | EQ         | BC/Ventura       |                      | Aug NQC                             | Solar        |
| SCE | LITLRK_6_SOLAR4          | 25840  | LITLRCK FD      | 12.5 | 0.37   | EQ         | BC/Ventura       |                      | Aug NQC                             | Solar        |
| SCE | LNCSTR_6_CREST           |        |                 |      | 0.00   |            | BC/Ventura       |                      | Not modeled<br>Energy Only          | Market       |
| SCE | LNCSTR_6_SOLAR2          | 25796  | LANCSTR FD1     | 12.5 | 6.90   | EQ         | BC/Ventura       |                      | Aug NQC                             | Solar        |
| SCE | MNDALY_6_MCGRTH          | 29306  | MCGPKGEN        | 13.8 | 48.56  | 1          | BC/Ventura       | S.Clara, Moorpark    |                                     | Market       |
| SCE | MOORPK_2_ACOBT1          |        |                 |      | 1.00   |            | BC/Ventura       | Moorpark             | Not modeled                         | Battery      |
| SCE | MOORPK_2_CALABS          | 25081  | WDT251          | 13.8 | 3.44   | EQ         | BC/Ventura       | Moorpark             | Aug NQC                             | Market       |
| SCE | MOORPK_6_QF              | 240111 | MOORARK<br>EQFD | 16   | 0.28   | HY         | BC/Ventura       | Moorpark             | Aug NQC                             | Market       |
| SCE | NEENCH_6_SOLAR           | 29900  | ALPINE_G        | 0.48 | 8.18   | EQ         | BC/Ventura       |                      | Aug NQC                             | Solar        |
| SCE | OASIS_6_CREST            |        |                 |      | 0.00   |            | BC/Ventura       |                      | Not modeled<br>Energy Only          | Market       |
| SCE | OASIS_6_GBDSR4           | 25800  | ANTLOPE<br>EQFD | 12.5 | 0.37   | EQ         | BC/Ventura       |                      | Aug NQC                             | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC  | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments            | CAISO<br>Tag |
|-----|--------------------------|-------|------------------|------|------|------------|------------------|----------------------|----------------------------|--------------|
| SCE | OASIS_6_SOLAR1           | 25095 | SOLARISG2        | 0.2  | 0.00 | 2          | BC/Ventura       |                      | Energy Only                | Solar        |
| SCE | OASIS_6_SOLAR2           | 25075 | SOLARISG         | 0.2  | 2.48 | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | OASIS_6_SOLAR3           |       |                  |      | 0.00 |            | BC/Ventura       |                      | Not modeled<br>Energy Only | Solar        |
| SCE | OMAR_2_UNIT 1            | 24102 | OMAR 1G          | 13.8 | 0.00 | 1          | BC/Ventura       |                      | Could retire<br>by 2034    | Net Seller   |
| SCE | OMAR_2_UNIT 2            | 24103 | OMAR 2G          | 13.8 | 0.00 | 2          | BC/Ventura       |                      | Could retire<br>by 2034    | Net Seller   |
| SCE | OMAR_2_UNIT 3            | 24104 | OMAR 3G          | 13.8 | 0.00 | 3          | BC/Ventura       |                      | Could retire<br>by 2034    | Net Seller   |
| SCE | OMAR_2_UNIT 4            | 24105 | OMAR 4G          | 13.8 | 0.00 | 4          | BC/Ventura       |                      | Could retire<br>by 2034    | Net Seller   |
| SCE | ORMOND_7_UNIT 1          | 24107 | ORMOND1G         | 26   | 0.00 | 1          | BC/Ventura       | Moorpark             | Strategic<br>Reserve       | Market       |
| SCE | ORMOND_7_UNIT 2          | 24108 | ORMOND2G         | 26   | 0.00 | 2          | BC/Ventura       | Moorpark             | Strategic<br>Reserve       | Market       |
| SCE | OSO_6_NSPIN              | 25614 | OSO A P          | 13.2 | 2.25 | 1          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | OSO_6_NSPIN              | 25614 | OSO A P          | 13.2 | 2.25 | 2          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | OSO_6_NSPIN              | 25614 | OSO A P          | 13.2 | 2.25 | 3          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | OSO_6_NSPIN              | 25614 | OSO A P          | 13.2 | 2.25 | 4          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | OSO_6_NSPIN              | 25615 | OSO B P          | 13.2 | 2.25 | 5          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | OSO_6_NSPIN              | 25615 | OSO B P          | 13.2 | 2.25 | 6          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | OSO_6_NSPIN              | 25615 | OSO B P          | 13.2 | 2.25 | 7          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | OSO_6_NSPIN              | 25615 | OSO B P          | 13.2 | 2.25 | 8          | BC/Ventura       |                      | Pumps                      | MUNI         |
| SCE | PIUTE_6_GNBSR1           | 25840 | LITLRCK FD       | 12.5 | 0.37 | EQ         | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | PLAINV_6_BSOLAR          | 29917 | SSOLAR_GRW<br>KS | 0.8  | 0.00 | 1          | BC/Ventura       |                      | Energy Only                | Solar        |
| SCE | PLAINV_6_DSOLAR          | 29914 | WADR_PV          | 0.42 | 1.24 | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | PLAINV_6_NLRSR1          | 29921 | NLR_INVTR        | 0.42 | 0.00 | 1          | BC/Ventura       |                      | Energy Only                | Solar        |
| SCE | PLAINV_6_SOLAR3          | 25089 | CNTRL ANT G      | 0.42 | 0.00 | 1          | BC/Ventura       |                      | Energy Only                | Solar        |
| SCE | PLAINV_6_SOLARC          | 25086 | SIRA SOLAR G     | 0.8  | 0.00 | 1          | BC/Ventura       |                      | Energy Only                | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC  | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments            | CAISO<br>Tag |
|-----|--------------------------|-------|-----------------|------|------|------------|------------------|----------------------|----------------------------|--------------|
| SCE | PMDLET_6_SOLAR1          | 29926 | WDT404_G        | 0.8  | 1.24 | EQ         | BC/Ventura       |                      | AugNQC                     | Solar        |
| SCE | RECTOR_2_CREST           |       |                 |      | 0.00 |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only | Market       |
| SCE | RECTOR_2_IVANPV          |       |                 |      | 0.00 |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only | Solar        |
| SCE | RECTOR_2_KAWEAH          | 25755 | KAWEAH1G        | 2.4  | 0.01 | 1          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | RECTOR_2_KAWEAH          | 25754 | KAWEAH2G        | 2.4  | 0.01 | 2          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | RECTOR_2_KAWEAH          | 25756 | KAWEAH3G        | 2.4  | 0.02 | 1          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | RECTOR_2_KAWH 1          | 24370 | KAWGEN          | 13.8 | 0.03 | 1          | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Market       |
| SCE | RECTOR_2_QF              |       |                 |      | 0.00 |            | BC/Ventura       | Rector, Vestal       | Aug NQC                    | Net Seller   |
| SCE | RECTOR_2_TFDBM1          |       |                 |      | 0.00 |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only | Market       |
| SCE | RECTOR_7_TULARE          |       |                 |      | 0.00 |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Aug NQC     | Market       |
| SCE | REDMAN_2_SOLAR           | 25800 | ANTLOPE<br>EQFD | 12.5 | 0.47 | EQ         | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | REDMAN_6_AVSSR1          | 25800 | ANTLOPE<br>EQFD | 12.5 | 0.37 | EQ         | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | ROSMND_6_SOLAR           | 25800 | ANTLOPE<br>EQFD | 12.5 | 0.37 | EQ         | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | RSMSLR_6_SOLAR1          | 29884 | DAWNGEN         | 0.8  | 2.48 | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | RSMSLR_6_SOLAR2          | 29888 | TWILGHTG        | 0.8  | 2.48 | 1          | BC/Ventura       |                      | Aug NQC                    | Solar        |
| SCE | SAUGUS_6_CREST           |       |                 |      | 0.00 |            | BC/Ventura       |                      | Not modeled<br>Energy Only | Market       |
| SCE | SAUGUS_6_MWDFTH          | 25721 | FOOTHILL        | 66   | 4.00 | EQ         | BC/Ventura       |                      | Aug NQC                    | MUNI         |
| SCE | SAUGUS_6_QF              | 25891 | SUAGUS<br>EQFD  | 12.5 | 0.30 | EQ         | BC/Ventura       |                      | Aug NQC                    | QF/Selfgen   |
| SCE | SAUGUS_6_QF              | 25865 | SUAGUS<br>EQFD  | 12.5 | 0.30 | HY         | BC/Ventura       |                      | Aug NQC                    | QF/Selfgen   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME  | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments                     | CAISO<br>Tag |
|-----|--------------------------|-------|-----------|------|--------|------------|------------------|----------------------|-------------------------------------|--------------|
| SCE | SAUGUS_7_CHIQCN          | 25722 | LANDFILL  | 66   | 5.35   | EQ         | BC/Ventura       |                      | Aug NQC                             | Market       |
| SCE | SHUTLE_6_CREST           |       |           |      | 0.00   |            | BC/Ventura       |                      | Not modeled<br>Energy Only          | Market       |
| SCE | SNCLRA_2_HOWLNG          |       |           |      | 5.03   |            | BC/Ventura       | S.Clara, Moorpark    | Not modeled<br>Aug NQC              | Market       |
| SCE | SNCLRA_2_SILBT1          | 25899 | WDT1520_G | 0.48 | 11.00  | EQ         | BC/Ventura       | S.Clara, Moorpark    |                                     | Battery      |
| SCE | SNCLRA_2_SPRHYD          |       |           |      | 0.16   |            | BC/Ventura       | S.Clara, Moorpark    | Not modeled<br>Aug NQC              | Market       |
| SCE | SNCLRA_2_UNIT            | 29952 | CAMGEN    | 13.8 | 27.50  | D1         | BC/Ventura       | S.Clara, Moorpark    |                                     | Market       |
| SCE | SNCLRA_2_UNIT1           | 24159 | WILLAMET  | 3.8  | 0.00   | D1         | BC/Ventura       | S.Clara, Moorpark    | Could retire<br>by 2034. Aug<br>NQC | Market       |
| SCE | SNCLRA_2_VESBT1          | 29824 | WDT1519   | 66   | 100.00 | 1          | BC/Ventura       | S.Clara, Moorpark    |                                     | Battery      |
| SCE | SNCLRA_6_OXGEN           | 24110 | OXGEN     | 13.8 | 47.70  | D1         | BC/Ventura       | S.Clara, Moorpark    |                                     | QF/Selfgen   |
| SCE | SNCLRA_6_PROCGN          | 24119 | PROCGEN   | 13.8 | 19.41  | D1         | BC/Ventura       | S.Clara, Moorpark    | Could retire<br>by 2039. Aug<br>NQC | QF/Selfgen   |
| SCE | SNCLRA_6_QF              |       |           |      | 0.31   |            | BC/Ventura       | S.Clara, Moorpark    | Not modeled<br>Aug NQC              | QF/Selfgen   |
| SCE | SPRGVL_2_CREST           |       |           |      | 0.00   |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only          | Market       |
| SCE | SPRGVL_2_EXETPV          |       |           |      | 0.00   |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only          | Market       |
| SCE | SPRGVL_2_LINDPV          |       |           |      | 0.00   |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only          | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME | kV   | NQC  | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments                     | CAISO<br>Tag |
|-----|--------------------------|-------|----------|------|------|------------|------------------|----------------------|-------------------------------------|--------------|
| SCE | SPRGVL_2_PORTPV          |       |          |      | 0.00 |            | BC/Ventura       | Rector, Vestal       | Not modeled<br>Energy Only          | Market       |
| SCE | SPRGVL_2_TULESC          | 25715 | TULE     | 66   | 0.00 | EQ         | BC/Ventura       | Rector, Vestal       | Aug NQC                             | Market       |
| SCE | SUNSHN_2_LNDFL           | 29954 | SUNSHINE | 13.7 | 3.15 | 1          | BC/Ventura       |                      | Aug NQC                             | Market       |
| SCE | SUNSHN_2_LNDFL           | 29954 | SUNSHINE | 13.7 | 3.15 | 2          | BC/Ventura       |                      | Aug NQC                             | Market       |
| SCE | SUNSHN_2_LNDFL           | 29954 | SUNSHINE | 13.7 | 3.15 | 3          | BC/Ventura       |                      | Aug NQC                             | Market       |
| SCE | SUNSHN_2_LNDFL           | 29954 | SUNSHINE | 13.7 | 3.15 | 4          | BC/Ventura       |                      | Aug NQC                             | Market       |
| SCE | SUNSHN_2_LNDFL           | 29954 | SUNSHINE | 13.7 | 3.15 | 5          | BC/Ventura       |                      | Aug NQC                             | Market       |
| SCE | SYCAMR_2_UNIT 1          | 24143 | SYCCYN1G | 13.8 | 0.00 | 1          | BC/Ventura       |                      | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| SCE | SYCAMR_2_UNIT 2          | 24144 | SYCCYN2G | 13.8 | 0.00 | 2          | BC/Ventura       |                      | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| SCE | SYCAMR_2_UNIT 3          | 24145 | SYCCYN3G | 13.8 | 0.00 | 3          | BC/Ventura       |                      | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| SCE | SYCAMR_2_UNIT 4          | 24146 | SYCCYN4G | 13.8 | 0.00 | 4          | BC/Ventura       |                      | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| SCE | TENGEN_2_PL1X2           | 24148 | TENNGEN1 | 13.8 | 0.00 | D1         | BC/Ventura       |                      | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| SCE | TENGEN_2_PL1X2           | 24149 | TENNGEN2 | 13.8 | 0.00 | D2         | BC/Ventura       |                      | Could retire<br>by 2034. Aug<br>NQC | Net Seller   |
| SCE | TULARE_2_TULBM1          |       |          |      | 0.00 |            | BC/Ventura       |                      | Not modeled<br>Energy Only          | Market       |
| SCE | VESTAL_2_KERN            | 24373 | KR 3-2   | 11   | 0.15 | 2          | BC/Ventura       | Vestal               | Aug NQC                             | QF/Selfgen   |
| SCE | VESTAL_2_KERN            | 24372 | KR 3-1   | 11   | 0.15 | 1          | BC/Ventura       | Vestal               | Aug NQC                             | QF/Selfgen   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV        | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments           | CAISO<br>Tag |
|-----|--------------------------|--------|------------------|-----------|-------|------------|------------------|------------------------------|---------------------------|--------------|
| SCE | VESTAL_2_RTS042          | 25874  | VESTAL EQFC      | 12.4<br>7 | 0.00  | HY         | BC/Ventura       | Vestal                       | Energy Only               | Market       |
| SCE | VESTAL_2_SOLAR1          | 25064  | TULRESLR_1<br>G  | 0.39      | 2.48  | EQ         | BC/Ventura       | Vestal                       | Aug NQC                   | Solar        |
| SCE | VESTAL_2_SOLAR2          | 25065  | TULRESLR_2<br>G  | 0.39      | 1.74  | EQ         | BC/Ventura       | Vestal                       | Aug NQC                   | Solar        |
| SCE | VESTAL_2_TS5SR1          | 25874  | VESTAL EQFC      | 12.5      | 6.92  | PV         | BC/Ventura       | Vestal                       | Aug NQC                   | Solar        |
| SCE | VESTAL_2_UNIT1           | 25874  | VESTAL EQFC      | 12.5      | 2.69  | SY         | BC/Ventura       | Vestal                       | Aug NQC                   | Market       |
| SCE | VESTAL_2_WELLHD          | 24116  | WELLGEN          | 13.8      | 49.00 | 1          | BC/Ventura       | Vestal                       |                           | Market       |
| SCE | VESTAL_6_QF              | 29008  | LAKEGEN          | 13.8      | 0.72  | 2          | BC/Ventura       | Vestal                       | Aug NQC                   | Market       |
| SCE | VESTAL_6_QF              | 29008  | LAKEGEN          | 13.8      | 1.77  | 1          | BC/Ventura       | Vestal                       | Aug NQC                   | Market       |
| SCE | WARNE_2_UNIT             | 25651  | WARNE1           | 13.8      | 19.54 | 1          | BC/Ventura       |                              | Aug NQC                   | MUNI         |
| SCE | WARNE_2_UNIT             | 25652  | WARNE2           | 13.8      | 19.54 | 2          | BC/Ventura       |                              | Aug NQC                   | MUNI         |
| SCE | ZZZ_New Unit             | 240011 | ANODE_G1         | 34.5      | 0.00  | 1          | BC/Ventura       | Rector, Vestal               | Waiting TPD<br>allocation | Battery      |
| SCE | ZZZ_New Unit             | 240014 | ANODE_G2         | 34.5      | 0.00  | 2          | BC/Ventura       | Rector, Vestal               | Waiting TPD<br>allocation | Battery      |
| SCE | ZZZ_New Unit             | 25867  | SPRNGVL          | 12.5      | 0.00  | EN         | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data     | Market       |
| SCE | ZZZ_New Unit             | 29775  | ANTLP2_P7_G<br>1 | 0.44      | 0.00  | EQ         | BC/Ventura       |                              | No NQC -<br>est. data     | Solar        |
| SCE | ZZZ_New Unit             | 25865  | SUAGUS<br>EQFD   | 12.5      | 0.00  | PV         | BC/Ventura       |                              | Energy Only               | Solar        |
| SCE | ZZZ_New Unit             | 25867  | SPRNGVL          | 12.5      | 0.00  | PV         | BC/Ventura       | Rector, Vestal               | Energy Only               | Solar        |
| SCE | ZZZ_New Unit             | 25800  | ANTLOPE<br>EQFD  | 12.5      | 0.00  | WD         | BC/Ventura       |                              | Energy Only               | Wind         |
| SCE | ZZZ_New Unit             | 29569  | ANTLP2_P5_G      | 0.66      | 0.63  | 1          | BC/Ventura       |                              | No NQC -<br>est. data     | Solar        |
| SCE | ZZZ_New Unit             | 25867  | SPRNGVL          | 12.5      | 1.00  | EQ         | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data     | Market       |
| SCE | ZZZ_New Unit             | 240115 | GOLETA<br>EQFD   | 16        | 1.10  | HY         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | No NQC -<br>est. data     | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME          | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments       | CAISO<br>Tag |
|-----|--------------------------|--------|-------------------|------|-------|------------|------------------|------------------------------|-----------------------|--------------|
| SCE | ZZZ_New Unit             | 29774  | ANTLP2_P4_G       | 0.63 | 1.88  | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 25855  | RECTOR<br>EQFD    | 12.5 | 1.94  | PV         | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 29775  | ANTLP2_P8_G<br>1  | 0.66 | 2.18  | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 240115 | GOLETA<br>EQFD    | 16   | 3.34  | SY         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | No NQC -<br>est. data | Market       |
| SCE | ZZZ_New Unit             | 29565  | ANTLP2_P10_<br>G2 | 0.69 | 3.65  | 2          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 29771  | ANT2_SPB          | 0.6  | 5.08  | EQ         | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 25069  | WDT1490_PV        | 0.36 | 7.11  | 1          | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 29782  | ANTLP2_C2_G<br>1  | 0.44 | 7.19  | EQ         | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 29566  | ANTLP2_P1BG<br>2  | 0.69 | 8.06  | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 25795  | WDT1539_G         | 0.8  | 10.00 | 1          | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 29563  | ANTLP2_P9_G<br>2  | 0.69 | 10.23 | 2          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 29767  | ANTLP2_P7B_<br>G  | 0.69 | 12.88 | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZ_New Unit             | 101801 | WDT1710_G         | 66   | 14.00 | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZ_New Unit             | 25965  | TOT896_G2PV       | 0.55 | 18.76 | 1          | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 25959  | TOT896_G1PV       | 0.55 | 19.01 | 1          | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Solar        |
| SCE | ZZZ_New Unit             | 29830  | WDT1454           | 66   | 20.00 | 1          | BC/Ventura       | S.Clara, Moorpark            | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 240418 | WDT1532_G         | 0.48 | 30.00 | 1          | BC/Ventura       | S.Clara, Moorpark            | No NQC -<br>est. data | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME          | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments       | CAISO<br>Tag |
|-----|--------------------------|--------|-------------------|------|--------|------------|------------------|------------------------------|-----------------------|--------------|
| SCE | ZZZ_New Unit             | 29826  | WDT1454           | 66   | 40.00  | 1          | BC/Ventura       | S.Clara, Moorpark            | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 29836  | WDT1384_G         | 0.63 | 50.00  | 1          | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Hybrid       |
| SCE | ZZZ_New Unit             | 240433 | WDT1649_G         | 0.39 | 80.00  | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZ_New Unit             | 25967  | TOT896_G2ST       | 0.55 | 109.50 | 1          | BC/Ventura       | Vestal                       | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 25961  | TOT896_G1ST       | 0.55 | 109.50 | 1          | BC/Ventura       | Vestal                       | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 29561  | ANTLP2_P1_G<br>1  | 0.63 | 125.00 | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZ_New Unit             | 240419 | WDT1647_G         | 0.69 | 134.90 | 1          | BC/Ventura       | Moorpark                     | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 29782  | ANTLP2_P10_<br>G1 | 0.66 | 0.00   | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 29792  | ANTLP2_P6A_<br>G  | 0.69 | 0.00   | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 240461 | WDT1580_PV        | 0.55 | 0.00   | 1          | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 240104 | S.CLARA<br>EQFD   | 16   | 0.01   | PV         | BC/Ventura       | S.Clara, Moorpark            | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 240100 | MOORARK<br>EQFD   | 16   | 0.11   | HY         | BC/Ventura       | Moorpark                     | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 25855  | RECTOR<br>EQFD    | 12.5 | 0.24   | EQ         | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 25855  | RECTOR<br>EQFD    | 12.5 | 0.24   | SL         | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 240100 | MOORARK<br>EQFD   | 16   | 0.37   | PV         | BC/Ventura       | Moorpark                     | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 240100 | MOORARK<br>EQFD   | 16   | 0.43   | T          | BC/Ventura       | Moorpark                     | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 25319  | RP_Goleta         | 13.8 | 0.92   | VB         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | No NQC -<br>est. data | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments       | CAISO<br>Tag |
|-----|--------------------------|--------|------------------|------|-------|------------|------------------|------------------------------|-----------------------|--------------|
| SCE | ZZZZA_New Unit           | 240104 | S.CLARA<br>EQFD  | 16   | 1.00  | T          | BC/Ventura       | S.Clara, Moorpark            | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 240100 | MOORARK<br>EQFD  | 16   | 2.00  | B          | BC/Ventura       | Moorpark                     | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240115 | GOLETA<br>EQFD   | 16   | 2.16  | FC         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 240525 | NST88338_G       | 0.6  | 2.48  | 1          | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 29086  | CALGREN_PIX      | 12.5 | 5.00  | 1          | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 240701 | TOT833_PV1       | 0.55 | 5.00  | S1         | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 29086  | CALGREN_PIX      | 12.5 | 6.00  | 2          | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 25322  | RP_ANTELOP<br>E_ | 0.69 | 8.49  | VW         | BC/Ventura       |                              | No NQC -<br>est. data | Wind         |
| SCE | ZZZZA_New Unit           | 25325  | RP_ANTELOP<br>E_ | 0.69 | 8.49  | VW         | BC/Ventura       |                              | No NQC -<br>est. data | Wind         |
| SCE | ZZZZA_New Unit           | 240702 | TOT833_PV2       | 0.55 | 10.00 | S2         | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 240336 | BESSGEN          | 0.63 | 12.50 | 2          | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240338 | BESSGEN          | 0.63 | 12.50 | 2          | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 25865  | SUAGUS<br>EQFD   | 12.5 | 15.00 | BS         | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240695 | WDT1701_G        | 0.69 | 15.50 | 1          | BC/Ventura       | S.Clara, Moorpark            | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 25865  | SUAGUS<br>EQFD   | 12.5 | 19.00 | T          | BC/Ventura       |                              | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 25360  | RP_VESTAL_P<br>V | 0.38 | 25.42 | VS         | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 25348  | RP_ANT_PV_<br>G_ | 0.38 | 25.48 | VS         | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID  | BUS #  | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME         | NQC<br>Comments       | CAISO<br>Tag |
|-----|---------------------------|--------|------------------|------|--------|------------|------------------|------------------------------|-----------------------|--------------|
| SCE | ZZZZA_New Unit            | 25351  | RP_ANT_PV_<br>G_ | 0.38 | 25.48  | VS         | BC/Ventura       |                              | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit            | 240704 | TOT833_B2        | 0.55 | 27.50  | B2         | BC/Ventura       |                              | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZZA_New Unit            | 240463 | WDT1580_ES       | 0.6  | 40.00  | 1          | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit            | 240703 | TOT833_B1        | 0.55 | 55.00  | B1         | BC/Ventura       |                              | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZZA_New Unit            | 240409 | WDT1650_G        | 0.48 | 80.00  | 1          | BC/Ventura       | Rector, Vestal               | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit            | 240406 | WDT1639-ES       | 0.69 | 83.00  | 1          | BC/Ventura       | Vestal                       | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit            | 25437  | RP_ANTELOP<br>E_ | 0.66 | 129.00 | VE         | BC/Ventura       |                              | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit            | 25440  | RP_MP_G_1        | 0.66 | 150.00 | VE         | BC/Ventura       | Moorpark                     | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit            | 25443  | RP_MP_G_2        | 0.66 | 150.00 | VE         | BC/Ventura       | Moorpark                     | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit            | 240282 | RP_MANDALY<br>_G | 0.66 | 200.00 | VE         | BC/Ventura       | S.Clara, Moorpark            | No NQC -<br>est. data | Battery      |
| SCE | ZZZZZ_APPGEN_6_UNIT<br>1  | 24009  | APPGEN1G         | 13.8 | 0.00   | 1          | BC/Ventura       |                              | Retired               | Market       |
| SCE | ZZZZZ_APPGEN_6_UNIT<br>1  | 24010  | APPGEN2G         | 13.8 | 0.00   | 2          | BC/Ventura       |                              | Retired               | Market       |
| SCE | ZZZZZ_APPGEN_6_UNIT<br>1  | 24361  | APPGEN3G         | 13.8 | 0.00   | 3          | BC/Ventura       |                              | Retired               | Market       |
| SCE | ZZZZZ_GOLETA_6_GAVO<br>TA | 25335  | GOLETA_DIST      | 66   | 0.00   | S1         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | Retired               | Market       |
| SCE | ZZZZZ_GOLETA_6_TAJIG<br>S | 25335  | GOLETA_DIST      | 66   | 0.00   | S1         | BC/Ventura       | S.Clara, Moorpark,<br>Goleta | Retired               | Market       |
| SCE | ZZZZZ_MNDALY_7_UNIT<br>1  | 24089  | MANDLY1G         | 13.8 | 0.00   | 1          | BC/Ventura       | S.Clara, Moorpark            | Retired               | Market       |
| SCE | ZZZZZ_MNDALY_7_UNIT<br>2  | 24090  | MANDLY2G         | 13.8 | 0.00   | 2          | BC/Ventura       | S.Clara, Moorpark            | Retired               | Market       |
| SCE | ZZZZZ_MNDALY_7_UNIT<br>3  | 24222  | MANDLY3G         | 16   | 0.00   | 3          | BC/Ventura       | S.Clara, Moorpark            | Retired               | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID  | BUS # | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments         | CAISO<br>Tag |
|-----|---------------------------|-------|------------------|------|--------|------------|------------------|----------------------------|-------------------------|--------------|
| SCE | ZZZZZ_MOORPK_7_UNIT<br>A1 | 24098 | MOORPARK         | 66   | 0.00   |            | BC/Ventura       | Moorpark                   | Retired                 | Market       |
| SCE | ZZZZZ_PANDOL_6_UNIT       | 24113 | PANDOL           | 13.8 | 0.00   | 1          | BC/Ventura       | Vestal                     | Retired                 | Market       |
| SCE | ZZZZZ_PANDOL_6_UNIT       | 24113 | PANDOL           | 13.8 | 0.00   | 2          | BC/Ventura       | Vestal                     | Retired                 | Market       |
| SCE | ZZZZZ_SAUGUS_2_TOLA<br>ND | 24135 | SAUGUS           | 66   | 0.00   |            | BC/Ventura       |                            | Retired                 | Market       |
| SCE | ZZZZZ_SAUGUS_6_PTCH<br>GN | 24118 | PITCHGEN         | 13.8 | 0.00   | D1         | BC/Ventura       |                            | Retired                 | MUNI         |
| SCE | ZZZZZ_SAUGUS_7_LOPE<br>Z  | 24135 | SAUGUS           | 66   | 0.00   |            | BC/Ventura       |                            | Retired                 | QF/Selfgen   |
| SCE | ZZZZZ_SPRGVL_2_TULE       | 25334 | SPRNGVL_DIS<br>T | 66   | 0.00   | S2         | BC/Ventura       | Rector, Vestal             | Retired                 | Market       |
| SCE | ZZZZZ_VESTAL_6_ULTRG<br>N | 24150 | ULTRAGEN         | 13.8 | 0.00   | 1          | BC/Ventura       | Vestal                     | Retired                 | QF/Selfgen   |
| SCE | ALAMIT_2_PL1X3            | 24575 | ALMT CTG1        | 18   | 211.52 | G1         | LA Basin         | Western                    |                         | Market       |
| SCE | ALAMIT_2_PL1X3            | 24576 | ALMT CTG2        | 18   | 211.52 | G2         | LA Basin         | Western                    |                         | Market       |
| SCE | ALAMIT_2_PL1X3            | 24577 | ALMT STG         | 18   | 251.66 | S1         | LA Basin         | Western                    |                         | Market       |
| SCE | ALAMIT_7_ES1              | 25523 | ALMITOS<br>B1 G  | 0.65 | 100.00 | 1          | LA Basin         | Western                    |                         | Battery      |
| SCE | ALAMIT_7_UNIT 3           | 24003 | ALAMT3 G         | 18   | 0.00   | 3          | LA Basin         | Western                    | Strategic<br>Reserve    | Market       |
| SCE | ALAMIT_7_UNIT 4           | 24004 | ALAMT4 G         | 18   | 0.00   | 4          | LA Basin         | Western                    | Strategic<br>Reserve    | Market       |
| SCE | ALAMIT_7_UNIT 5           | 24005 | ALAMT5 G         | 20   | 0.00   | 5          | LA Basin         | Western                    | Strategic<br>Reserve    | Market       |
| SCE | ALTWD_2_AT3WD3            | 29077 | ALTWNDGEN2       | 0.6  | 1.07   | 1          | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                 | Wind         |
| SCE | ALTWD_2_COAWD1            | 29075 | ALTWNDGEN1       | 0.65 | 5.49   | 1          | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                 | Wind         |
| SCE | ANAHM_2_CANYN1            | 25211 | CanyonGT 1       | 13.8 | 49.21  | 1          | LA Basin         | Western                    | Could retire<br>by 2039 | MUNI         |
| SCE | ANAHM_2_CANYN2            | 25212 | CanyonGT 2       | 13.8 | 48.04  | 2          | LA Basin         | Western                    | Could retire<br>by 2039 | MUNI         |
| SCE | ANAHM_2_CANYN3            | 25213 | CanyonGT 3       | 13.8 | 46.49  | 3          | LA Basin         | Western                    | Could retire<br>by 2039 | MUNI         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME   | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments                     | CAISO<br>Tag |
|-----|--------------------------|--------|------------|------|-------|------------|------------------|----------------------------|-------------------------------------|--------------|
| SCE | ANAHM_2_CANYN4           | 25214  | CanyonGT 4 | 13.8 | 49.80 | 4          | LA Basin         | Western                    | Could retire<br>by 2039             | MUNI         |
| SCE | ARCOGN_2_UNITS           | 24163  | ARCO 5G    | 13.8 | 30.50 | 5          | LA Basin         | Western                    | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| SCE | ARCOGN_2_UNITS           | 24164  | ARCO 6G    | 13.8 | 30.50 | 6          | LA Basin         | Western                    | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| SCE | ARCOGN_2_UNITS           | 24011  | ARCO 1G    | 13.8 | 61.00 | 1          | LA Basin         | Western                    | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| SCE | ARCOGN_2_UNITS           | 24012  | ARCO 2G    | 13.8 | 61.00 | 2          | LA Basin         | Western                    | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| SCE | ARCOGN_2_UNITS           | 24013  | ARCO 3G    | 13.8 | 61.00 | 3          | LA Basin         | Western                    | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| SCE | ARCOGN_2_UNITS           | 24014  | ARCO 4G    | 13.8 | 61.00 | 4          | LA Basin         | Western                    | Could retire<br>by 2039. Aug<br>NQC | Net Seller   |
| SCE | BARRE_2_ALASB1           |        |            |      | 5.96  |            | LA Basin         | Western                    | Not modeled                         | Hybrid       |
| SCE | BARRE_2_QF               |        |            |      | 0.00  |            | LA Basin         | Western                    | Not modeled                         | QF/Selfgen   |
| SCE | BARRE_6_PEAKE            | 29309  | BARPKGEN   | 13.8 | 49.00 | 1          | LA Basin         | Western                    | Could retire<br>by 2039             | Market       |
| SCE | BLAST_1_WIND             | 29049  | BLAST_G    | 0.6  | 5.33  | 1          | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                             | Wind         |
| SCE | BUCKWD_1_NPALM1          | 240150 | DEVERS FC  | 12.5 | 0.30  | PV         | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                             | Solar        |
| SCE | BUCKWD_1_QF              | 25634  | BUCKWIND   | 115  | 1.80  | QF         | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                             | QF/Selfgen   |
| SCE | BUCKWD_7_WINTCV          | 25634  | BUCKWIND   | 115  | 0.14  | W5         | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                             | Wind         |
| SCE | CABZON_1_WINDA1          | 29290  | CABAZON    | 33   | 4.46  | 1          | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                             | Wind         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME   | NQC<br>Comments                                  | CAISO<br>Tag |
|-----|--------------------------|-------|------------------|------|-------|------------|------------------|------------------------|--|--------------|
| SCE | CAPWD_1_QF               | 25633 | CAPWIND          | 115  | 2.13  | QF         | LA Basin         | Eastern, Valley-Devers | Aug NQC  | QF/Selfgen   |
| SCE | CENTER_2_RHONDO          | 25810 | CENTER<br>EQFD   | 12.5 | 0.00  | EQ         | LA Basin         | Western                |  | QF/Selfgen   |
| SCE | CENTER_2_SOLAR1          |       |                  |      | 0.00  |            | LA Basin         | Western                | Not modeled<br>Energy Only                       | Solar        |
| SCE | CENTER_2_TECNG1          |       |                  |      | 0.00  |            | LA Basin         | Western                | Not modeled<br>Energy Only                       | Market       |
| SCE | CENTER_6_PEAKEP          | 25187 | WDT1429_BAT<br>T | 0.48 | 0.00  | 1          | LA Basin         | Western                | Could retire<br>by 2039.<br>Start-<br>up/Back-up | Battery      |
| SCE | CENTER_6_PEAKEP          | 29308 | CTRPGEN          | 13.8 | 47.30 | 1          | LA Basin         | Western                | Could retire<br>by 2039                          | Market       |
| SCE | CENTRY_6_PL1X4           | 25302 | CLTNCTRY         | 13.8 | 0.00  | 1          | LA Basin         | Eastern                | Could retire<br>by 2034. Aug<br>NQC              | MUNI         |
| SCE | CHEVMN_2_UNITS           | 29009 | CHEVGEN 5        | 13.8 | 0.00  | 2          | LA Basin         | Western, El Nido       | Could retire<br>by 2034. Aug<br>NQC              | Net Seller   |
| SCE | CHEVMN_2_UNITS           | 24022 | CHEVGEN 1        | 13.8 | 0.00  | 1          | LA Basin         | Western, El Nido       | Could retire<br>by 2034. Aug<br>NQC              | Net Seller   |
| SCE | CHEVMN_2_UNITS           | 24023 | CHEVGEN 2        | 13.8 | 0.00  | 2          | LA Basin         | Western, El Nido       | Could retire<br>by 2034. Aug<br>NQC              | Net Seller   |
| SCE | CHEVMN_2_UNITS           | 29009 | CHEVGEN 5        | 13.8 | 0.00  | 1          | LA Basin         | Western, El Nido       | Could retire<br>by 2034. Aug<br>NQC              | Net Seller   |
| SCE | CHINO_2_APEBT1           | 25180 | WDT1445BES<br>S  | 0.48 | 20.00 | 1          | LA Basin         | Eastern                | Aug NQC  | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME       | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments                     | CAISO<br>Tag |
|-----|--------------------------|-------|----------------|------|-------|------------|------------------|----------------------|-------------------------------------|--------------|
| SCE | CHINO_2_JURUPA           | 25812 | CHINO EQFC     | 12.5 | 0.00  | SY         | LA Basin         | Eastern              | Not modeled<br>Energy Only          | Market       |
| SCE | CHINO_2_PESBT1           | 25812 | CHINO EQFC     | 12.5 | 10.00 | BT         | LA Basin         | Eastern              | Aug NQC                             | Battery      |
| SCE | CHINO_2_QF               | 25812 | CHINO EQFC     | 12.5 | 0.00  | EQ         | LA Basin         | Eastern              | Aug NQC                             | QF/Selfgen   |
| SCE | CHINO_2_SASOLR           | 25812 | CHINO EQFC     | 12.5 | 0.00  | PV         | LA Basin         | Eastern              | Energy Only                         | Solar        |
| SCE | CHINO_2_SOLAR2           | 25812 | CHINO EQFC     | 12.5 | 0.00  | PV         | LA Basin         | Eastern              | Energy Only                         | Solar        |
| SCE | CHINO_6_CIMGEN           | 24026 | CIMGEN         | 13.8 | 26.00 | D1         | LA Basin         | Eastern              | Aug NQC                             | QF/Selfgen   |
| SCE | COLTON_6_AGUAM1          | 25303 | CLTNAGUA       | 13.8 | 43.00 | 1          | LA Basin         | Eastern              | Could retire<br>by 2039. Aug<br>NQC | MUNI         |
| SCE | CORONS_2_SOLAR           |       |                |      | 0.00  |            | LA Basin         | Eastern              | Not modeled<br>Energy Only          | Solar        |
| SCE | CORONS_6_CLRWTR          | 29340 | CLRWTRST       | 13.8 | 0.00  | S1         | LA Basin         | Eastern              | Could retire<br>by 2034             | MUNI         |
| SCE | CORONS_6_CLRWTR          | 29338 | CLRWTRCT       | 13.8 | 0.00  | G1         | LA Basin         | Eastern              | Could retire<br>by 2034             | MUNI         |
| SCE | DELAMO_2_ALASB2          |       |                |      | 5.96  |            | LA Basin         | Western              | Not modeled                         | Hybrid       |
| SCE | DELAMO_2_SOLAR1          | 25818 | DELAMO<br>EQFD | 12.5 | 0.19  | EQ         | LA Basin         | Western              | Aug NQC                             | Solar        |
| SCE | DELAMO_2_SOLAR2          | 25818 | DELAMO<br>EQFD | 12.5 | 0.22  | EQ         | LA Basin         | Western              | Aug NQC                             | Solar        |
| SCE | DELAMO_2_SOLAR3          | 25818 | DELAMO<br>EQFD | 12.5 | 0.16  | EQ         | LA Basin         | Western              | Aug NQC                             | Solar        |
| SCE | DELAMO_2_SOLAR4          | 25818 | DELAMO<br>EQFD | 12.5 | 0.16  | EQ         | LA Basin         | Western              | Aug NQC                             | Solar        |
| SCE | DELAMO_2_SOLAR5          | 25818 | DELAMO<br>EQFD | 12.5 | 0.12  | EQ         | LA Basin         | Western              | Aug NQC                             | Solar        |
| SCE | DELAMO_2_SOLAR6          | 25818 | DELAMO<br>EQFD | 12.5 | 0.25  | EQ         | LA Basin         | Western              | Aug NQC                             | Solar        |
| SCE | DELAMO_2_SOLRC1          |       |                |      | 0.00  |            | LA Basin         | Western              | Not modeled<br>Energy Only          | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME  | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments                     | CAISO<br>Tag |
|-----|--------------------------|--------|-----------|------|-------|------------|------------------|----------------------------|-------------------------------------|--------------|
| SCE | DEAMO_2_SOLRD            |        |           |      | 0.00  |            | LA Basin         | Western                    | Not modeled<br>Energy Only          | Solar        |
| SCE | DEVERS_1_SEPV05          |        |           |      | 0.00  |            | LA Basin         | Eastern, Valley-<br>Devers | Not modeled<br>Energy Only          | Solar        |
| SCE | DEVERS_1_SOLAR           |        |           |      | 0.00  |            | LA Basin         | Eastern, Valley-<br>Devers | Not modeled<br>Energy Only          | Solar        |
| SCE | DEVERS_1_SOLAR1          |        |           |      | 0.00  |            | LA Basin         | Eastern, Valley-<br>Devers | Not modeled<br>Energy Only          | Solar        |
| SCE | DEVERS_1_SOLAR2          |        |           |      | 0.00  |            | LA Basin         | Eastern, Valley-<br>Devers | Not modeled<br>Energy Only          | Solar        |
| SCE | DEVERS_2_CS2SR4          |        |           |      | 0.00  |            | LA Basin         | Eastern, Valley-<br>Devers | Not modeled<br>Energy Only          | Solar        |
| SCE | DEVERS_2_DHSPG2          | 240150 | DEVERS FC | 12.5 | 0.00  | T          | LA Basin         | Eastern, Valley-<br>Devers | Energy Only                         | Market       |
| SCE | DMDVLY_1_UNITS           | 25424  | ESRP P1   | 6.9  | 0.07  | 2          | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25424  | ESRP P1   | 6.9  | 0.07  | 3          | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25424  | ESRP P1   | 6.9  | 0.07  | 4          | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25425  | ESRP P2   | 6.9  | 0.07  | 6          | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25425  | ESRP P2   | 6.9  | 0.07  | 7          | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25425  | ESRP P2   | 6.9  | 0.07  | 8          | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25426  | ESRP P3   | 6.9  | 0.07  | 10         | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25425  | ESRP P3   | 6.9  | 0.07  | 11         | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DMDVLY_1_UNITS           | 25425  | ESRP P3   | 6.9  | 0.07  | 12         | LA Basin         | Eastern                    | Aug NQC                             | QF/Selfgen   |
| SCE | DREWS_6_PL1X4            | 25301  | CLTNDREW  | 13.8 | 0.00  | 1          | LA Basin         | Eastern                    | Could retire<br>by 2034. Aug<br>NQC | MUNI         |
| SCE | DVLCYN_1_UNITS           | 25648  | DVLCYN1G  | 13.8 | 30.02 | 1          | LA Basin         | Eastern                    | Aug NQC                             | MUNI         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments                                  | CAISO<br>Tag |
|-----|--------------------------|-------|------------------|------|--------|------------|------------------|----------------------------|--|--------------|
| SCE | DVLCYN_1_UNITS           | 25649 | DVLCYN2G         | 13.8 | 30.02  | 2          | LA Basin         | Eastern                    | Aug NQC  | MUNI         |
| SCE | DVLCYN_1_UNITS           | 25603 | DVLCYN3G         | 13.8 | 40.03  | 3          | LA Basin         | Eastern                    | Aug NQC  | MUNI         |
| SCE | DVLCYN_1_UNITS           | 25604 | DVLCYN4G         | 13.8 | 40.03  | 4          | LA Basin         | Eastern                    | Aug NQC  | MUNI         |
| SCE | ELLIS_2_QF               | 24325 | ORCOGEN          | 13.8 | 0.76   | 1          | LA Basin         | Western                    | Aug NQC  | QF/Selfgen   |
| SCE | ELSEGN_2_UN1011          | 29904 | ELSEG5GT         | 16.5 | 137.16 | 5          | LA Basin         | Western, El Nido           | Aug NQC  | Market       |
| SCE | ELSEGN_2_UN1011          | 29903 | ELSEG6ST         | 13.8 | 137.16 | 6          | LA Basin         | Western, El Nido           | Aug NQC  | Market       |
| SCE | ELSEGN_2_UN2021          | 29902 | ELSEG7GT         | 16.5 | 135.87 | 7          | LA Basin         | Western, El Nido           | Aug NQC  | Market       |
| SCE | ELSEGN_2_UN2021          | 29901 | ELSEG8ST         | 13.8 | 135.87 | 8          | LA Basin         | Western, El Nido           | Aug NQC  | Market       |
| SCE | ESNHWR_2_WC1BT1          | 25632 | EISNHOW<br>EQFD  | 12.5 | 1.50   | EQ         | LA Basin         | Eastern, Valley-<br>Devers |  | Battery      |
| SCE | ETIWND_2_CHMPNE          |       |                  |      | 0.00   |            | LA Basin         | Eastern                    | Not modeled<br>Energy Only                       | Market       |
| SCE | ETIWND_2_FONTNA          | 25822 | ETIWANDA<br>EQFD | 12.5 | 0.38   | EQ         | LA Basin         | Eastern                    | Aug NQC  | QF/Selfgen   |
| SCE | ETIWND_2_SOLAR1          | 25822 | ETIWANDA<br>EQFD | 12.5 | 0.12   | EQ         | LA Basin         | Eastern                    | Aug NQC  | Solar        |
| SCE | ETIWND_2_SOLAR2          |       |                  |      | 0.00   |            | LA Basin         | Eastern                    | Not modeled<br>Energy Only                       | Solar        |
| SCE | ETIWND_2_SOLAR5          |       |                  |      | 0.00   |            | LA Basin         | Eastern                    | Not modeled<br>Energy Only                       | Solar        |
| SCE | ETIWND_2_UNIT1           | 24071 | INLAND           | 13.8 | 33.60  | 1          | LA Basin         | Eastern                    | Aug NQC  | QF/Selfgen   |
| SCE | ETIWND_6_GRPLND          | 25188 | WDT1430_BES<br>S | 13.8 | 0.00   | 1          | LA Basin         | Eastern                    | Could retire<br>by 2039.<br>Start-<br>up/Back-up | Battery      |
| SCE | ETIWND_6_GRPLND          | 29305 | ETWPKGEN         | 13.8 | 45.64  | 1          | LA Basin         | Eastern                    | Could retire<br>by 2039                          | Market       |
| SCE | ETIWND_6_MWDETI          | 25422 | ETI MWDG         | 13.8 | 0.00   | 1          | LA Basin         | Eastern                    | Aug NQC  | Market       |
| SCE | GARNET_1_SOLAR           |       |                  |      | 0.00   |            | LA Basin         | Eastern, Valley-<br>Devers | Not modeled<br>Energy Only                       | Solar        |
| SCE | GARNET_1_SOLAR2          | 25827 | GARNET FD        | 34.5 | 0.50   | EQ         | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC  | Solar        |
| SCE | GARNET_1_WIND            | 24815 | GARNET           | 115  | 0.71   | W3         | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC  | Wind         |
| SCE | GARNET_1_WINDS           | 24815 | GARNET           | 115  | 2.45   | W2         | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC  | Wind         |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME   | NQC<br>Comments            | CAISO<br>Tag |
|-----|--------------------------|--------|-----------------|------|-------|------------|------------------|------------------------|----------------------------|--------------|
| SCE | GARNET_1_WT3WIND         |        |                 |      | 0.00  |            | LA Basin         | Eastern, Valley-Devers | Not modeled<br>Energy Only | Market       |
| SCE | GARNET_2_COAWD2          | 24815  | GARNET          | 115  | 1.18  | QF         | LA Basin         | Eastern, Valley-Devers | Aug NQC                    | Wind         |
| SCE | GARNET_2_HYDRO           | 24815  | GARNET          | 115  | 0.00  | PC         | LA Basin         | Eastern, Valley-Devers | Aug NQC                    | Market       |
| SCE | GARNET_2_WIND1           | 240526 | WDT1131QFC      | 0.21 | 1.22  | W1         | LA Basin         | Eastern, Valley-Devers | Aug NQC                    | Wind         |
| SCE | GARNET_2_WIND2           | 240528 | WDT1080QFC      | 0.21 | 1.27  | W3         | LA Basin         | Eastern, Valley-Devers | Aug NQC                    | Wind         |
| SCE | GARNET_2_WIND3           | 24815  | GARNET          | 115  | 1.37  | QF         | LA Basin         | Eastern, Valley-Devers | Aug NQC                    | Wind         |
| SCE | GARNET_2_WIND4           | 24815  | GARNET          | 115  | 1.07  | QF         | LA Basin         | Eastern, Valley-Devers | Aug NQC                    | Wind         |
| SCE | GARNET_2_WIND5           | 24815  | GARNET          | 115  | 0.33  | QF         | LA Basin         | Eastern, Valley-Devers | Aug NQC                    | Wind         |
| SCE | GLNARM_2_UNIT 5          | 29014  | GLENARM5_S<br>T | 13.8 | 15.00 | ST         | LA Basin         | Western                |                            | MUNI         |
| SCE | GLNARM_2_UNIT 5          | 29013  | GLENARM5_C<br>T | 13.8 | 50.00 | CT         | LA Basin         | Western                |                            | MUNI         |
| SCE | GLNARM_7_UNIT 1          | 29005  | PASADNA1        | 13.8 | 22.13 | 1          | LA Basin         | Western                | Could retire<br>by 2039    | MUNI         |
| SCE | GLNARM_7_UNIT 2          | 29006  | PASADNA2        | 13.8 | 22.38 | 1          | LA Basin         | Western                | Could retire<br>by 2039    | MUNI         |
| SCE | GLNARM_7_UNIT 3          | 25042  | PASADNA3        | 13.8 | 44.83 | 1          | LA Basin         | Western                | Could retire<br>by 2039    | MUNI         |
| SCE | GLNARM_7_UNIT 4          | 25043  | PASADNA4        | 13.8 | 42.42 | 1          | LA Basin         | Western                | Could retire<br>by 2039    | MUNI         |
| SCE | HARBGN_7_UNITS           | 24062  | HARBOR G        | 13.8 | 11.86 | HP         | LA Basin         | Western                |                            | Market       |
| SCE | HARBGN_7_UNITS           | 25510  | HARBORG4        | 4.16 | 11.86 | LP         | LA Basin         | Western                |                            | Market       |
| SCE | HARBGN_7_UNITS           | 24062  | HARBOR G        | 13.8 | 76.27 | 1          | LA Basin         | Western                |                            | Market       |
| SCE | HINSON_6_LBECH1          | 24170  | LBEACH12        | 13.8 | 63.00 | 1          | LA Basin         | Western                | Could retire<br>by 2039    | Market       |
| SCE | HINSON_6_LBECH2          | 24170  | LBEACH12        | 13.8 | 63.00 | 2          | LA Basin         | Western                | Could retire<br>by 2039    | Market       |
| SCE | HINSON_6_LBECH3          | 24171  | LBEACH34        | 13.8 | 63.00 | 3          | LA Basin         | Western                | Could retire<br>by 2039    | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments         | CAISO<br>Tag |
|-----|--------------------------|--------|------------------|------|--------|------------|------------------|----------------------------|-------------------------|--------------|
| SCE | HINSON_6_LBECH4          | 24171  | LBEACH34         | 13.8 | 63.00  | 4          | LA Basin         | Western                    | Could retire<br>by 2039 | Market       |
| SCE | HINSON_6_SERRGN          | 24139  | SERRFGEN         | 13.8 | 34.00  | D1         | LA Basin         | Western                    | Aug NQC                 | Market       |
| SCE | HNTGBH_2_PL1X3           | 24580  | HUNTBCH<br>CTG1  | 18   | 211.23 | G1         | LA Basin         | Western                    |                         | Market       |
| SCE | HNTGBH_2_PL1X3           | 24581  | HUNTBCH<br>CTG2  | 18   | 211.23 | G2         | LA Basin         | Western                    |                         | Market       |
| SCE | HNTGBH_2_PL1X3           | 24582  | HUNTBCH<br>STG   | 18   | 251.34 | S1         | LA Basin         | Western                    |                         | Market       |
| SCE | HNTGBH_7_UNIT 2          | 24067  | HUNT2 G          | 13.8 | 0.00   | 2          | LA Basin         | Western                    | Strategic<br>Reserve    | Market       |
| SCE | INDIGO_1_UNIT 1          | 29190  | INDIGO G4        | 13.8 | 45.30  | 4          | LA Basin         | Eastern, Valley-<br>Devers | Could retire<br>by 2039 | Market       |
| SCE | INDIGO_1_UNIT 2          | 29191  | INDIGO G5        | 13.8 | 45.30  | 5          | LA Basin         | Eastern, Valley-<br>Devers | Could retire<br>by 2039 | Market       |
| SCE | INDIGO_1_UNIT 3          | 29180  | INDIGO G3        | 13.8 | 45.30  | 3          | LA Basin         | Eastern, Valley-<br>Devers | Could retire<br>by 2039 | Market       |
| SCE | JOANEC_2_ST3BT3          | 102869 | SNTANS3G         | 0.55 | 40.00  | 3          | LA Basin         | Western                    |                         | Battery      |
| SCE | JOANEC_2_STABT1          | 102867 | SNTANS3G1        | 0.55 | 20.00  | 1          | LA Basin         | Western                    |                         | Battery      |
| SCE | JOANEC_2_STABT2          | 102868 | SNTANS3G2        | 0.55 | 20.00  | 2          | LA Basin         | Western                    |                         | Battery      |
| SCE | JOHANN_2_JOSBT1          | 240501 | WDT1392          | 0.48 | 10.00  | 1          | LA Basin         | Western                    |                         | Battery      |
| SCE | JOHANN_2_JOSBT2          | 240502 | WDT1393          | 0.48 | 10.00  | 1          | LA Basin         | Western                    |                         | Battery      |
| SCE | JOHANN_2_OCEBT2          | 240500 | JOHANNA FD       | 12.5 | 9.00   | EQ         | LA Basin         | Western                    |                         | Battery      |
| SCE | JOHANN_2_OCEBT3          | 240500 | JOHANNA FD       | 12.5 | 6.00   | EQ         | LA Basin         | Western                    |                         | Battery      |
| SCE | LACIEN_2_VENICE          | 24337  | VENICE           | 13.8 | 0.00   | 1          | LA Basin         | Western, El Nido           | Aug NQC                 | MUNI         |
| SCE | LGHTHP_6_ICEGEN          | 24070  | ICEGEN           | 13.8 | 10.20  | ST         | LA Basin         | Western                    | Aug NQC                 | QF/Selfgen   |
| SCE | LGHTHP_6_ICEGEN          | 24070  | ICEGEN           | 13.8 | 37.80  | GT         | LA Basin         | Western                    | Aug NQC                 | QF/Selfgen   |
| SCE | MARVEL_2_MARBT3          | 25239  | MARVEL_ES3       | 34.5 | 74.93  | 1          | LA Basin         | Eastern, Valley-<br>Devers |                         | Battery      |
| SCE | MARVEL_2_MARBX2          | 25231  | MARVEL_ES1       | 34.5 | 162.50 | 1          | LA Basin         | Eastern, Valley-<br>Devers |                         | Battery      |
| SCE | MARVEL_2_MARBX2          | 25235  | MARVEL_ES2       | 34.5 | 162.50 | 1          | LA Basin         | Eastern, Valley-<br>Devers |                         | Battery      |
| SCE | MIRLOM_2_CORONA          | 25844  | MIRALOMA<br>EQFD | 12.5 | 0.64   | EQ         | LA Basin         | Eastern                    | Aug NQC                 | QF/Selfgen   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments            | CAISO<br>Tag |
|-----|--------------------------|-------|------------------|------|-------|------------|------------------|----------------------------|----------------------------|--------------|
| SCE | MIRLOM_2_CREST           | 25844 | MIRALOMA<br>EQFD | 12.5 | 0.00  | EQ         | LA Basin         | Eastern                    | Aug NQC                    | Market       |
| SCE | MIRLOM_2_LNDFL           | 25844 | MIRALOMA<br>EQFD | 12.5 | 0.37  | EQ         | LA Basin         | Eastern                    | Aug NQC                    | Market       |
| SCE | MIRLOM_2_MLBBTA          | 25185 | WDT1425_G1       | 0.48 | 10.00 | 1          | LA Basin         | Eastern                    | Aug NQC                    | Battery      |
| SCE | MIRLOM_2_MLBBTB          | 25186 | WDT1426_G2       | 0.48 | 10.00 | 1          | LA Basin         | Eastern                    | Aug NQC                    | Battery      |
| SCE | MIRLOM_2_TEMESC          | 25844 | MIRALOMA<br>EQFD | 12.5 | 0.77  | EQ         | LA Basin         | Eastern                    | Aug NQC                    | QF/Selfgen   |
| SCE | MIRLOM_6_PEAKEER         | 29307 | MRLPKGEN         | 13.8 | 47.18 | 1          | LA Basin         | Eastern                    | Could retire<br>by 2039    | Market       |
| SCE | MIRLOM_7_MWDLKM          | 24210 | MIRALOMA         | 66   | 3.60  |            | LA Basin         | Eastern                    | Not modeled<br>Aug NQC     | MUNI         |
| SCE | MOJAVE_1_SIPHON          | 25657 | MJVSPHN1         | 13.8 | 3.28  | 1          | LA Basin         | Eastern                    | Aug NQC                    | Market       |
| SCE | MOJAVE_1_SIPHON          | 25657 | MJVSPHN1         | 13.8 | 3.28  | 2          | LA Basin         | Eastern                    | Aug NQC                    | Market       |
| SCE | MOJAVE_1_SIPHON          | 25657 | MJVSPHN1         | 13.8 | 3.28  | 3          | LA Basin         | Eastern                    | Aug NQC                    | Market       |
| SCE | MTWIND_1_MVPWD1          | 29064 | MOUNTWND_<br>1G  | 0.6  | 7.25  | 1          | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                    | Wind         |
| SCE | MTWIND_1_UNIT 3          | 29069 | MOUNTWND_<br>3G  | 0.6  | 2.44  | 1          | LA Basin         | Eastern, Valley-<br>Devers | Aug NQC                    | Wind         |
| SCE | OLINDA_2_COYCRK          |       |                  |      | 0.00  |            | LA Basin         | Western                    | Not modeled                | QF/Selfgen   |
| SCE | OLINDA_2_LNDFL2          | 29011 | BREAPWR2         | 13.8 | 4.32  | C1         | LA Basin         | Western                    | Aug NQC                    | Market       |
| SCE | OLINDA_2_LNDFL2          | 29011 | BREAPWR2         | 13.8 | 4.32  | C2         | LA Basin         | Western                    | Aug NQC                    | Market       |
| SCE | OLINDA_2_LNDFL2          | 29011 | BREAPWR2         | 13.8 | 4.32  | C3         | LA Basin         | Western                    | Aug NQC                    | Market       |
| SCE | OLINDA_2_LNDFL2          | 29011 | BREAPWR2         | 13.8 | 4.32  | C4         | LA Basin         | Western                    | Aug NQC                    | Market       |
| SCE | OLINDA_2_LNDFL2          | 29011 | BREAPWR2         | 13.8 | 7.72  | S1         | LA Basin         | Western                    | Aug NQC                    | Market       |
| SCE | OLINDA_7_BLKSDND         |       |                  |      | 0.25  |            | LA Basin         | Western                    | Not modeled<br>Aug NQC     | Market       |
| SCE | PADUA_2_ONTARO           | 25851 | PADUA EQFC       | 12.5 | 0.64  | EQ         | LA Basin         | Eastern                    | Aug NQC                    | QF/Selfgen   |
| SCE | PADUA_2_SOLAR1           |       |                  |      | 0.00  |            | LA Basin         | Eastern                    | Not modeled<br>Energy Only | Solar        |
| SCE | PADUA_6_MWSDSM           | 25851 | PADUA EQFC       | 12.5 | 0.80  | HY         | LA Basin         | Eastern                    | Aug NQC                    | MUNI         |
| SCE | PADUA_6_QF               | 25851 | PADUA EQFC       | 12.5 | 0.34  | T          | LA Basin         | Eastern                    | Aug NQC                    | QF/Selfgen   |
| SCE | PADUA_7_SDIMAS           | 25851 | PADUA EQFC       | 12.5 | 1.05  | EQ         | LA Basin         | Eastern                    | Aug NQC                    | Market       |
| SCE | PWEST_1_UNIT             | 24815 | GARNET           | 115  | 0.23  | PC         | LA Basin         | Western                    | Aug NQC                    | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME    | NQC<br>Comments      | CAISO<br>Tag |
|-----|--------------------------|--------|-----------------|------|--------|------------|------------------|-------------------------|----------------------|--------------|
| SCE | RENWD_1_QF               | 25636  | RENWIND         | 115  | 0.55   | Q1         | LA Basin         | Eastern, Valley-Devers  | Aug NQC              | QF/Selfgen   |
| SCE | RENWD_1_QF               | 25636  | RENWIND         | 115  | 0.55   | Q2         | LA Basin         | Eastern, Valley-Devers  | Aug NQC              | QF/Selfgen   |
| SCE | RVSIDE_2_RERCU3          | 24299  | RERC2G3         | 13.8 | 49.00  | 1          | LA Basin         | Eastern                 | Could retire by 2039 | MUNI         |
| SCE | RVSIDE_2_RERCU4          | 24300  | RERC2G4         | 13.8 | 49.00  | 1          | LA Basin         | Eastern                 | Could retire by 2039 | MUNI         |
| SCE | RVSIDE_6_RERCU1          | 24242  | RERC1G          | 13.8 | 48.35  | 1          | LA Basin         | Eastern                 | Could retire by 2039 | MUNI         |
| SCE | RVSIDE_6_RERCU2          | 24243  | RERC2G          | 13.8 | 48.50  | 1          | LA Basin         | Eastern                 | Could retire by 2039 | MUNI         |
| SCE | RVSIDE_6_SOLAR1          |        |                 |      | 0.93   |            | LA Basin         | Eastern                 | Not modeled Aug NQC  | Solar        |
| SCE | RVSIDE_6_SPRING          | 24240  | SPRINGS1        | 13.8 | 9.00   | 1          | LA Basin         | Eastern                 |                      | Market       |
| SCE | RVSIDE_6_SPRING          | 24241  | SPRINGS3        | 13.8 | 9.00   | 1          | LA Basin         | Eastern                 |                      | Market       |
| SCE | RVSIDE_6_SPRING          | 24240  | SPRINGS1        | 13.8 | 9.00   | 2          | LA Basin         | Eastern                 |                      | Market       |
| SCE | RVSIDE_6_SPRING          | 24241  | SPRINGS3        | 13.8 | 9.00   | 2          | LA Basin         | Eastern                 |                      | Market       |
| SCE | SANITR_6_UNITS           | 24324  | SANIGEN         | 13.8 | 1.11   | D1         | LA Basin         | Eastern                 | Aug NQC              | QF/Selfgen   |
| SCE | SANTGO_2_LNDFL1          | 24341  | COYGEN          | 13.8 | 18.64  | 1          | LA Basin         | Western                 | Aug NQC              | Market       |
| SCE | SANTGO_2_MABBT1          | 240509 | SANTIAGO<br>EQF | 12.5 | 2.00   | BS         | LA Basin         | Western                 | Aug NQC              | Battery      |
| SCE | SANWD_1_QF               | 29072  | SANWIND_G       | 0.48 | 3.37   | 1          | LA Basin         | Eastern, Valley-Devers  | Aug NQC              | Wind         |
| SCE | SBERDO_2_PSP3            | 24921  | MNTV-G3A        | 18   | 148.59 | 1          | LA Basin         | Eastern, West of Devers | Could retire by 2039 | Market       |
| SCE | SBERDO_2_PSP3            | 24922  | MNTV-G3B        | 18   | 148.59 | 1          | LA Basin         | Eastern, West of Devers | Could retire by 2039 | Market       |
| SCE | SBERDO_2_PSP3            | 24923  | MNTV-ST3        | 18   | 257.82 | 1          | LA Basin         | Eastern, West of Devers | Could retire by 2039 | Market       |
| SCE | SBERDO_2_PSP4            | 24924  | MNTV-G4A        | 18   | 0.00   | 1          | LA Basin         | Eastern, West of Devers | Could retire by 2034 | Market       |
| SCE | SBERDO_2_PSP4            | 24925  | MNTV-G4B        | 18   | 0.00   | 1          | LA Basin         | Eastern, West of Devers | Could retire by 2034 | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME              | NQC<br>Comments         | CAISO<br>Tag |
|-----|--------------------------|-------|-----------------|------|--------|------------|------------------|-----------------------------------|-------------------------|--------------|
| SCE | SBERDO_2_PSP4            | 24926 | MNTV-ST4        | 18   | 0.00   | 1          | LA Basin         | Eastern, West of<br>Devers        | Could retire<br>by 2034 | Market       |
| SCE | SBERDO_2_SNTANA          | 25861 | SNBRDNO FD      | 12.5 | 0.00   | EQ         | LA Basin         | Eastern, West of<br>Devers        | Aug NQC                 | QF/Selfgen   |
| SCE | SBERDO_6_MILLCK          | 25861 | SNBRDNO FD      | 12.5 | 0.57   | EQ         | LA Basin         | Eastern, West of<br>Devers        | Aug NQC                 | QF/Selfgen   |
| SCE | SENTNL_2_CTG1            | 29101 | SENTINEL_G1     | 13.8 | 107.68 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | SENTNL_2_CTG2            | 29102 | SENTINEL_G2     | 13.8 | 103.98 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | SENTNL_2_CTG3            | 29103 | SENTINEL_G3     | 13.8 | 105.69 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | SENTNL_2_CTG4            | 29104 | SENTINEL_G4     | 13.8 | 106.55 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | SENTNL_2_CTG5            | 29105 | SENTINEL_G5     | 13.8 | 107.52 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | SENTNL_2_CTG6            | 29106 | SENTINEL_G6     | 13.8 | 105.00 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | SENTNL_2_CTG7            | 29107 | SENTINEL_G7     | 13.8 | 106.73 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | SENTNL_2_CTG8            | 29108 | SENTINEL_G8     | 13.8 | 106.85 | 1          | LA Basin         | Eastern, Valley-<br>Devers        |                         | Market       |
| SCE | STANTN_2_SBEBX2          | 25675 | WH_STN_5        | 0.55 | 34.40  | 1          | LA Basin         | Western                           |                         | Battery      |
| SCE | STANTN_2_SBEBX2          | 25677 | WH_STN_7        | 0.55 | 34.40  | 1          | LA Basin         | Western                           |                         | Battery      |
| SCE | STANTN_2_STAGT1          | 25670 | WH_STN_1        | 13.8 | 49.65  | 1          | LA Basin         | Western                           |                         | Market       |
| SCE | STANTN_2_STAGT2          | 25671 | WH_STN_2        | 13.8 | 49.65  | 1          | LA Basin         | Western                           |                         | Market       |
| SCE | TIFFNY_1_DILLON          | 29021 | WINTEC6         | 115  | 4.90   | 1          | LA Basin         | Eastern, Valley-<br>Devers        | Aug NQC                 | Wind         |
| SCE | TRNSWD_1_QF              | 25746 | TRANWND_1G      | 0.4  | 2.12   | QF         | LA Basin         | Eastern, Valley-<br>Devers        | Aug NQC                 | Wind         |
| SCE | TRNSWD_1_QF              | 25749 | TRANWND_2G      | 0.4  | 2.12   | QF         | LA Basin         | Eastern, Valley-<br>Devers        | Aug NQC                 | Wind         |
| SCE | TULEWD_1_TULWD1          |       |                 |      | 14.21  |            | LA Basin         | Eastern, Valley-<br>Devers        | Not modeled<br>Aug NQC  | Wind         |
| SCE | VALLEY_5_PERRIS          | 25872 | VALLEYS<br>EQFD | 12.5 | 2.40   | T          | LA Basin         | Eastern, Valley,<br>Valley-Devers | Aug NQC                 | QF/Selfgen   |
| SCE | VALLEY_5_REDMTN          | 25872 | VALLEYS<br>EQFD | 12.5 | 1.21   | T          | LA Basin         | Eastern, Valley,<br>Valley-Devers | Aug NQC                 | QF/Selfgen   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME              | NQC<br>Comments            | CAISO<br>Tag |
|-----|--------------------------|-------|-----------------|------|-------|------------|------------------|-----------------------------------|----------------------------|--------------|
| SCE | VALLEY_5_SOLAR1          | 25872 | VALLEYS<br>EQFD | 12.5 | 0.00  | PV         | LA Basin         | Eastern, Valley,<br>Valley-Devers | Energy Only                | Solar        |
| SCE | VALLEY_5_SOLAR2          | 25846 | WDT786G         | 34.5 | 2.48  | EQ         | LA Basin         | Eastern, Valley,<br>Valley-Devers | Aug NQC                    | Solar        |
| SCE | VENWD_1_WIND3            | 25645 | VENWIND         | 115  | 4.85  | EU         | LA Basin         | Eastern, Valley-<br>Devers        | Aug NQC                    | Wind         |
| SCE | VERNON_6_GONZL1          |       |                 |      | 5.75  |            | LA Basin         | Western                           | Not modeled                | MUNI         |
| SCE | VERNON_6_GONZL2          |       |                 |      | 5.75  |            | LA Basin         | Western                           | Not modeled                | MUNI         |
| SCE | VERNON_6_MALBRG          | 24239 | MALBRG1G        | 13.8 | 43.95 | C1         | LA Basin         | Western                           |                            | MUNI         |
| SCE | VERNON_6_MALBRG          | 24240 | MALBRG2G        | 13.8 | 43.95 | C2         | LA Basin         | Western                           |                            | MUNI         |
| SCE | VERNON_6_MALBRG          | 24241 | MALBRG3G        | 13.8 | 51.10 | S3         | LA Basin         | Western                           |                            | MUNI         |
| SCE | VILLPK_2_VALLYV          |       |                 |      | 1.20  |            | LA Basin         | Western                           | Not modeled<br>Aug NQC     | QF/Selfgen   |
| SCE | VILLPK_6_MWDYOR          |       |                 |      | 2.40  |            | LA Basin         | Western                           | Not modeled<br>Aug NQC     | MUNI         |
| SCE | VISTA_6_QF               | 25887 | VSTA EQFD       | 12.5 | 0.10  | EQ         | LA Basin         | Eastern                           | Not modeled<br>Aug NQC     | QF/Selfgen   |
| SCE | WALCRK_2_CTG1            | 29201 | WALCRKG1        | 13.8 | 96.43 | 1          | LA Basin         | Western                           |                            | Market       |
| SCE | WALCRK_2_CTG2            | 29202 | WALCRKG2        | 13.8 | 96.91 | 1          | LA Basin         | Western                           |                            | Market       |
| SCE | WALCRK_2_CTG3            | 29203 | WALCRKG3        | 13.8 | 96.65 | 1          | LA Basin         | Western                           |                            | Market       |
| SCE | WALCRK_2_CTG4            | 29204 | WALCRKG4        | 13.8 | 96.49 | 1          | LA Basin         | Western                           |                            | Market       |
| SCE | WALCRK_2_CTG5            | 29205 | WALCRKG5        | 13.8 | 96.65 | 1          | LA Basin         | Western                           |                            | Market       |
| SCE | WALNUT_2_SOLAR           |       |                 |      | 0.00  |            | LA Basin         | Western                           | Not modeled<br>Energy Only | Solar        |
| SCE | WALNUT_6_HILLGEN         |       |                 |      | 21.88 |            | LA Basin         | Western                           | Not modeled<br>Aug NQC     | Net Seller   |
| SCE | WALNUT_7_WCOVST          |       |                 |      | 5.02  |            | LA Basin         | Western                           | Not modeled<br>Aug NQC     | Market       |
| SCE | WHTWTR_1_WINDA1          | 29061 | WHITEWTR        | 33   | 6.69  | 1          | LA Basin         | Eastern, Valley-<br>Devers        | Aug NQC                    | Wind         |
| SCE | ZZ_DEVERS_1_QF           | 25632 | TERAWND         | 115  | 0.00  | QF         | LA Basin         | Eastern, Valley-<br>Devers        | Mothballed                 | QF/Selfgen   |
| SCE | ZZ_DEVERS_1_QF           | 25639 | SEAWIND         | 115  | 0.00  | QF         | LA Basin         | Eastern, Valley-<br>Devers        | Mothballed                 | QF/Selfgen   |
| SCE | ZZ_GARNET_1_UNITS        | 24815 | GARNET          | 115  | 0.00  | QF         | LA Basin         | Eastern, Valley-<br>Devers        | Mothballed                 | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME         | kV   | NQC  | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME   | NQC<br>Comments        | CAISO<br>Tag |
|-----|--------------------------|-------|------------------|------|------|------------|------------------|------------------------|------------------------|--------------|
| SCE | ZZ_GARNET_1_UNITS        | 24815 | GARNET           | 115  | 0.00 | QF         | LA Basin         | Eastern, Valley-Devers | Mothballed             | Market       |
| SCE | ZZ_GARNET_1_UNITS        | 24815 | GARNET           | 115  | 0.00 | QF         | LA Basin         | Eastern, Valley-Devers | Mothballed             | Market       |
| SCE | ZZ_MOBGEN_6_UNIT 1       | 24094 | MOBGEN1          | 13.8 | 0.00 | 1          | LA Basin         | Western, El Nido       | No NQC -<br>hist. data | QF/Selfgen   |
| SCE | ZZ_MOBGEN_6_UNIT 1       | 24094 | MOBGEN2          | 13.8 | 0.00 | 1          | LA Basin         | Western, El Nido       | No NQC -<br>hist. data | QF/Selfgen   |
| SCE | ZZ_MTWIND_1_UNIT 2       | 29066 | MOUNTWIND_<br>2G | 0.6  | 0.00 | 1          | LA Basin         | Eastern, Valley-Devers | Mothballed             | Wind         |
| SCE | ZZ_NA                    | 24327 | THUMSGEN         | 13.8 | 0.00 | 1          | LA Basin         | Western                | No NQC -<br>hist. data | QF/Selfgen   |
| SCE | ZZ_NA                    | 24330 | OUTFALL1         | 13.8 | 0.00 | 1          | LA Basin         | Western, El Nido       | No NQC -<br>hist. data | QF/Selfgen   |
| SCE | ZZ_NA                    | 24331 | OUTFALL2         | 13.8 | 0.00 | 1          | LA Basin         | Western, El Nido       | No NQC -<br>hist. data | QF/Selfgen   |
| SCE | ZZ_NA                    | 29260 | ALTAMSA4         | 115  | 0.00 | 1          | LA Basin         | Eastern, Valley-Devers | No NQC -<br>hist. data | Wind         |
| SCE | ZZ_NA                    | 25838 | LA FRSA<br>EQFD  | 16   | 0.00 | EQ         | LA Basin         | Western                | No NQC -<br>est. data  | Market       |
| SCE | ZZ_NA                    | 25842 | MESACAL<br>EQFD  | 16   | 0.01 | EQ         | LA Basin         | Western                | No NQC -<br>est. data  | Solar        |
| SCE | ZZ_NA                    | 25838 | LA FRSA<br>EQFD  | 16   | 0.07 | PV         | LA Basin         | Western                | No NQC -<br>est. data  | Solar        |
| SCE | ZZ_NA                    | 25820 | EL NIDO EQFD     | 16   | 0.09 | EQ         | LA Basin         | Western, El Nido       | No NQC -<br>est. data  | Solar        |
| SCE | ZZ_NA                    | 25883 | VILLAPK<br>EQFD  | 12.5 | 0.14 | EQ         | LA Basin         | Western                | No NQC -<br>est. data  | Solar        |
| SCE | ZZ_NA                    | 25857 | RIOHNDQ<br>EQFD  | 12.5 | 0.20 | EQ         | LA Basin         | Western                | No NQC -<br>est. data  | Solar        |
| SCE | ZZ_NA                    | 25889 | WALNUT<br>EQFD   | 12.5 | 0.20 | EQ         | LA Basin         | Western                | No NQC -<br>est. data  | Solar        |
| SCE | ZZ_NA                    | 25892 | HINSON EQDS      | 12.5 | 0.30 | PV         | LA Basin         | Western                | No NQC -<br>est. data  | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME              | NQC<br>Comments           | CAISO<br>Tag |
|-----|--------------------------|--------|-----------------|------|-------|------------|------------------|-----------------------------------|---------------------------|--------------|
| SCE | ZZ_NA                    | 25892  | HINSON EQDS     | 12.5 | 3.20  | EQ         | LA Basin         | Western                           | No NQC -<br>est. data     | Market       |
| SCE | ZZ_NA                    | 25849  | NEWARK FD1      | 16   | 4.39  | EQ         | LA Basin         | Western                           | No NQC -<br>est. data     | Solar        |
| SCE | ZZ_PANSEA_1_PANARO       | 25640  | PANAERO         | 115  | 3.40  | QF         | LA Basin         | Eastern, Valley-<br>Devers        |                           | Wind         |
| SCE | ZZ_VALLEY_5_RTS044       | 240514 | VALLEYSC<br>EQF | 12.5 | 0.55  | PV         | LA Basin         | Eastern, Valley,<br>Valley-Devers | No NQC -<br>est. data     | Solar        |
| SCE | ZZ_VENWD_1_WIND1         | 25645  | VENWIND         | 115  | 0.00  | Q1         | LA Basin         | Eastern, Valley-<br>Devers        | Mothballed                | QF/Selfgen   |
| SCE | ZZ_VENWD_1_WIND2         | 25645  | VENWIND         | 115  | 0.00  | Q2         | LA Basin         | Eastern, Valley-<br>Devers        | Mothballed                | QF/Selfgen   |
| SCE | ZZZ_JOANEC_2_ST3BT4      | 102870 | SNTANS4         | 0.55 | 40.00 | 4          | LA Basin         | Western                           | No NQC - P<br>max         | Battery      |
| SCE | ZZZ_New Unit             | 240002 | CATHODE1_G      | 34.5 | 0.00  | 1          | LA Basin         | Western                           | Waiting TPD<br>allocation | Battery      |
| SCE | ZZZ_New Unit             | 114201 | WDT1510G        | 0.69 | 0.00  | 1          | LA Basin         | Eastern                           | Energy Only               | Battery      |
| SCE | ZZZ_New Unit             | 698380 | WDT1558_G       | 0.55 | 0.00  | 1          | LA Basin         | Eastern, West of<br>Devers        | Energy Only               | Battery      |
| SCE | ZZZ_New Unit             | 240004 | CATHODE2_G      | 34.5 | 0.00  | 2          | LA Basin         | Western                           | Waiting TPD<br>allocation | Battery      |
| SCE | ZZZ_New Unit             | 25833  | WDT458G         | 0.2  | 0.00  | EQ         | LA Basin         | Eastern, Valley-<br>Devers        | Energy Only               | Solar        |
| SCE | ZZZ_New Unit             | 25832  | WDT334G         | 0.2  | 0.00  | EQ         | LA Basin         | Eastern, Valley-<br>Devers        | Energy Only               | Solar        |
| SCE | ZZZ_New Unit             | 98956  | WDT1635_G       | 0.6  | 0.00  | EQ         | LA Basin         | Eastern, Valley,<br>Valley-Devers | Energy Only               | Battery      |
| SCE | ZZZ_New Unit             | 99213  | WDT1636_G       | 0.6  | 0.00  | EQ         | LA Basin         | Eastern, Valley,<br>Valley-Devers | Energy Only               | Battery      |
| SCE | ZZZ_New Unit             | 698384 | WDT1583         | 34.5 | 0.00  | PV         | LA Basin         | Western                           | No NQC -<br>est. data     | Solar        |
| SCE | ZZZ_New Unit             | 698385 | WDT1582         | 34.5 | 0.00  | PV         | LA Basin         | Western                           | No NQC -<br>est. data     | Solar        |
| SCE | ZZZ_New Unit             | 240153 | BOTTLE          | 34.5 | 0.60  | W1         | LA Basin         | Eastern, Valley-<br>Devers        | No NQC -<br>est. data     | Wind         |
| SCE | ZZZ_New Unit             | 240155 | UNIMDGEN        | 12   | 1.00  | 1          | LA Basin         | Eastern, West of<br>Devers        | No NQC -<br>est. data     | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME              | NQC<br>Comments       | CAISO<br>Tag |
|-----|--------------------------|--------|-----------------|------|--------|------------|------------------|-----------------------------------|-----------------------|--------------|
| SCE | ZZZ_New Unit             | 240157 | VALLEYS GAS     | 12.5 | 1.00   | EQ         | LA Basin         | Eastern, Valley,<br>Valley-Devers | No NQC -<br>est. data | Market       |
| SCE | ZZZ_New Unit             | 240158 | VSTA BIO        | 12.5 | 1.00   | EQ         | LA Basin         | Eastern                           | No NQC -<br>est. data | Market       |
| SCE | ZZZ_New Unit             | 240159 | VSTA GAS        | 12.5 | 1.00   | SY         | LA Basin         | Eastern                           | No NQC -<br>est. data | Market       |
| SCE | ZZZ_New Unit             | 25834  | HI DSRT         | 34.5 | 1.20   | EQ         | LA Basin         | Eastern, Valley-<br>Devers        | No NQC -<br>est. data | Market       |
| SCE | ZZZ_New Unit             | 240156 | VALIEYS HYD     | 12.5 | 7.00   | EQ         | LA Basin         | Eastern, Valley,<br>Valley-Devers | No NQC -<br>est. data | Market       |
| SCE | ZZZ_New Unit             | 698384 | WDT1583         | 34.5 | 10.00  | B1         | LA Basin         | Western                           | No NQC - P<br>max     | Battery      |
| SCE | ZZZ_New Unit             | 698385 | WDT1582         | 34.5 | 10.00  | B1         | LA Basin         | Western                           | No NQC - P<br>max     | Battery      |
| SCE | ZZZ_New Unit             | 100608 | WDT1702_G       | 0.38 | 77.00  | 1          | LA Basin         | Western                           | No NQC - P<br>max     | Battery      |
| SCE | ZZZ_New Unit             | 102675 | ALMTES2         | 0.75 | 84.50  | 1          | LA Basin         | Western                           | No NQC - P<br>max     | Battery      |
| SCE | ZZZ_New Unit             | 99139  | WDT1641_G       | 0.6  | 100.00 | 1          | LA Basin         | Western, El Nido                  | No NQC - P<br>max     | Battery      |
| SCE | ZZZ_New Unit             | 99511  | WDT1652_G       | 0.6  | 100.00 | 1          | LA Basin         | Western                           | No NQC - P<br>max     | Battery      |
| SCE | ZZZ_New Unit             | 98673  | TOT913_G        | 0.6  | 100.00 | 1          | LA Basin         | Eastern                           | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 99615  | WDT1669_G       | 0.69 | 100.00 | 1          | LA Basin         | Eastern                           | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 102866 | WDT1719_G       | 0.39 | 100.00 | 1          | LA Basin         | Eastern                           | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 240008 | SEPARATOR_<br>G | 34.5 | 100.00 | 1          | LA Basin         | Eastern                           | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 99035  | WDT1648_G       | 0.39 | 100.00 | 1          | LA Basin         | Eastern, West of<br>Devers        | No NQC -<br>Pmax      | Battery      |
| SCE | ZZZ_New Unit             | 102874 | WDT1711_G       | 0.39 | 120.00 | 1          | LA Basin         | Eastern                           | No NQC -<br>Pmax      | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID  | BUS #  | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments                     | CAISO<br>Tag |
|-----|---------------------------|--------|-----------------|------|--------|------------|------------------|----------------------------|-------------------------------------|--------------|
| SCE | ZZZ_New Unit              | 99116  | WDT1659_G       | 0.6  | 200.00 | EQ         | LA Basin         | Eastern, West of<br>Devers | No NQC -<br>Pmax                    | Battery      |
| SCE | ZZZ_New Unit              | 100251 | TOT934_G1       | 0.55 | 235.00 | 1          | LA Basin         | Eastern, Valley            | No NQC -<br>Pmax                    | Battery      |
| SCE | ZZZ_New Unit              | 100252 | TOT934_G2       | 0.55 | 235.00 | 2          | LA Basin         | Eastern, Valley            | No NQC -<br>Pmax                    | Battery      |
| SCE | ZZZ_New Unit              | 100253 | TOT934_G3       | 0.55 | 235.00 | 3          | LA Basin         | Eastern, Valley            | No NQC -<br>Pmax                    | Battery      |
| SCE | ZZZZA_JOHANN_2_T1BB<br>T1 | 240498 | JOHANNA<br>EQFD | 12.5 | 1.40   | BS         | LA Basin         | Western                    | WDAT1428 -<br>No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit            | 240504 | LITEHIPE EQF    | 12.5 | 0.02   | PV         | LA Basin         | Western                    | No NQC -<br>est. data               | Solar        |
| SCE | ZZZZA_New Unit            | 240498 | JOHANNA<br>EQFD | 12.5 | 0.06   | PV         | LA Basin         | Western                    | No NQC -<br>est. data               | Solar        |
| SCE | ZZZZA_New Unit            | 240509 | SANTIAGO<br>EQF | 12.5 | 0.29   | PV         | LA Basin         | Western                    | No NQC -<br>est. data               | Solar        |
| SCE | ZZZZA_New Unit            | 240505 | MIRAGE EQFD     | 12.5 | 0.47   | PV         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data               | Solar        |
| SCE | ZZZZA_New Unit            | 240498 | JOHANNA<br>EQFD | 12.5 | 0.64   | SY         | LA Basin         | Western                    | No NQC -<br>est. data               | Market       |
| SCE | ZZZZA_New Unit            | 240504 | LITEHIPE EQF    | 12.5 | 0.92   | EQ         | LA Basin         | Western                    | No NQC -<br>est. data               | Market       |
| SCE | ZZZZA_New Unit            | 240527 | WDT016A         | 0.21 | 1.09   | W2         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data               | Wind         |
| SCE | ZZZZA_New Unit            | 240542 | WDT1644_PV      | 0.55 | 1.31   | 1          | LA Basin         | Western                    | No NQC -<br>est. data               | Solar        |
| SCE | ZZZZA_New Unit            | 240520 | MILLIKEM FD3    | 12.5 | 1.36   | PV         | LA Basin         | Eastern                    | No NQC -<br>est. data               | Solar        |
| SCE | ZZZZA_New Unit            | 25377  | RP_MESA_G       | 0.66 | 4.00   | VE         | LA Basin         | Western                    | No NQC -<br>est. data               | Battery      |
| SCE | ZZZZA_New Unit            | 240504 | LITEHIPE EQF    | 12.5 | 5.00   | T          | LA Basin         | Western                    | No NQC -<br>est. data               | Market       |
| SCE | ZZZZA_New Unit            | 240507 | OLINDA EQF      | 12.5 | 5.15   | EQ         | LA Basin         | Western                    | No NQC -<br>est. data               | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments       | CAISO<br>Tag |
|-----|--------------------------|--------|------------------|------|-------|------------|------------------|----------------------------|-----------------------|--------------|
| SCE | ZZZZA_New Unit           | 25885  | VSTA EQFD        | 12.5 | 5.70  | EQ         | LA Basin         | Eastern                    |                       | Market       |
| SCE | ZZZZA_New Unit           | 240541 | WDT1644_ST       | 0.55 | 8.69  | 1          | LA Basin         | Western                    | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 240248 | RP_DEVE_WN<br>_  | 0.65 | 8.82  | VW         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Wind         |
| SCE | ZZZZA_New Unit           | 240251 | RP_DEVE_WN<br>_  | 0.65 | 8.82  | VW         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Wind         |
| SCE | ZZZZA_New Unit           | 240254 | RP_DEVE_WN<br>_  | 0.65 | 8.82  | VW         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Wind         |
| SCE | ZZZZA_New Unit           | 240257 | RP_DEVE_WN<br>_  | 0.65 | 8.82  | VW         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Wind         |
| SCE | ZZZZA_New Unit           | 240512 | LAS LOMA FD      | 12.5 | 8.83  | 2          | LA Basin         | Western                    | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 240495 | DECLEZ EQ<br>FC  | 12.5 | 9.67  | EQ         | LA Basin         | Eastern                    | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 240451 | WH_STN_8         | 0.55 | 10.00 | 1          | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240452 | WH_STN_9         | 0.55 | 10.00 | 1          | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240513 | WDT292A          | 12.5 | 10.00 | 1          | LA Basin         | Western                    | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 240516 | MERCED<br>EQFD   | 12.5 | 13.00 | LG         | LA Basin         | Western                    | No NQC -<br>est. data | Market       |
| SCE | ZZZZA_New Unit           | 25446  | RP_ELNIDO_G      | 0.66 | 13.00 | VE         | LA Basin         | Western, El Nido           | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240533 | WDT1602_G        | 0.39 | 20.00 | 1          | LA Basin         | Western, El Nido           | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 25310  | RP_DEVE_PV<br>1_ | 0.38 | 24.80 | VS         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 25313  | RP_DEVE_PV<br>2_ | 0.38 | 24.80 | VS         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Solar        |
| SCE | ZZZZA_New Unit           | 25316  | RP_DEVE_BE<br>SS | 0.66 | 45.00 | VE         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME       | NQC<br>Comments       | CAISO<br>Tag |
|-----|--------------------------|--------|------------------|------|--------|------------|------------------|----------------------------|-----------------------|--------------|
| SCE | ZZZZA_New Unit           | 25434  | RP_JOHANNA<br>_  | 0.66 | 50.00  | VE         | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240954 | TOT1005_G_E<br>S | 0.65 | 75.00  | 1          | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240426 | WDT1725_G        | 0.39 | 90.00  | 1          | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240436 | WDT17816-G       | 34.5 | 110.00 | 1          | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 25356  | RP_MIRALOM<br>A  | 0.66 | 150.00 | VE         | LA Basin         | Eastern                    |                       | Battery      |
| SCE | ZZZZA_New Unit           | 25359  | RP_MIRALOM<br>A_ | 0.66 | 150.00 | VE         | LA Basin         | Eastern                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 25347  | RP_WALNUT_<br>G  | 0.66 | 200.00 | VE         | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 240445 | TOT927_G         | 0.39 | 250.00 | 1          | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 25380  | RP_LAGUBEL<br>L_ | 0.66 | 250.00 | VE         | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZA_New Unit           | 25383  | RP_LAGUBEL<br>L_ | 0.66 | 250.00 | VE         | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZAB_New Unit          | 240747 | RP_CHINO_PV<br>_ | 0.38 | 0.35   | VS         | LA Basin         | Eastern                    | No NQC -<br>est. data | Solar        |
| SCE | ZZZZAB_New Unit          | 240744 | RP_MIRALOM<br>A_ | 0.38 | 0.37   | VS         | LA Basin         | Eastern                    | No NQC -<br>est. data | Solar        |
| SCE | ZZZZAB_New Unit          | 25549  | RP_LTHIPE_P<br>V | 0.39 | 0.91   | VS         | LA Basin         | Western                    | No NQC -<br>est. data | Solar        |
| SCE | ZZZZAB_New Unit          | 240720 | RP_ELCSCO_<br>PV | 0.38 | 24.80  | VS         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Solar        |
| SCE | ZZZZAB_New Unit          | 25310  | RP_DEVE_PV<br>3_ | 0.38 | 24.80  | VS         | LA Basin         | Eastern, Valley-<br>Devers | No NQC -<br>est. data | Solar        |
| SCE | ZZZZAB_New Unit          | 25543  | RP_HINSON_<br>G  | 0.66 | 25.00  | VE         | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |
| SCE | ZZZZAB_New Unit          | 240735 | RP_BARRE_G       | 0.66 | 40.00  | VE         | LA Basin         | Western                    | No NQC -<br>est. data | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO | MKT/SCHED<br>RESOURCE ID  | BUS #  | BUS NAME         | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME              | NQC<br>Comments       | CAISO<br>Tag |
|-----|---------------------------|--------|------------------|------|--------|------------|------------------|-----------------------------------|-----------------------|--------------|
| SCE | ZZZZAB_New Unit           | 240720 | RP_ELCASCO<br>_G | 0.66 | 40.00  | VE         | LA Basin         | Eastern, Valley-<br>Devers        | No NQC -<br>est. data | Battery      |
| SCE | ZZZZAB_New Unit           | 25502  | RP_CENTER_<br>G  | 0.66 | 80.00  | VE         | LA Basin         | Western                           | No NQC -<br>est. data | Battery      |
| SCE | ZZZZAB_New Unit           | 240723 | RP_EAGLERO<br>CK | 0.66 | 80.00  | VE         | LA Basin         | Western                           | No NQC -<br>est. data | Battery      |
| SCE | ZZZZAB_New Unit           | 240728 | RP_VSTA_G        | 0.66 | 100.00 | VE         | LA Basin         | Western                           | No NQC -<br>est. data | Battery      |
| SCE | ZZZZZ_ALAMIT_7_UNIT 1     | 24001  | ALAMT1 G         | 18   | 0.00   | 1          | LA Basin         | Western                           | Retired               | Market       |
| SCE | ZZZZZ_ALAMIT_7_UNIT 2     | 24002  | ALAMT2 G         | 18   | 0.00   | 2          | LA Basin         | Western                           | Retired               | Market       |
| SCE | ZZZZZ_ALAMIT_7_UNIT 6     | 24161  | ALAMT6 G         | 20   | 0.00   | 6          | LA Basin         | Western                           | Retired               | Market       |
| SCE | ZZZZZ_ANAHM_7_CT          | 25208  | DowlingCTG       | 13.8 | 0.00   | 1          | LA Basin         | Western                           | Retired               | MUNI         |
| SCE | ZZZZZ_BRDWAY_7_UNIT<br>3  | 29007  | BRODWYSC         | 13.8 | 0.00   |            | LA Basin         | Western                           | Retired               | MUNI         |
| SCE | ZZZZZ_CENTER_2_QF         | 29953  | SIGGEN           | 13.8 | 0.00   | D1         | LA Basin         | Western                           | Retired               | QF/Selfgen   |
| SCE | ZZZZZ_CHINO_6_SMPPA<br>P  | 24140  | SIMPSON          | 13.8 | 0.00   | R1         | LA Basin         | Eastern                           | Retired               | QF/Selfgen   |
| SCE | ZZZZZ_ETIWND_7_MIDVL<br>Y | 24055  | ETIWANDA         | 66   | 0.00   |            | LA Basin         | Eastern                           | Retired               | QF/Selfgen   |
| SCE | ZZZZZ_ETIWND_7_UNIT 3     | 24052  | MTNVIST3         | 18   | 0.00   | 3          | LA Basin         | Eastern                           | Retired               | Market       |
| SCE | ZZZZZ_ETIWND_7_UNIT 4     | 24053  | MTNVIST4         | 18   | 0.00   | 4          | LA Basin         | Eastern                           | Retired               | Market       |
| SCE | ZZZZZ_GARNET_2_DIFW<br>D1 | 24815  | GARNET           | 115  | 0.00   |            | LA Basin         | Eastern, Valley-<br>Devers        | Retired               | Market       |
| SCE | ZZZZZ_HINSON_6_CARB<br>GN | 24020  | CARBGEN1         | 13.8 | 0.00   | 1          | LA Basin         | Western                           | Retired               | Market       |
| SCE | ZZZZZ_HINSON_6_CARB<br>GN | 24328  | CARBGEN2         | 13.8 | 0.00   | 1          | LA Basin         | Western                           | Retired               | Market       |
| SCE | ZZZZZ_HNTGBH_7_UNIT<br>1  | 24066  | HUNT1 G          | 13.8 | 0.00   | 1          | LA Basin         | Western                           | Retired               | Market       |
| SCE | ZZZZZ_INLDEM_5_UNIT 1     | 29041  | IEEC-G1          | 19.5 | 0.00   | 1          | LA Basin         | Eastern, Valley,<br>Valley-Devers | Retired               | Market       |
| SCE | ZZZZZ_INLDEM_5_UNIT 2     | 29042  | IEEC-G2          | 19.5 | 0.00   | 1          | LA Basin         | Eastern, Valley,<br>Valley-Devers | Retired               | Market       |
| SCE | ZZZZZ_LAGBEL_2_STG1       |        |                  |      | 0.00   |            | LA Basin         | Western                           | Retired               | Market       |
| SCE | ZZZZZ_LAGBEL_6_QF         | 29951  | REFUSE           | 13.8 | 0.00   | D1         | LA Basin         | Western                           | Retired               | QF/Selfgen   |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO   | MKT/SCHED<br>RESOURCE ID  | BUS # | BUS NAME    | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME              | NQC<br>Comments | CAISO<br>Tag |
|-------|---------------------------|-------|-------------|------|--------|------------|------------------|-----------------------------------|-----------------|--------------|
| SCE   | ZZZZZ_MESAS_2_QF          | 24209 | MESA CAL    | 66   | 0.00   |            | LA Basin         | Western                           | Retired         | QF/Selfgen   |
| SCE   | ZZZZZ_MIRLOM_6_DELG<br>EN | 29339 | DELGEN      | 13.8 | 0.00   | 1          | LA Basin         | Eastern                           | Retired         | QF/Selfgen   |
| SCE   | ZZZZZ_OLINDA_2_QF         | 24211 | OLINDA      | 66   | 0.00   |            | LA Basin         | Western                           | Retired         | QF/Selfgen   |
| SCE   | ZZZZZ_OLINDA_7_LNDFIL     | 24211 | OLINDA      | 66   | 0.00   |            | LA Basin         | Western                           | Retired         | QF/Selfgen   |
| SCE   | ZZZZZ_REDOND_7_UNIT<br>5  | 24121 | REDON5 G    | 18   | 0.00   | 5          | LA Basin         | Western                           | Retired         | Market       |
| SCE   | ZZZZZ_REDOND_7_UNIT<br>6  | 24122 | REDON6 G    | 18   | 0.00   | 6          | LA Basin         | Western                           | Retired         | Market       |
| SCE   | ZZZZZ_REDOND_7_UNIT<br>7  | 24123 | REDON7 G    | 20   | 0.00   | 7          | LA Basin         | Western                           | Retired         | Market       |
| SCE   | ZZZZZ_REDOND_7_UNIT<br>8  | 24124 | REDON8 G    | 20   | 0.00   | 8          | LA Basin         | Western                           | Retired         | Market       |
| SCE   | ZZZZZ_RHONDO_2_QF         | 24213 | RIOHONDO    | 66   | 0.00   | DG         | LA Basin         | Western                           | Retired         | QF/Selfgen   |
| SCE   | ZZZZZ_RHONDO_6_PUEN<br>TE | 24213 | RIOHONDO    | 66   | 0.00   |            | LA Basin         | Western                           | Retired         | Net Seller   |
| SCE   | ZZZZZ_SBERDO_2_QF         | 24214 | SANBRDNO    | 66   | 0.00   |            | LA Basin         | Eastern, West of<br>Devers        | Retired         | QF/Selfgen   |
| SCE   | ZZZZZ_VALLEY_7_BADLN<br>D | 24160 | VALLEYSC    | 115  | 0.00   |            | LA Basin         | Eastern, Valley,<br>Valley-Devers | Retired         | Market       |
| SCE   | ZZZZZ_VALLEY_7_UNITA<br>1 | 24160 | VALLEYSC    | 115  | 0.00   |            | LA Basin         | Eastern, Valley,<br>Valley-Devers | Retired         | Market       |
| SCE   | ZZZZZ_WALNUT_7_WCO<br>VCT | 24157 | WALNUT      | 66   | 0.00   |            | LA Basin         | Western                           | Retired         | Market       |
| SCE   | ZZZZZZ_ELSEGN_7_UNIT<br>4 | 24048 | ELSEG4 G    | 18   | 0.00   | 4          | LA Basin         | Western, El Nido                  | Retired         | Market       |
| SDG&E | BORDER_6_UNITA1           | 22149 | CALPK_BD    | 13.8 | 51.25  | 1          | SD-IV            | San Diego, Border                 |                 | Market       |
| SDG&E | BREGGO_6_DEGRSL           | 22085 | BORREGO     | 12.5 | 0.78   | 6          | SD-IV            | San Diego                         | Aug NQC         | Solar        |
| SDG&E | BREGGO_6_SOLAR            | 22082 | BR GEN1     | 0.21 | 3.22   | 1          | SD-IV            | San Diego                         | Aug NQC         | Solar        |
| SDG&E | CARLS1_2_CARCT1           | 22783 | EA GEN1 U8  | 13.8 | 105.50 | 1          | SD-IV            | San Diego                         | Aug NQC         | Market       |
| SDG&E | CARLS1_2_CARCT1           | 22784 | EA GEN1 U9  | 13.8 | 105.50 | 1          | SD-IV            | San Diego                         | Aug NQC         | Market       |
| SDG&E | CARLS1_2_CARCT1           | 22786 | EA GEN1 U6  | 13.8 | 105.50 | 1          | SD-IV            | San Diego                         | Aug NQC         | Market       |
| SDG&E | CARLS1_2_CARCT1           | 22787 | EA GEN1 U7  | 13.8 | 105.50 | 1          | SD-IV            | San Diego                         | Aug NQC         | Market       |
| SDG&E | CARLS2_1_CARCT1           | 22789 | EA GEN1 U10 | 13.8 | 105.50 | 1          | SD-IV            | San Diego                         | Aug NQC         | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO   | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME   | NQC<br>Comments | CAISO<br>Tag |
|-------|--------------------------|-------|-----------------|------|--------|------------|------------------|------------------------|-----------------|--------------|
| SDG&E | CHILLS_1_SYCENG          | 22120 | CARLTNHS        | 138  | 1.00   | 1          | SD-IV            | San Diego              | Aug NQC         | QF/Selfgen   |
| SDG&E | CHILLS_7_UNITA1          | 22120 | CARLTNHS        | 138  | 1.52   | 2          | SD-IV            | San Diego              | Aug NQC         | QF/Selfgen   |
| SDG&E | CNTNLA_2_SOLAR1          | 23401 | DW GEN3 G1      | 0.33 | 15.50  | 1          | SD-IV            |                        | Aug NQC         | Solar        |
| SDG&E | CNTNLA_2_SOLAR2          | 23402 | DW GEN3 G2      | 0.33 | 5.65   | 2          | SD-IV            |                        | Aug NQC         | Solar        |
| SDG&E | CPVERD_2_SOLAR           | 23301 | IV GEN3 G2      | 0.31 | 7.66   | 1          | SD-IV            |                        | Aug NQC         | Solar        |
| SDG&E | CPVERD_2_SOLAR           | 23309 | IV GEN3 G1      | 0.31 | 9.58   | 1          | SD-IV            |                        | Aug NQC         | Solar        |
| SDG&E | CRELMN_6_RAMON1          | 22152 | CREELMAN        | 69   | 0.25   | 27         | SD-IV            | San Diego              | Aug NQC         | Solar        |
| SDG&E | CRELMN_6_RAMON2          | 22152 | CREELMAN        | 69   | 0.62   | 27         | SD-IV            | San Diego              | Aug NQC         | Solar        |
| SDG&E | CRELMN_6_RAMSR3          | 22152 | CREELMAN        | 69   | 0.43   | 35         | SD-IV            | San Diego              | Aug NQC         | Solar        |
| SDG&E | CRSTWD_6_KUMYAY          | 22915 | KUMEYAAY        | 0.69 | 5.44   | 1          | SD-IV            | San Diego              | Aug NQC         | Wind         |
| SDG&E | CSLR4S_2_SOLAR           | 23298 | DW GEN1 G1      | 0.32 | 8.06   | 1          | SD-IV            |                        | Aug NQC         | Solar        |
| SDG&E | CSLR4S_2_SOLAR           | 23299 | DW GEN1 G2      | 0.32 | 8.06   | 1          | SD-IV            |                        | Aug NQC         | Solar        |
| SDG&E | ELCAJN_6_EB1BT1          | 22208 | EL CAJON        | 69   | 7.50   | 1          | SD-IV            | San Diego, El<br>Cajon |                 | Battery      |
| SDG&E | ELCAJN_6_LM6K            | 23320 | EC GEN2         | 13.8 | 48.10  | 1          | SD-IV            | San Diego, El<br>Cajon |                 | Market       |
| SDG&E | ELCAJN_6_UNITA1          | 22150 | EC GEN1         | 13.8 | 45.42  | 1          | SD-IV            | San Diego, El<br>Cajon |                 | Market       |
| SDG&E | ENERSJ_2_WIND            | 23100 | ECO GEN1 G1     | 0.69 | 16.44  | G1         | SD-IV            |                        | Aug NQC         | Wind         |
| SDG&E | ENERSJ_5_ESJWD2          |       |                 |      | 11.43  |            | SD-IV            |                        | Aug NQC         | Wind         |
| SDG&E | ESCND0_6_EB1BT1          | 22256 | ESCNDIDO        | 69   | 10.00  | 10         | SD-IV            | San Diego              |                 | Battery      |
| SDG&E | ESCND0_6_EB2BT2          | 22256 | ESCNDIDO        | 69   | 10.00  | 11         | SD-IV            | San Diego              |                 | Battery      |
| SDG&E | ESCND0_6_EB3BT3          | 22256 | ESCNDIDO        | 69   | 10.00  | 12         | SD-IV            | San Diego              |                 | Battery      |
| SDG&E | ESCND0_6_PL1X2           | 22257 | ES GEN          | 13.8 | 48.71  | 1          | SD-IV            | San Diego              |                 | Market       |
| SDG&E | ESCND0_6_UNITB1          | 22153 | CALPK_ES        | 13.8 | 48.04  | 1          | SD-IV            | San Diego              |                 | Market       |
| SDG&E | ESCO_6_GLMQF             | 22333 | GOALLINE        | 13.8 | 8.75   | 2          | SD-IV            | San Diego              | Aug NQC         | Net Seller   |
| SDG&E | ESCO_6_GLMQF             | 22333 | GOALLINE        | 13.8 | 41.15  | 1          | SD-IV            | San Diego              | Aug NQC         | Net Seller   |
| SDG&E | FALBRK_6_FESBT1          | 23544 | AV<br>GEN1 BESS | 0.64 | 40.00  | 1          | SD-IV            | San Diego              |                 | Battery      |
| SDG&E | GATEWY_2_GESBT1          | 23710 | OM<br>GEN4 BESS | 0.51 | 175.00 | 1          | SD-IV            | San Diego              |                 | Battery      |
| SDG&E | IVSLR2_2_SM2SR1          | 23441 | DW GEN6         | 0.42 | 18.60  | 1          | SD-IV            |                        | Aug NQC         | Solar        |
| SDG&E | IVSLRP_2_SOLAR1          | 23440 | DW GEN2         | 0.36 | 24.80  | 1          | SD-IV            |                        | Aug NQC         | Solar        |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO   | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments            | CAISO<br>Tag |
|-------|--------------------------|-------|-----------------|------|--------|------------|------------------|----------------------|----------------------------|--------------|
| SDG&E | IWEST_2_SOLAR1           | 23156 | DU GEN1 G2      | 0.2  | 8.54   | 1          | SD-IV            |                      | Aug NQC                    | Solar        |
| SDG&E | IWEST_2_SOLAR1           | 23155 | DU GEN1 G1      | 0.2  | 10.06  | 1          | SD-IV            |                      | Aug NQC                    | Solar        |
| SDG&E | JACMSR_1_JACSR1          | 23352 | ECO GEN2        | 0.55 | 2.48   | 1          | SD-IV            |                      | Aug NQC                    | Solar        |
| SDG&E | KEARNY_6_NESBT1          | 22372 | KEARNY          | 60   | 10.00  | 25         | SD-IV            | San Diego            | Aug NQC                    | Battery      |
| SDG&E | KEARNY_6_SESBT2          | 22372 | KEARNY          | 60   | 10.00  | 26         | SD-IV            | San Diego            | Aug NQC                    | Battery      |
| SDG&E | KYCORA_6_KMSBT1          |       |                 |      | 0.00   |            | SD-IV            | San Diego            | Not modeled<br>Energy Only | Battery      |
| SDG&E | LAKHDG_6_UNIT 1          | 22625 | LKHODG1         | 13.8 | 20.00  | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | LAKHDG_6_UNIT 2          | 22626 | LKHODG2         | 13.8 | 20.00  | 2          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | LARKSP_6_UNIT 1          | 22074 | LRKSPBD1        | 13.8 | 49.00  | 1          | SD-IV            | San Diego, Border    |                            | Market       |
| SDG&E | LARKSP_6_UNIT 2          | 22075 | LRKSPBD2        | 13.8 | 49.00  | 1          | SD-IV            | San Diego, Border    |                            | Market       |
| SDG&E | LAROA2_2_UNITA1          | 22996 | INTBST          | 18   | 145.19 | 1          | SD-IV            |                      |                            | Market       |
| SDG&E | LAROA2_2_UNITA1          | 22997 | INTBCT          | 16   | 176.81 | 1          | SD-IV            |                      |                            | Market       |
| SDG&E | LECONT_2_LESBT1          | 23597 | BW<br>GEN8 BESS | 0.69 | 40.00  | 1          | SD-IV            |                      | PCDS                       | Battery      |
| SDG&E | LILIAC_6_SOLAR           | 22404 | LILIAC          | 69   | 0.37   | 67         | SD-IV            | San Diego            |                            | Solar        |
| SDG&E | MRGT_6_MEF2              | 22487 | MEF MR2         | 13.8 | 44.00  | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | MRGT_6_MMAREF            | 22486 | MEF MR1         | 13.8 | 45.00  | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | MRGT_6_TGEBT1            | 23412 | MRGT GEN        | 0.64 | 30.00  | 1          | SD-IV            | San Diego            |                            | Battery      |
| SDG&E | MSHGTS_6_MMARLF          | 22448 | MESAHGTS        | 69   | 4.08   | 1          | SD-IV            | San Diego            | Aug NQC                    | Market       |
| SDG&E | MSSION_2_QF              | 22496 | MISSION         | 69   | 0.32   | 1          | SD-IV            | San Diego            | Aug NQC                    | Market       |
| SDG&E | MURRAY_6_UNIT            | 22532 | MURRAY          | 69   | 0.00   |            | SD-IV            | San Diego            | Not modeled<br>Energy Only | Market       |
| SDG&E | OCTILO_5_WIND            | 23314 | OCO GEN G1      | 0.69 | 14.43  | 1          | SD-IV            |                      | Aug NQC                    | Wind         |
| SDG&E | OCTILO_5_WIND            | 23318 | OCO GEN G2      | 0.69 | 14.43  | 1          | SD-IV            |                      | Aug NQC                    | Wind         |
| SDG&E | OGROVE_6_PL1X2           | 22628 | PA GEN1         | 13.8 | 48.00  | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | OGROVE_6_PL1X2           | 22629 | PA GEN2         | 13.8 | 48.00  | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | OTAY_6_PL1X2             | 22617 | OY GEN          | 13.8 | 37.20  | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | OTMESA_2_PL1X3           | 22605 | OTAYMGT1        | 18   | 165.16 | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | OTMESA_2_PL1X3           | 22606 | OTAYMGT2        | 18   | 166.17 | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | OTMESA_2_PL1X3           | 22607 | OTAYMST1        | 16   | 272.27 | 1          | SD-IV            | San Diego            |                            | Market       |
| SDG&E | PALOMR_2_PL1X3           | 22262 | PEN_CT1         | 18   | 176.98 | 1          | SD-IV            | San Diego            |                            | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO   | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments  | CAISO<br>Tag |
|-------|--------------------------|-------|-----------------|------|--------|------------|------------------|----------------------|------------------|--------------|
| SDG&E | PALOMR_2_PL1X3           | 22263 | PEN_CT2         | 18   | 176.98 | 1          | SD-IV            | San Diego            |                  | Market       |
| SDG&E | PALOMR_2_PL1X3           | 22265 | PEN_ST          | 18   | 234.24 | 1          | SD-IV            | San Diego            |                  | Market       |
| SDG&E | PIOPIC_2_CTG1            | 23162 | PIO PICO CT1    | 13.8 | 111.30 | 1          | SD-IV            | San Diego            | No NQC -<br>Pmax | Market       |
| SDG&E | PIOPIC_2_CTG2            | 23163 | PIO PICO CT2    | 13.8 | 112.70 | 1          | SD-IV            | San Diego            | No NQC -<br>Pmax | Market       |
| SDG&E | PIOPIC_2_CTG3            | 23164 | PIO PICO CT3    | 13.8 | 112.00 | 1          | SD-IV            | San Diego            | No NQC -<br>Pmax | Market       |
| SDG&E | PRCTVY_1_MIGBT1          | 22672 | PRCTRVLY        | 138  | 0.00   | 4          | SD-IV            | San Diego            | Aug NQC          | Battery      |
| SDG&E | SAMPSN_6_KELCO1          | 22704 | SAMPSON         | 12.5 | 1.59   | 1          | SD-IV            | San Diego            | Aug NQC          | Net Seller   |
| SDG&E | SLRMS3_2_SRMSR1          | 23443 | DW GEN4 G2      | 0.6  | 12.40  | 1          | SD-IV            |                      | Aug NQC          | Solar        |
| SDG&E | SLRMS3_2_SRMSR1          | 23442 | DW GEN4 G1      | 0.6  | 18.60  | 1          | SD-IV            |                      | Aug NQC          | Solar        |
| SDG&E | SMRCOS_6_LNDFIL          | 22724 | SANMRCOS        | 69   | 1.50   | 1          | SD-IV            | San Diego            | Aug NQC          | Market       |
| SDG&E | TERMEX_2_PL1X3           | 22982 | IV GEN1 CTG2    | 18   | 156.44 | 1          | SD-IV            |                      |                  | Market       |
| SDG&E | TERMEX_2_PL1X3           | 22983 | IV GEN1 CTG3    | 18   | 156.44 | 1          | SD-IV            |                      |                  | Market       |
| SDG&E | TERMEX_2_PL1X3           | 22981 | IV GEN1 STG     | 21   | 280.13 | 1          | SD-IV            |                      |                  | Market       |
| SDG&E | VLCNTR_6_VCEBT1          | 22991 | VC<br>GEN1 GEN3 | 34.5 | 0.00   | 1          | SD-IV            | San Diego            | Energy Only      | Battery      |
| SDG&E | VLCNTR_6_VCEBT1          | 23627 | VC<br>GEN1 GEN1 | 34.5 | 54.00  | 1          | SD-IV            | San Diego            |                  | Battery      |
| SDG&E | VLCNTR_6_VCEBT2          | 23628 | VC<br>GEN1 GEN2 | 34.5 | 50.00  | 1          | SD-IV            | San Diego            |                  | Battery      |
| SDG&E | VLCNTR_6_VCSLR           | 22870 | VALCNTR         | 69   | 0.29   | 59         | SD-IV            | San Diego            | Aug NQC          | Solar        |
| SDG&E | VLCNTR_6_VCSLR1          | 22870 | VALCNTR         | 69   | 0.31   | 28         | SD-IV            | San Diego            | Aug NQC          | Solar        |
| SDG&E | VLCNTR_6_VCSLR2          | 22870 | VALCNTR         | 69   | 0.62   | 28         | SD-IV            | San Diego            | Aug NQC          | Solar        |
| SDG&E | VSTAES_6_VESBT1          | 23541 | ME GEN<br>1 BS1 | 0.64 | 5.00   | 1          | SD-IV            | San Diego            |                  | Battery      |
| SDG&E | VSTAES_6_VESBT1          | 23216 | ME GEN<br>1 BS2 | 0.48 | 5.00   | 1          | SD-IV            | San Diego            |                  | Battery      |
| SDG&E | WESCAN_2_BDSBT1          | 23421 | Q1531_ES1       | 0.55 | 65.50  | 1          | SD-IV            |                      |                  | Battery      |
| SDG&E | WESCAN_2_BDSBT1          | 23425 | Q1531_ES2       | 0.55 | 65.50  | 1          | SD-IV            |                      |                  | Battery      |
| SDG&E | WISTRA_2_WRSSR1          | 23287 | DW GEN5 G1      | 0.42 | 12.40  | 1          | SD-IV            |                      | Aug NQC          | Solar        |
| SDG&E | ZZ_CBRLLLO_6_PLSTP1      | 22092 | CABRILLO        | 69   | 2.70   | 1          | SD-IV            | San Diego            |                  | Market       |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO   | MKT/SCHED<br>RESOURCE ID | BUS # | BUS NAME        | kV   | NQC   | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments   | CAISO<br>Tag |
|-------|--------------------------|-------|-----------------|------|-------|------------|------------------|----------------------|---|--------------|
| SDG&E | ZZ_CCRITA_7_RPPCHF       | 22124 | CHCARITA        | 138  | 2.00  | 1          | SD-IV            | San Diego            |   | Market       |
| SDG&E | ZZ_LAROA1_2_UNITA1       | 20187 | LRP-U1          | 16   | 0.00  | 1          | SD-IV            |                      | Connect to<br>CENACE/CF<br>E grid for the<br>summer –<br>not available<br>for ISO BAA<br>RA purpose | Market       |
| SDG&E | ZZ_NA                    | 22916 | PFC-AVC         | 0.6  | 0.00  | 1          | SD-IV            | San Diego            | No NQC -<br>hist. data  | QF/Selfgen   |
| SDG&E | ZZ_NA                    | 22204 | EASTGATE        | 69   | 0.20  | 1          | SD-IV            | San Diego            | No NQC -<br>hist. data  | Market       |
| SDG&E | ZZ_NA                    | 22604 | OTAY            | 69   | 2.20  | 3          | SD-IV            | San Diego            | No NQC -<br>hist. data  | Market       |
| SDG&E | ZZ_NA                    | 22604 | OTAY            | 69   | 2.80  | 1          | SD-IV            | San Diego            | No NQC -<br>hist. data  | Market       |
| SDG&E | ZZZ_New Unit             | 22949 | BUE GEN<br>1_G4 | 0.69 | 0.00  | 1          | SD-IV            |                      | Energy Only   | Wind         |
| SDG&E | ZZZ_New Unit             | 23475 | Q1832_GEN       | 0.39 | 0.00  | 1          | SD-IV            | San Diego            | Waiting TPD<br>allocation   | Battery      |
| SDG&E | ZZZ_New Unit             | 23231 | Q1432_PV        | 0.39 | 0.00  | 1          | SD-IV            | San Diego            | Energy Only   | Solar        |
| SDG&E | ZZZ_New Unit             | 23414 | Q1166_PV_G1     | 0.63 | 0.00  | 1          | SD-IV            |                      | Energy Only   | Solar        |
| SDG&E | ZZZ_New Unit             | 23436 | Q1166_PV_G2     | 0.63 | 0.00  | 1          | SD-IV            |                      | Energy Only   | Solar        |
| SDG&E | ZZZ_New Unit             | 22624 | PALA            | 69   | 0.00  | 88         | SD-IV            | San Diego            | Waiting TPD<br>allocation   | Battery      |
| SDG&E | ZZZ_New Unit             | 22112 | CAPSTRNO        | 138  | 5.65  | 1          | SD-IV            | San Diego            | No NQC -<br>Pmax  | Market       |
| SDG&E | ZZZ_New Unit             | 22440 | MELROSE         | 69   | 10.00 | 22         | SD-IV            | San Diego            | No NQC -<br>Pmax  | Battery      |
| SDG&E | ZZZ_New Unit             | 22440 | MELROSE         | 69   | 10.00 | 23         | SD-IV            | San Diego            | No NQC -<br>Pmax  | Battery      |
| SDG&E | ZZZ_New Unit             | 22088 | BOULEVRD        | 69   | 10.00 | 27         | SD-IV            |                      | No NQC -<br>Pmax  | Battery      |
| SDG&E | ZZZ_New Unit             | 22136 | CLAIRMNT        | 69   | 10.00 | 28         | SD-IV            | San Diego            | No NQC -<br>Pmax  | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO   | MKT/SCHED<br>RESOURCE ID  | BUS #  | BUS NAME    | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME   | NQC<br>Comments  | CAISO<br>Tag |
|-------|---------------------------|--------|-------------|------|--------|------------|------------------|------------------------|------------------|--------------|
| SDG&E | ZZZ_New Unit              | 22216  | ELLIOTT     | 69   | 10.00  | 29         | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZ_New Unit              | 22636  | PARADISE    | 69   | 10.00  | 30         | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZ_New Unit              | 23253  | Q1432_ES    | 0.48 | 17.40  | 1          | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZ_New Unit              | 23871  | Q1662_ES    | 34.5 | 50.00  | 12         | SD-IV            | San Diego, El<br>Cajon | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZ_New Unit              | 23710  | Q1170_BESS  | 0.51 | 75.00  | 1          | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZ_New Unit              | 23416  | Q1166_ES_G1 | 0.63 | 87.00  | 1          | SD-IV            |                        | No NQC -<br>PCDS | Battery      |
| SDG&E | ZZZ_New Unit              | 23438  | Q1166_ES_G2 | 0.63 | 87.00  | 1          | SD-IV            |                        | No NQC -<br>PCDS | Battery      |
| SDG&E | ZZZ_New Unit              | 23929  | Q1669_ES    | 0.6  | 100.00 | 1          | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZ_New Unit              | 23933  | Q1670_ES    | 0.6  | 200.00 | 1          | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZ_New Unit              | 23959  | Q1673_ES1   | 0.6  | 300.00 | 1          | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZ_New Unit             | 22969  | Q1532_GEN   | 34.5 | 90.00  | 1          | SD-IV            |                        | No NQC -<br>Pmax | Hybrid       |
| SDG&E | ZZZZ_New Unit             | 23042  | Q1806_GEN   | 0.66 | 250.00 | 1          | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_CAMERN_6_BSPB<br>T1 | 22104  | CAMERON     | 69   | 0.50   | 79         | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_CAMERN_6_BSPS<br>R1 | 22104  | CAMERON     | 69   | 0.01   | 78         | SD-IV            | San Diego              | No NQC -<br>Pmax | Solar        |
| SDG&E | ZZZZA_CRELMN_6_AABB<br>T1 | 22152  | CREELMAN    | 69   | 0.50   | 77         | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_New Unit            | 230138 | GR1209_G    | 0.64 | 30.00  | VE         | SD-IV            | San Diego              | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_New Unit            | 23560  | Q1047_BESS  | 0.55 | 50.00  | 1          | SD-IV            | San Diego, El<br>Cajon | No NQC -<br>Pmax | Battery      |

Attachment A - List of physical resources by PTO, local area and market ID

| PTO   | MKT/SCHED<br>RESOURCE ID | BUS #  | BUS NAME  | kV   | NQC    | UNIT<br>ID | LCR AREA<br>NAME | LCR SUB-AREA<br>NAME | NQC<br>Comments  | CAISO<br>Tag |
|-------|--------------------------|--------|-----------|------|--------|------------|------------------|----------------------|------------------|--------------|
| SDG&E | ZZZZA_New Unit           | 230147 | GR1212_G  | 0.48 | 100.00 | VE         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_New Unit           | 230149 | GR1213_G1 | 13.8 | 109.00 | VE         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_New Unit           | 230150 | GR1213_G2 | 13.8 | 109.00 | VE         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_New Unit           | 230151 | GR1213_G3 | 13.8 | 109.00 | VE         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_New Unit           | 230151 | GR1213_G4 | 13.8 | 109.00 | VE         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_OTAY_6_ECVBT1      | 22604  | OTAY      | 69   | 3.00   | 90         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZA_OTAY_6_ECVBT2      | 22604  | OTAY      | 69   | 3.00   | 91         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZAB_New Unit          | 230167 | GR1216_G  | 0.48 | 92.00  | VE         | SD-IV            | San Diego            | No NQC -<br>Pmax | Battery      |
| SDG&E | ZZZZZ_PTLOMA_6_NTCQ<br>F | 22660  | POINTLMA  | 69   | 0.00   | 1          | SD-IV            | San Diego            | Retired          | QF/Selfgen   |

○

## Attachment B – Effectiveness factors for procurement guidance

**Table - Eagle Rock.**

Effectiveness factors to the Eagle Rock-Cortina 115 kV line:

| Gen Bus | Gen Name | Gen ID | Eff Fctr (%) |
|---------|----------|--------|--------------|
| 31406   | GEYSR5-6 | 1      | 36           |
| 31406   | GEYSR5-6 | 2      | 36           |
| 31408   | GEYSER78 | 1      | 36           |
| 31408   | GEYSER78 | 2      | 36           |
| 31412   | GEYSER11 | 1      | 37           |
| 31435   | GEO.ENGY | 1      | 35           |
| 31435   | GEO.ENGY | 2      | 35           |
| 31433   | POTTRVLY | 1      | 34           |
| 31433   | POTTRVLY | 3      | 34           |
| 31433   | POTTRVLY | 4      | 34           |
| 38020   | CITY UKH | 1      | 32           |
| 38020   | CITY UKH | 2      | 32           |

**Table – Rio Oso**

Effectiveness factors to the Rio Oso-Atlantic 230 kV line:

| Gen Bus | Gen Name | Gen ID | Eff Fctr. (%) |
|---------|----------|--------|---------------|
| 32498   | SPILINCF | 1      | 49            |
| 32500   | ULTR RCK | 1      | 49            |
| 32456   | MIDLFORK | 1      | 33            |

**Attachment B - Effectiveness factors for procurement guidance**

|       |           |   |    |
|-------|-----------|---|----|
| 32456 | MIDLFORK  | 2 | 33 |
| 32458 | RALSTON   | 1 | 33 |
| 32513 | ELDRADO1  | 1 | 32 |
| 32514 | ELDRADO2  | 1 | 32 |
| 32510 | CHILIBAR  | 1 | 32 |
| 32486 | HELLHOLE  | 1 | 31 |
| 32508 | FRNCH MD  | 1 | 30 |
| 32460 | NEWCASTLE | 1 | 26 |
| 32478 | HALSEY F  | 1 | 24 |
| 32512 | WISE      | 1 | 24 |
| 38114 | Stig CC   | 1 | 14 |
| 38123 | Q267CT    | 1 | 14 |
| 38124 | Q267ST    | 1 | 14 |
| 32462 | CHI.PARK  | 1 | 8  |
| 32464 | DTCHFLT1  | 1 | 4  |

**Table – South Bay-Moss Landing**

Effectiveness factors to the Moss Landing-Las Aguillas 230 kV line:

| <b>Gen Bus</b> | <b>Gen Name</b> | <b>Gen ID</b> | <b>Eff Fctr. (%)</b> |
|----------------|-----------------|---------------|----------------------|
| 36209          | SLD ENRG        | 1             | 20                   |
| 36221          | DUKMOSS1        | 1             | 20                   |
| 36222          | DUKMOSS2        | 1             | 20                   |
| 36223          | DUKMOSS3        | 1             | 20                   |
| 36224          | DUKMOSS4        | 1             | 20                   |
| 36225          | DUKMOSS5        | 1             | 20                   |
| 36226          | DUKMOSS6        | 1             | 20                   |

Attachment B - Effectiveness factors for procurement guidance

|       |          |    |    |
|-------|----------|----|----|
| 36405 | MOSSLND6 | 1  | 17 |
| 36406 | MOSSLND7 | 1  | 17 |
| 35881 | MEC CTG1 | 1  | 13 |
| 35882 | MEC CTG2 | 1  | 13 |
| 35883 | MEC STG1 | 1  | 13 |
| 35850 | GLRY COG | 1  | 12 |
| 35850 | GLRY COG | 2  | 12 |
| 35851 | GROYPKR1 | 1  | 12 |
| 35852 | GROYPKR2 | 1  | 12 |
| 35853 | GROYPKR3 | 1  | 12 |
| 35623 | SWIFT    | BT | 10 |
| 35863 | CATALYST | 1  | 10 |
| 36863 | DVRaGT1  | 1  | 8  |
| 36864 | DVRbGt2  | 1  | 8  |
| 36865 | DVRaST3  | 1  | 8  |
| 36859 | Laf300   | 2  | 8  |
| 36859 | Laf300   | 1  | 8  |
| 36858 | Gia100   | 1  | 7  |
| 36895 | Gia200   | 1  | 7  |
| 35854 | LECEFGT1 | 1  | 7  |
| 35855 | LECEFGT2 | 1  | 7  |
| 35856 | LECEFGT3 | 1  | 7  |
| 35857 | LECEFGT4 | 1  | 7  |
| 35858 | LECEFST1 | 1  | 7  |
| 35860 | OLS-AGNE | 1  | 7  |

Attachment B - Effectiveness factors for procurement guidance

**Table – Ames/Pittsburg/Oakland**

Effectiveness factors to the Ames-Ravenswood #1 115 kV line:

| Gen Bus | Gen Name | Gen ID | Eff Fctr. (%) |
|---------|----------|--------|---------------|
| 35304   | RUSELCT1 | 1      | 10            |
| 35305   | RUSELCT2 | 2      | 10            |
| 35306   | RUSELST1 | 3      | 10            |
| 33469   | OX_MTN   | 1      | 10            |
| 33469   | OX_MTN   | 2      | 10            |
| 33469   | OX_MTN   | 3      | 10            |
| 33469   | OX_MTN   | 4      | 10            |
| 33469   | OX_MTN   | 5      | 10            |
| 33469   | OX_MTN   | 6      | 10            |
| 33469   | OX_MTN   | 7      | 10            |
| 33107   | DEC STG1 | 1      | 3             |
| 33108   | DEC CTG1 | 1      | 3             |
| 33109   | DEC CTG2 | 1      | 3             |
| 33110   | DEC CTG3 | 1      | 3             |
| 33102   | COLUMBIA | 1      | 3             |
| 33111   | LMECCT2  | 1      | 3             |
| 33112   | LMECCT1  | 1      | 3             |
| 33113   | LMECST1  | 1      | 3             |
| 33151   | FOSTER W | 1      | 2             |
| 33151   | FOSTER W | 2      | 2             |
| 33151   | FOSTER W | 3      | 2             |
| 33136   | CCCSD    | 1      | 2             |
| 33141   | SHELL 1  | 1      | 2             |
| 33142   | SHELL 2  | 1      | 2             |

Attachment B - Effectiveness factors for procurement guidance

|       |             |   |   |
|-------|-------------|---|---|
| 33143 | SHELL 3     | 1 | 2 |
| 32900 | CRCKTCOG    | 1 | 2 |
| 32910 | UNOCAL      | 1 | 2 |
| 32910 | UNOCAL      | 2 | 2 |
| 32910 | UNOCAL      | 3 | 2 |
| 32920 | UNION CH    | 1 | 2 |
| 32921 | ChevGen1    | 1 | 2 |
| 32922 | ChevGen2    | 1 | 2 |
| 32923 | ChevGen3    | 3 | 2 |
| 32741 | HILLSIDE_12 | 1 | 2 |
| 32901 | OAKLND 1    | 1 | 1 |
| 32902 | OAKLND 2    | 2 | 1 |
| 32903 | OAKLND 3    | 3 | 1 |
| 38118 | ALMDACT1    | 1 | 1 |
| 38119 | ALMDACT2    | 1 | 1 |

Effectiveness factors to the Moraga-Claremont #2 115 kV line:

| Gen Bus | Gen Name    | Gen ID | Eff Fctr. (%) |
|---------|-------------|--------|---------------|
| 32741   | HILLSIDE_12 | 1      | 15            |
| 32921   | ChevGen1    | 1      | 15            |
| 32922   | ChevGen2    | 1      | 15            |
| 32923   | ChevGen3    | 3      | 15            |
| 32920   | UNION CH    | 1      | 14            |
| 32910   | UNOCAL      | 1      | 13            |
| 32910   | UNOCAL      | 2      | 13            |
| 32910   | UNOCAL      | 3      | 13            |

Attachment B - Effectiveness factors for procurement guidance

|       |          |   |    |
|-------|----------|---|----|
| 32901 | OAKLND 1 | 1 | 10 |
| 32902 | OAKLND 2 | 2 | 10 |
| 32903 | OAKLND 3 | 3 | 10 |
| 38118 | ALMDACT1 | 1 | 10 |
| 38119 | ALMDACT2 | 1 | 10 |
| 33141 | SHELL 1  | 1 | 9  |
| 33142 | SHELL 2  | 1 | 9  |
| 33143 | SHELL 3  | 1 | 9  |
| 33136 | CCCSD    | 1 | 8  |
| 32900 | CRCKTCOG | 1 | 7  |
| 33151 | FOSTER W | 1 | 6  |
| 33151 | FOSTER W | 2 | 6  |
| 33151 | FOSTER W | 3 | 6  |
| 33102 | COLUMBIA | 1 | 3  |
| 33111 | LMECCT2  | 1 | 3  |
| 33112 | LMECCT1  | 1 | 3  |
| 33113 | LMECST1  | 1 | 3  |
| 33107 | DEC STG1 | 1 | 3  |
| 33108 | DEC CTG1 | 1 | 3  |
| 33109 | DEC CTG2 | 1 | 3  |
| 33110 | DEC CTG3 | 1 | 3  |