

ISO TARIFF APPENDIX J

End-Use Meter Standards & Capabilities

End-Use Meter Standards & Capabilities Part A

END-USE METER STANDARDS & CAPABILITIES

End Use Meter Standards. All metering shall be of a revenue class metering accuracy in accordance with the ANSI C12 standards on metering and any other requirements of the relevant UDC or Local Regulatory Authority that may apply. Such requirements may apply to meters, current transformers and potential transformers, and associated equipment. ANSI C12 metering standards include the following:

ANSI C12.1 - American National Standard Code For Electricity Metering

ANSI C12.4 - American National Standard For Mechanical Demand Registers

ANSI C12.5 - American National Standard For Thermal Demand Meters

ANSI C12.6 - American National Standard For Marking And Arrangement Of Terminals For Phase-Shifting Devices Used In Metering

ANSI C12.7 - American National Standard For Watt-hour Meter Sockets

ANSI C12.8 - American National Standard For Test Blocks And Cabinets For installation Of Self-Contained A-Base Watt-hour Meters

ANSI C12.9 - American National Standard For Test Switches For Transformer-Rated Meters

ANSI C12.10 - American National Standard For Electromechanical Watt-hour Meters

ANSI C12.11 - American National Standard For Instrument Transformers For Revenue Metering, 10 kV BIL Through 350 kV BIL

ANSI C12.13 - American National Standard For Electronic Time-Of -Use Registers For Electricity Meters

ANSI C12.14 - American National Standard For Magnetic Tape Pulse Recorders For Electricity Meters

ANSI C12.15 - American National Standard For Solid-State Demand Registers For Electromechanical Watt-hour Meters

ANSI C12.16 - American National Standard For Solid-State Electricity Meters

ANSI C12.17 - American National Standard For Cartridge-Type Solid-State
Pulse Recorders For Electricity Metering

ANSI C12.18 - American National Standard For Protocol Specification For ANSI
Type 2 Optical Port

Part B

PARTICIPATING SELLERS METER STANDARDS AND CAPABILITIES