

Stakeholder Comments Template

Flexible Resource Adequacy Criteria and Must-Offer Obligation

Submitted by	Company	Date Submitted
Will Mitchell wmitchell@cpv.com (240) 893-6201	CPV	May 28, 2014

CPV respectfully submits the following recommendation for the Draft Tariff Language:

To reconcile the permitted monthly operating limitations, based on 30-day maximum emit potential and, requirements of 2 or 1 start[s] per day, unencumbered by annual or monthly operating limitations, facilities capable of 60 or 30 starts times in a given month should be considered capable of starting 2 or 1 times per day, for the purposes of qualifying for a given category.