

Good morning,

-In regards to the San Diego – Imperial Valley area potential LCR reduction options, was a parallel El Centro 230:92kV transformer to the existing transformer considered in lieu of the series reactors on the S-line?

-What was the next most limiting facility found beyond the El Centro 230:92kV transformer?

-What other LCR reduction options were analyzed but not considered due to cost-effectiveness in lieu of the 230kV S-line series reactors?

Thank you,

Jesus Martinez  
Imperial Irrigation District