

## July 27 2017 Exceptional Dispatch CPM Designation Report

### **Designation Summary:**

The California ISO issued an Exceptional Dispatch Capacity Procurement Mechanism (CPM) designation to ELCAJN\_6\_LM6K for a non-system reliability need. The designation is effective July 27, 2017 for a duration of 60 days

### **Duration and Cost:**

RESOURCE_ID	MW	ED Code	Accepted offer price
ELCAJN_6_LM6K	24.87	Local Reliability Issue	\$6.31/kW-month

### **Reason for CPM:**

The ISO issued an Exceptional Dispatch CPM designation to ELCAJN\_6\_LM6K to address an Exceptional Dispatch Non-System Reliability Need. The Exceptional Dispatch was issued to address a potential thermal overload on a 69 kV line in the San Diego Area for the next contingency event. The designation amount reflects the minimum amount of capacity the ISO could designate to mitigate the reliability need posed by the potential thermal overload.

Prior CPM report information is available to download at:

<http://www.caiso.com/market/Pages/ReportsBulletins/Default.aspx>