Local Capacity Requirements (LCR) for Year 2009 Study Results for the Humboldt and North Coast/North Bay Areas



LCR Stakeholder Meeting, March 4th, 2008, Folsom CA



Paul Didsayabutra Senior Regional Transmission Engineer Planning and Infrastructure Development Department California Independent System Operator (CAISO)

### Humboldt and North Coast/North Bay Areas



# Humboldt Area Load and Resources (MW)

		2009
Load	=	200
Transmission Losses	=	7
Total Load	=	207
Market Generation	=	166
Muni Generation	=	0
QF/Self-Gen Generation	=	45
Total Qualifying Capacity	=	211



### **Humboldt Area - Overview**



### **Category B**

### **Critical Contingency**

Contingency of Humboldt 115/60 kV Transformer (#1 or #2)

#### **Limitation**

Thermal overload on the parallel transformer that still in-service

#### **Local Capacity Requirement**

LCR of 141 MW (including 45 MW of QF/Self generation). The requirement for the market units refers to units on the 60 kV side only.



### **Category** C

### **Critical Contingency**

Contingency of Humboldt 115/60 kV Transformer (#1 or #2) and one unit of the new 60 kV Humboldt Bay Power Plant

#### **Limitation**

6

Thermal overload on the parallel transformer that still in-service

#### **Local Capacity Requirement**

LCR of 155 MW (including 45 MW of QF/Self generation as well as 3 MW of Deficiency). The requirement for the market units refers to units on the 60 kV side only.



# Summary of the Requirements

	<b>Existing Generation</b>	Deficiency	Total MW
	Capacity Needed (MW)	(MW)	Requirement
Category B	141	0	141
Category C	152	3	155

# Changes since the 2008 LCR study

### The Humboldt Bay Re-Powering Project is modeled in the study

This project replaces the existing Humboldt Bay Power Plant with a new 166 MW Power Plant

\*Only units connected to the 60 kV side will mitigate the problem



# North Coast/North Bay Load and Resources (MW)

- - - -

		2009
Load	=	1530
Transmission Losses	=	66
Total Load	=	1596
Market Generation	=	621
Muni Generation	=	128
QF Generation	=	134
Total Qualifying Capacity	=	883



### North Coast / North Bay - Overview





### **Eagle Rock Sub-Area**

**Category B** 

Critical Contingency: The outage of Cortina #4 230/115 kV transformer.

Limitation: Thermal overload on Fulton-Hopland 60 kV line

Local Capacity Requirement: 121 MW (includes 19 MW of QF generation)

### **Category C**

10

<u>Critical Contingency</u>: The outage of Eagle Rock-Silverado-Fulton 115 kV line followed by Cortina #4 230/115 kV transformer. <u>Limitation</u>: Thermal overload on Fulton-Hopland 60 kV line <u>Local Capacity Requirement</u>: 237 MW (includes 19 MW of QF generation)

<sup>1</sup> LCR requirement for Eagle Rock pocket can be counted toward the requirement of Fulton pocket



### **Fulton Sub-Area**

#### **Category B**

No addition requirement (237 MW LCR in Eagle Rock is sufficient)

#### **Category C**

<u>Critical Contingency</u>: The outage of Lakeville-Ignacio 230 kV line #1 followed by Crockett-Sobrante 230 kV line #1

Limitation: Thermal overload on Fulton-Lakeville 230 kV line #1

Local Capacity Requirement<sup>1</sup>: 495 MW (includes 71 MW of QF and 62 MW of Muni generation).

<sup>1</sup> LCR requirement for Eagle Rock pocket can be counted toward the requirement of Fulton pocket



**Lakeville Sub-Area** (LCR requirement for the overall North Coast/North Bay area<sup>1</sup>)

**Category B** 

<u>Critical Contingency:</u> The outages of Vaca Dixon-Tullucay 230 kV

Limitation: Thermal overload on Vaca Dixon-Lakeville 230 kV line.

Local Capacity Requirement: 570 MW (includes 135 MW of QF and 129 MW of Muni generation).

### **Category** C

<u>Critical Contingency:</u> The outages of Vaca Dixon-Tullucay 230 kV line followed by Crockett-Sobrante 230 kV or vice versa.

Limitation: Thermal overload on Vaca Dixon-Lakeville 230 kV line.

Local Capacity Requirement: 839 MW (includes 135 MW of QF and 129 MW of Muni generation).

<sup>&</sup>lt;sup>1</sup> LCR requirement for Eagle Rock/Fulton pocket can be counted toward the requirement of Lakeville pocket

# **Revised Load Forecast**

The revised load forecast projects higher future demand in North Coast and North Bay area. This results in a slight increase of LCR in this area compare to the previous projection



# **Stakeholder Comments**



### Your comments and questions are welcome

For written comments, please send to: <u>RegionalTransmission@caiso.com</u>



