



California ISO  
Shaping a Renewed Future


# 2016 and 2020 Draft LCR Study Results - Greater Bay Area

Bryan Fong

Senior Regional Transmission Engineer


Stakeholder Meeting

March 9, 2015





# Greater Bay Area Transmission System



# New major transmission projects

- Contra Costa – Moraga 230 kV Line Reconductoring – 06/16
- East Shore-Oakland J 115 kV Reconductoring Project – 07/18
- Embarcadero-Potrero 230 kV Transmission Project – 04/16
- Evergreen-Mabury Conversion to 115 kV - 12/17
- Metcalf-Evergreen 115 kV Line Reconductoring – 05/19
- Metcalf-Piercy & Swift and Newark-Dixon Landing 115 kV Upgrade – 05/19
- Moraga Transformers Capacity Increase – 10/16
- Pittsburg – Tesla 230 kV Reconductoring – 10/15
- Tesla-Newark 230 kV Path Upgrade – 12/17
- Vaca Dixon-Lakeville 230 kV Reconductoring – 07/17

# Power plant changes

## Additions:

- Marsh Landing Generating Station
- Los Esteros Critical Energy Facility (LECEF) capacity increase
- Russel City
- Oakley (2020 only)

## Retirements:

- Contra Costa units #6 and #7
- GWF #1-5

# Bay Area Load and Resources (MW)

		<b>2016</b>	<b>2020</b>
Load	=	9,790	10,048
AAEE	=	-144	-369
Transmission Losses	=	173	188
Pumps	=	264	264
Total Load	=	<b>10,083</b>	<b>10,131</b>
Market Generation	=	6,243	6,900
Wind Generation	=	285	285
Muni Generation	=	519	519
QF Generation	=	485	485
Total Qualifying Capacity	=	<b>7,505</b>	<b>8,162</b>

# San Jose Sub Area

## **San Jose Sub-area – Category B**

Contingency: Metcalf-Evergreen #2 115 kV Line with Duane PP out of service

Limiting component: Thermal overload of Metcalf-Evergreen #1 115 kV Line

2016 LCR need: 265 MW (includes 61 MW of QF and 202 MW of generation)

2020 LCR need: no LCR need

## **San Jose Sub-area – Category C**

Contingency: Metcalf El Patio #1 or #2 overlapped with the outage of Metcalf-Evergreen #2 115 kV

Limiting component: Thermal overload of Metcalf-Piercy 115 kV Line

2016 LCR need: 687 MW (includes 61 MW of QF and 202 MW of generation as well as 135 MW of deficiency )

2020 LCR need: 522 MW (includes 263 MW of QF/Muni generation)

# Llagas Sub Area

## **Llagas Sub-area – Category B**

Contingency: Metcalf D-Morgan Hill 115 kV with one of the Gilroy peakers off line

Limiting component: 5% voltage drop at the Morgan Hill substation

2016 LCR need: 135 MW (includes 0 MW of QF/Muni generation)

2020 LCR need: 158 MW (includes 0 MW of QF/Muni generation)

## **Llagas Sub-area – Category C**

Same as Category B

# Oakland Sub Area

## **Oakland Sub-area – Category B**

Contingency: Moraga – Claremont #1 or #2 230 kV line with one Oakland CT off-line

Limiting component: Remaining Moraga – Claremont 230 kV line

2016 LCR need: No requirement

2020 LCR need: 161 MW (includes 49 MW of QF/Muni generation)

## **Oakland Sub-area – Category C**

Contingency: overlapping C-X #2 and C-X #3 115 kV cables

Limiting component: Thermal overload on the Moraga – Claremont #1 or #2 230 kV Line.

2016 LCR need: 92 MW (includes 49 MW of QF/Muni generation)

2020 LCR need: Not binding = Same as Category B

**This requirement does not include the need for the Pittsburg/  
Oakland sub-area**

# Pittsburg/Oakland Sub Area

## **Pittsburg/Oakland Sub-area – Category B**

Contingency: Moraga #3 230/115 kV Bank

Limiting component: Thermal overload on Moraga #1 230/115 kV Bank

2016 LCR need: 1188 MW (includes 369 MW of QF and 49 MW of Muni generation)

2020 LCR need: No requirement.

## **Pittsburg/Oakland Sub-area – Category C**

Contingency: Moraga #3 230/115 kV Bank and Delta Energy Center

Limiting component: Thermal overload on Moraga #1 230/115 kV Bank  
(400 MW of Trans Bay Cable run back has been used)

2016 LCR need: 2001 MW (includes 369 MW of QF and 49 MW of Muni generation)

2020 LCR need: No requirement.

# Pittsburg Sub Area

## **Pittsburg Sub-area – Category B**

2016 LCR need: Yes - Part of Pittsburg/Oakland sub-area

2020 LCR need: No requirement.

## **Pittsburg Sub-area – Category C**

2016 LCR need: Yes - Part of Pittsburg/Oakland sub-area

Contingency: Vaca-Dixon Lakeville & Vaca-Dixon Tulucay 230 kV lines

Limiting component: Thermal overload on Moraga-Sobrante 115 kV line

2020 LCR need: 1471 MW (includes 369 MW of QF generation)

# Ames Sub Area

## **Ames Sub-area – Category B**

2016 LCR need: No requirement.

2020 LCR need: No requirement.

## **Ames Sub-area – Category C**

Contingency: Newark-Ravenswood & Tesla-Ravenswood 230 kV lines

Limiting component: Overload of Newark-Ames #1, #2, #3 and Newark-Ames Distribution 115 kV lines

2016 LCR need: 586 MW (beyond Pittsburg/Oakland sub-area) (includes 0 MW of QF generation)

2020 LCR need: No requirements due to South of San Mateo Capacity Increase transmission project

# Contra Costa Sub Area

## **Contra Costa Sub-area – Category B**

Contingency: Kelso-Tesla 230 kV with the Gateway off line

Limiting component: Thermal overload on the Delta Switching Yard-  
Tesla 230 kV Line

2016 LCR need: 930 MW (includes 256 MW of Wind generation and  
264 MW of MUNI pumps)

2020 LCR need: 1354 MW (includes 256 MW of Wind generation  
and 264 MW of MUNI pumps)

## **Contra Costa Sub-area – Category C**

Same as Category B

# Greater Bay Area Overall

## **Bay Area Overall – Category B**

Contingency: Tesla-Metcalf 500 kV line with Delta Energy Center out of service

Limiting component: Reactive margin within the Bay Area

2016 LCR need: 3790 MW (includes 485 MW of QF, 519 MW of MUNI and 258 MW of wind generation)

2020 LCR need: 3820 MW (includes 485 MW of QF, 519 MW of MUNI and 258 MW of wind generation)

# Greater Bay Area Overall

## Bay Area Overall – Category C

2016 LCR need: Sum of Category C sub area requirements at 4339 MW (includes 485 MW of QF, 519 MW of MUNI and 258 MW of wind generation as well as 135 MW of deficiency)

Contingency: Tesla-Metcalf 500 kV line with Tesla-Newark #1 230 kV line

Limiting component: Tesla-Delta Switching Yard 230 kV line

2020 LCR need: 4191 MW (includes 485 MW of QF, 519 MW of MUNI and 258 MW of wind generation)

# Greater Bay Area

## Available Generation

Year	QF (MW)	Muni (MW)	Wind (MW)	Market (MW)	Max. Qualifying Capacity (MW)
2016	485	519	258	6243	7505
2020	485	519	258	6900	8162

## Total LCR need

	Existing Generation Capacity Needed (MW)		Deficiency (MW)		Total MW Need	
	2016	2020	2016	2020	2016	2020
Category B (Single)	3790	3820	0	0	3790	3820
Category C (Multiple)	4204	4191	135	0	4339	4191

# Changes

## Since last year:

- 1) 2016 load forecast is lower by 135 MW vs. 2015
- 2) Sum of sub-area LCR needs drive the Bay Area total requirement in 2016
- 3) LCR need has decreased by 28 MW vs. 2015 – due to a combination of load and new Ames sub-area requirements.
- 4) 2020 load forecast is lower by 189 MW vs. 2019
- 5) Added Generation: Oakley (2020 only)
- 6) Long-term LCR need has decreased by 33 MW vs. 2019

**Your comments and questions are welcome.**

**For written comments, please send to: [RegionalTransmission@caiso.com](mailto:RegionalTransmission@caiso.com)**