




2018 & 22 Draft LCR Study Results Humboldt Area

Irina Green


Senior Advisor, Regional Transmission North

Stakeholder Meeting

March 9, 2017




Humboldt and North Coast/North Bay



Humboldt Load and Resources (MW)

		2018	2022
Load	=	184	196
AAEE	=	-8	-17
Transmission Losses	=	11	11
Total Load	=	187	190
Market Generation	=	210	210
QF/Self-Gen Generation	=	20	20
Total Qualifying Capacity	=	230	230

Critical Contingencies Humboldt Area



Critical Contingencies Humboldt Area

Humboldt Overall – Single Contingency Winter Peak

Contingency: Cottonwood-Bridgeville 115 kV line + one Humboldt PP units out of service

Limiting component: Thermal overload on Humboldt -Trinity 115 kV line

2018 LCR Need: 121 MW (including 20 MW of QF/Self generation)

2022 LCR Need: 121 MW (including 20 MW of QF/Self generation)

Humboldt Overall – Double Contingencies Winter Peak

Contingency: Cottonwood – Bridgeville 115 kV line + Humboldt – Humboldt Bay 115kV line

Limiting component: Thermal overload on Humboldt -Trinity 115 kV line

2018 LCR need: 169 MW (including 20 MW of QF/Self generation)

2022 LCR need: 169 MW (including 20 MW of QF/Self generation)

Changes

Since last year:

- 1) Load went down by 1 MW in 2018 compared with 2017
- 2) LCR need increased by 12 MW in 2018 compared to 2017 due to different limiting contingency.
- 3) Load went down by 5 MW in 2022 compared with 2021
- 4) LCR need remained the same in 2022 compared to 2021.

Your comments and questions are welcomed

Please send written comments to:
RegionalTransmission@caiso.com