



Flexible Capacity Needs and Availability Assessment Hours Technical Study for 2020

Clyde Loutan
Principal, Renewable Energy Integration

Hong Zhou
Market Development Analyst, Lead

Amber Motley
Manager, Short Term Forecasting

April 4th, 2019

What's the purpose of this call?

To discuss the assumptions, methodology, and draft results of the monthly flexible capacity requirement and Availability Assessment Hours Technical Study.

Specifically

Calculating requirements for all LRAs within the ISO footprint for RA compliance year 2020 and advisory flexible capacity requirements for compliance years 2021 and 2022

Agenda / Overview

- Background
- Process review
 - Expected build out from all LSEs (CPUC jurisdictional and non-jurisdictional)
 - Load, wind and solar profiles
 - Calculate 3-hour net load upward ramps
 - Add contingency reserves
 - Calculate monthly Flexible Capacity requirement
- Overview of methodology used for system/local availability assessment hours
 - 2020 availability assessment hours
 - 2021-2022 draft availability assessment hours

Each LSE Scheduling Coordinator shall make a year-ahead and month-ahead showing of flexible capacity for each month of the compliance year


Resource Adequacy (RA)

- Ensure LSEs contract for adequate capacity to meet expected flexible needs
- Year ahead: LSEs need to secure a minimum of 90% of the next years monthly needs
- Month ahead: LSEs need to secure adequate net qualified capacity to serve their peak load including a planning reserve margin and flexible capacity to address largest 3-hour net load ramps plus contingency reserves
- All resources participating in the ISO markets under an RA contract will have an RA must-offer-obligation
- Required to submit economic bids into the ISO's real-time market consistent with the category of flexible capacity


The ISO used the following data to determine the flexible capacity

- CEC's "1-in-2" Mid-hourly demand forecast for 2020 through 2022
 - Behind-the-meter hourly solar PV production
 - Hourly AAEE
- LSE SCs updated renewable build-out for 2018 through 2022
- The data included:
 - Installed capacity by technology and expected operating date (e.g. Solar thermal, solar PV tracking, solar PV non-tracking, estimate of behind-the-meter solar PV etc.) for all variable energy resources under contract
 - Operational date or expected on-line date
 - Location of CREZ latitude and longitude coordinates
 - Resources located outside ISO's BAA indicated if the resources are firmed or non-firmed


CEC (mid baseline, mid AAEE) projected 1-in-2 CAISO coincident peak forecast




Solar & wind build-out through December 2022





Firmed and non-firmed out of state contracted solar & wind through December 2022



Non-firmed out-of-state contracted renewables through December 2022



LSEs estimate of behind-the-meter solar PV capacity & CEC's estimated production through 2022







The ISO flexibility capacity assessment is based on current LSE's RPS build-out data

- Used the most current data available for renewable build-out submitted by all LSE SCs
- For new renewable installation scale 2018 actual production data based on installed monthly capacity in subsequent years
- Generated net load profiles for 2020 through 2022 using the simulated:
 - Load profiles for 2020 through 2022
 - Solar profiles for 2020 through 2022
 - Wind profiles for 2020 through 2022

The ISO will use the CEC's 1-in-2 IEPR forecast to develop the load forecast

- The ISO uses “1-in-2” IEPR forecast; the IEPR forecast has both an hourly view and a monthly view.
 - The forecast is correlated such that the peak of the month can be seen in the hourly profile.
- CEC IEPR Load Forecast
 - https://www.energy.ca.gov/2018_energy_policy/documents/index.html
 - Title of File: “Corrected CAISO Hourly Results CEDU 2018-2022”
 - The ISO will be using column AR (Managed Total Energy for Load) within the spreadsheet.
 - Managed Total Energy for Load =
 - + Baseline Consumption Load
 - Committed PV Generation
 - Additional achievable PV generation
 - AAEE
 - POU AAEE

Smoothing 2020 1-minute load profile



Hourly load forecast to 1-minute load forecast

- Used 2018 actual 1-minute load data to build 1-minute load profiles for subsequent years
- Scaled the hourly CEC load forecast value of each hour into 1-minute forecast data using a smoothing equation looking at the differences between the forecasted year and the 2018 1-minute actuals.

2020 Load 1-Minute Forecast

$$- \text{2020 } L_{\text{CECfcst_1-min}} = \text{2018 } L_{\text{Act_1-min}} + X$$

- Where X = Interpolated 1min profile from the difference

$$(\text{2020 } L_{\text{CECfcst_hourly}} - \text{2018 } L_{\text{actual_hourly}})$$

2021 Load 1-Minute Forecast

$$- \text{2021 } L_{\text{CECfcst_1-min}} = \text{2018 } L_{\text{Act_1-min}} + X$$

- Where X = Interpolated 1min profile from the difference

$$(\text{2021 } L_{\text{CECfcst_hourly}} - \text{2018 } L_{\text{actual_hourly}})$$

Solar growth assumptions through 2022

- Used the actual solar 1-minute solar production data for 2018 to develop the 1-minute solar profiles for 2019 through 2022
- Scaled 1-minute solar data using the forecast monthly solar capacity for the new plants scheduled to be operational in 2019
- Repeated the above steps for 2020, 2021 & 2022

$$2019 S_{\text{Mth_Sim_1-min}} = 2018 S_{\text{Act_1-min}} * 2019 S_{\text{Mth Capacity}} / 2018 S_{\text{Mth Capacity}}$$

$$2020 S_{\text{Mth_Sim_1-min}} = 2018 S_{\text{Act_1-min}} * 2020 S_{\text{Mth Capacity}} / 2018 S_{\text{Mth Capacity}}$$

$$2021 S_{\text{Mth_Sim_1-min}} = 2018 S_{\text{Act_1-min}} * 2021 S_{\text{Mth Capacity}} / 2018 S_{\text{Mth Capacity}}$$

$$2022 S_{\text{Mth_Sim_1-min}} = 2018 S_{\text{Act_1-min}} * 2022 S_{\text{Mth Capacity}} / 2018 S_{\text{Mth Capacity}}$$

Net-load is a NERC accepted metric¹ for evaluating additional flexibility needs to accommodate VERs

- Net load is defined as load minus wind and solar power production
- Net load variability increases as more and more wind and solar resources are integrated into the system
- The monthly 3-hour flexible capacity need equates to the largest upward change in net load when looking across a rolling 3-hour evaluation window
- The ISO dispatches flexible resources (including renewable resources with energy bids) to meet net load

¹ NERC Special Report


Flexibility Report Requirements and metrics for Variable Generation: Implications for System Planning Studies, August 2010 . http://www.nerc.com/files/IVGTF_Task_1_4_Final.pdf

The monthly 3-hour upward ramping need is calculated using the largest ramp in each 180 minute period

- The maximum monthly 3-hour net load ramp within a 3-hour period is the highest MW value reached within any 3-hour moving window
- The maximum net load change in 3-hours can occur in less than 3 hours
- The maximum 3-hour upward ramp was calculated as:

$\text{Net Load}_{181 \text{ min}} - \text{Net Load}_1, \text{Net Load}_{182 \text{ min}} - \text{Net Load}_2, \dots, \text{Net Load}_{n+180 \text{ min}} - \text{Net Load}_n$

Maximum monthly 3-hour upward net load ramps for 2018 through 2022



*Please note Actuals in this graph may have solar/wind curtailments present

The flexible capacity methodology should provide the ISO with sufficient flexible capacity

Methodology

$$\text{Flexible Req}_{MTH_y} = \text{Max}[(3RR_{HR_x})_{MTH_y}] + \text{Max}(\text{MSSC}, 3.5\% * E(\text{PL}_{MTH_y})) + \epsilon$$

Where:

$\text{Max}[(3RR_{HR_x})_{MTH_y}]$ = Largest 3-hour contiguous ramp starting in hour x for month y

$E(\text{PL})$ = Expected peak load


MTH_y = Month y

MSSC = Most Severe Single Contingency

ϵ = Annually adjustable error term to account for load forecast errors and variability. ϵ is currently set at zero


For next year the ISO will work towards changing the Flex RA standard to be reflective of the current WECC/NERC reliability requirements.

Maximum monthly 3-hour upward flexible capacity needs for 2020 through



*Please note Actuals in this graph may have solar/wind curtailments present


Example of the recommended monthly 2018 upward 3-hour ramps using 2016 actual 1-minute data




*Please note Actuals in this graph may have solar/wind curtailments present

The actual net load and 3-hour ramps are about four years ahead of the ISO's original estimate primarily due to under forecasting rooftop solar PV installation

Typical Spring Day



The 3-hour upward ramps are more than 50% of the daily peak demand, which indicates the need for faster ramping resources






Preliminary Results

Hong Zhou.
Market Development Analyst, Lead

Amber Motley
Manager, Short Term Forecasting

Forecasted monthly 2020 ISO system-wide flexible capacity needs*

Forecasted monthly 2020 ISO system-wide flexible capacity needs*



*Flexibility Requirement_{MTHy} = Max[(3RR_{HRx})_{MTHy}] + Max(MSSC, 3.5%*E(PL_{MTHy})) + ε

Components of the flexible capacity needs

Month	Average of Load contribution 2020	Average of Wind contribution 2020	Average of Solar contribution 2020	Total percent 2020
January	43.11%	-1.61%	-55.28%	100%
February	39.86%	4.63%	-64.76%	100%
March	30.70%	-4.79%	-64.51%	100%
April	32.26%	-0.46%	-67.28%	100%
May	31.36%	-2.56%	-66.08%	100%
June	26.46%	-4.83%	-68.71%	100%
July	15.30%	2.43%	-87.13%	100%
August	24.06%	-1.89%	-74.05%	100%
September	27.26%	-1.36%	-71.39%	100%
October	34.39%	-1.57%	-64.04%	100%
November	38.87%	-5.43%	-55.69%	100%
December	44.27%	-0.94%	-54.80%	100%


$$\Delta \text{ Load} - \Delta \text{ Wind} - \Delta \text{ Solar} = 100$$

Flexible capacity categories allow a wide variety of resources to provide flexible capacity


- Category 1 (Base Flexibility): Operational needs determined by the magnitude of the largest 3-hour secondary net load ramp
- Category 2 (Peak Flexibility): Operational need determined by the difference between 95 percent of the maximum 3-hour net load ramp and the largest 3-hour secondary net load ramp
- Category 3 (Super-Peak Flexibility): Operational need determined by five percent of the maximum 3-hour net load ramp of the month

The 2020 forecasted distribution range of daily maximum and secondary 3-hour net load ramps

Distribution of daily second 3-hour net load ramps




Distribution of daily max 3-hour net load ramps



Seasonal breakout of flexible capacity needs


Month	Unadjusted			Adjusted		
	Base Flexibility	Peak Flexibility	Super-Peak Flexibility	Base Flexibility	Peak Flexibility	Super-Peak Flexibility
January	37%	58%	5%	35%	60%	5%
February	38%	57%	5%	35%	60%	5%
March	34%	61%	5%	35%	60%	5%
April	34%	61%	5%	35%	60%	5%
May	44%	51%	5%	52%	43%	5%
June	43%	52%	5%	52%	43%	5%
July	63%	32%	5%	52%	43%	5%
August	57%	38%	5%	52%	43%	5%
September	51%	44%	5%	52%	43%	5%
October	37%	58%	5%	35%	60%	5%
November	31%	64%	5%	35%	60%	5%
December	34%	61%	5%	35%	60%	5%

Total flexible capacity needed in each category – seasonally adjusted



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
■ Super-Peak Flexibility	939	940	905	886	830	796	667	797	848	908	932	903
■ Peak Flexibility	11,303	11,312	10,885	10,659	7,190	6,890	5,780	6,900	7,342	10,924	11,209	10,862
■ Base Flexibility	6,545	6,551	6,303	6,173	8,584	8,226	6,901	8,238	8,766	6,326	6,491	6,290

CPUC jurisdictional flexible capacity allocation - by flexible capacity category



Start time of 3-Hour net load ramp to evaluate seasonal must offer obligations

Month	3-Hour Net Load Ramp Start Hour (Hour Ending)			
	15:00	16:00	17:00	18:00
January	31			
February	18	10		
March	4	10	17	
April		3	26	1
May		3	21	7
June			27	3
July	1	3	27	
August		19	12	
September	2	28		
October	3	28		
November	30			
December	31			

Seasonal must offer obligations for peak and super-peak flexible capacity

- Recommended Must-offer obligation hours in Hour Ending.
 - HE 16- HE 20 (3:00 PM to 8:00 PM) January through April and October through December
 - HE 16– HE 20 (3:00 PM to 8:00 PM) May through September

Review of preliminary assessment results

- Flexible Capacity need is largest in the off-peak months
 - Flexible capacity makes up a greater percentage of resource adequacy needs during the off-peak months
 - Increase almost exclusively caused by 3-hour ramp, not increase in peak load
- Growth of behind-the-meter solar PV and utility scale PV contributes to the larger flexible capacity requirements
- Using the ISO flexible capacity contribution calculation majority of 3-hour net load ramps are attributable to CPUC jurisdictional LSEs
- The Peak and Super-Peak MOO hours have not changed from the 2019 study (information below is in Hour Ending)
 - January through April and October through December: HE 16- HE 20 (3:00 p.m. to 8:00 p.m.)
 - May through September: HE 16 – HE 20 (3:00 p.m. to 8:00 p.m.)



Allocation to SC

Hong Zhou.
Market Development Analyst, Lead

Amber Motley
Manager, Short Term Forecasting

Notation

- Notation :
 - L (load), W (wind), S (solar), and NL(net load)
 - R (reserve) = $\max(\text{MSCC}, 3.5 * \text{peak_load})$
 - $\text{NL} = \text{L} - \text{W} - \text{S}$
 - $\Delta \text{Ramp}, \Delta \text{NL} = \Delta \text{L} - \Delta \text{W} - \Delta \text{S}$
 - ΔNL_{2020} Net Load Ramp Req in 2020
 - $\Delta \text{NL}_{sc,2020}$ Net Load Ramp Req SC Allocation in 2020
 - Σ summation of all SC
 - 2020 forecast (L) and survey results (W and S);
 - 2018 Load observed
 - $pl_{r_{sc}}$ CEC peak load ratio
- The history of load allocation formula evolution is detailed in the draft paper

Allocation Formula

$$\begin{aligned} \text{Flax Requirement} &= \Delta NL_{2020} + R_{2020} \\ &= \Delta NL_{2020} + \Sigma pl_{r_{sc}} * R_{2020} \end{aligned}$$

$$\begin{aligned} \Delta NL_{2020} &= \Delta L_{2020} - \Delta W_{2020} - \Delta S_{2020} \\ &= \Delta L_{2020} - \frac{\Sigma W_{sc,2020}}{W_{2020}} * \Delta W_{2020} - \frac{\Sigma S_{sc,2020}}{S_{2020}} * \Delta S_{2020} \end{aligned}$$

Now, Focusing on allocating ΔL_{2020}

Allocation load proportion to SC

- $$\begin{aligned}\Delta L_{2020} &= \Delta L_{2018} + (\Delta L_{2020} - \Delta L_{2018}) \\ &= \Sigma \Delta L_{sc,2018} + \frac{\Sigma L_{sc,2018}^M}{L_{2018}^M} * (\Delta L_{2020} - \Delta L_{2018})\end{aligned}$$
- ΔL_{2018} is the average load portion of top 5 maximum 2018 3h ramps while matching 2020 maximum 3h ramp on month and time, and L_{2018}^M is the average load at beginning and the end of points during those top 5 ramps.
- The subscript SC is for LSC, Δ and Σ is the mathematic notation for difference and summation, Δ is denoted for the ramp here.
- Therefore, each SC will receive:

$$\Delta L_{sc,2018} + \frac{L_{sc,2018}^M}{L_{2018}^M} * (\Delta L_{2020} - \Delta L_{2018})$$

AVAILABILITY ASSESSMENT HOURS





Availability assessment hours: Background and purpose

- Concept originally developed as part of the ISO standard capacity product (SCP)
 - Maintained as part of Reliability Service Initiative – Phase 1 (i.e. RA Availability Incentive Mechanism, or RAAIM)
- Determine the hours of greatest need to maximize the effectiveness of the availability incentive structure
 - Resources are rewarded for availability during hours of greatest need
 - Hours determined annually by ISO and published in the BPM
 - See section 40.9 of the ISO tariff



Methodology overview of system/local availability assessment hours

- Used data described in previous slides to obtain:
 - Hourly Average Load
 - By Hour
 - By Month
 - Years 2020-2022
- Calculated:
 - Top 5% of Load Hours within each month using an hourly load distribution
 - Years 2020 through 2022

Expected load shape evolution: Summer season




Expected load shape evolution: Summer season





Summer Season

2020 top 5% of load hours (in HE)




Summer Season: Top 5% Hour Ending



Expected load shape evolution: Winter season




Expected load shape evolution: Winter season



Winter Season

2020 top 5% of load hours (HE)

Winter Season: Top 5% Hour Ending



Availability assessment hours draft recommendation

Winter Season Draft Recommendation

Year	Start	End
2019 (Final)	HE 17	HE 21
2020 (Draft)	HE 17	HE 21
2021 (Estimate)	HE 17	HE 21
2022 (Estimate)	HE 17	HE 21

Summer Season Draft Recommendation

Year	Start	End
2019 (Final)	HE 17	HE 21
2020 (Draft)	HE 17	HE 21
2021 (Estimate)	HE 17	HE 21
2022 (Estimate)	HE 17	HE 21

Reliability Requirements; Section 7 –No BPM Updates Needed

2019 System and Local Resource Adequacy Availability Assessment Hours

Analysis employed: Top 5% of load hours using average hourly load

Summer – April 1 through October 31

Availability Assessment Hours: 4pm – 9pm (HE17 – HE21)

Winter – November 1 through March 31

Availability Assessment Hours: 4pm – 9pm (HE17 – HE21)

2019 Flexible Resource Adequacy Availability Assessment Hours and must offer obligation hours

Flexible Type	RA Capacity	Category Designation	Required Hours (All Hour Ending Times)	Bidding Hours Ending	Required Bidding Days
January – April					
October – December					
Base Ramping		Category 1	05:00am to 10:00pm (HE6-HE22)	10:00pm	All days
Peak Ramping		Category 2	3:00pm to 8:00pm (HE16-HE20)	8:00pm	All days
Super-Peak Ramping		Category 3	3:00pm to 8:00pm (HE16-HE20)	8:00pm	Non-Holiday Weekdays*
May – September					
Base Ramping		Category 1	05:00am to 10:00pm (HE6-HE22)	10:00pm	All days
Peak Ramping		Category 2	3:00pm to 8:00pm (HE16-HE20)	8:00pm	All days
Super-Peak Ramping		Category 3	3:00pm to 8:00pm (HE16-HE20)	8:00pm	Non-Holiday Weekdays*

Next steps

- Published Draft Flexible Capacity Needs Assessment for 2019 – April 4, 2019
 - ~~Stakeholder call April 4, 2019~~
 - Comments due April 19, 2019
 - Please submit comments on the assumptions to initiativecomments@caiso.com
- Publish Final Flexible Capacity Needs Assessment for 2019 –
May 15th, 2019

Questions
