




# Draft Flexible Capacity Needs Assessment for 2018

Clyde Loutan  
Principal, Renewable Energy Integration

Karl Meeusen, PhD  
Senior Advisor, Infrastructure Policy

April 6, 2017



# What's the purpose of this call?

To discuss the assumptions, methodology and results of the monthly flexible capacity requirement

## **Specifically**

Calculating requirements for all LRAs within the ISO footprint for RA compliance year 2018 and advisory flexible capacity requirements for compliance years 2019 and 2020

# Agenda / Overview

- Background
- Process review
  - Expected build out from all LSEs (CPUC jurisdictional and non-Jurisdictional)
  - Load, wind and solar profiles
  - Calculate 3-hour net-load ramps
  - Add contingency reserves
  - Calculate monthly Flexible Capacity requirement
  - Next steps

Each LSE Scheduling Coordinator shall make a year-ahead and month-ahead showing of flexible capacity for each month of the compliance year

## Resource Adequacy (RA)


- Ensure LSEs contract for adequate capacity to meet expected flexible needs
- Year ahead: LSEs need to secure a minimum of 90% of the next years monthly needs
- Month ahead: LSEs need to secure adequate net qualified capacity to serve their peak load including a planning reserve margin and flexible capacity to address largest three hour net load ramps plus contingency reserves
- All resources participating in the ISO markets under an RA contract will have an RA must-offer-obligation
- Required to submit economic bids into the ISO's real-time market consistent with the category of flexible capacity

# What data did the ISO collect?


- CEC's monthly demand forecast (e.g. 2017-20 demand forecast)
- LSE SCs updated renewable build-out for 2016 through 2020
- The data included:
  - Installed capacity by technology and expected operating date (e.g. Solar thermal, solar PV tracking, solar PV non-tracking, estimate of behind-the-meter solar PV etc.) for all variable energy resources under contract
  - Operational date or expected on-line date
  - Location of CREZ latitude and longitude coordinates
  - Resources located outside ISO's BAA indicated if the resources are firmed or non-firmed

# Renewable build-out through December 2020


Expected Renewable Build-Out through 2020




# Out of state renewable imports through December 2020



# Firmed and non-firmed out of state imports through December 2020




# Behind the meter solar PV build-out through 2020



# Projected 1 in 2 CAISO coincident peak, CEC Planning Forecast (Mid Baseline, Mid AEE)

## CEC Planning Monthly Forecast for 2017 through 2020 vs. 2016 Actuals



# The ISO flexibility capacity assessment is based on current LSE's RPS build-out data

- Uses most current data available for renewable build-out obtained from all LSE SCs
- For new renewable installation scale 2016 actual production data based on installed capacity in subsequent years
- For new BTM use NEXANT production data located in close geographic proximity
- Generate net-load profiles for 2017 through 2020
  - Generate load profiles for 2017 through 2020
  - Generate solar profiles for 2017 through 2020
  - Generate wind profiles for 2017 through 2020

# The ISO used the CEC's 1-in-2 monthly peak load forecast to develop the load forecast

- Used 2016 actual 1-minute load data to build 1-minute load profiles for 2017 through 2020
- Scaled the actual 1-minute load value of each month of 2016 using a load growth factor of monthly peak forecast divided by actual 2016 monthly peak

## ***2017 Load Growth Assumptions***

- Scale the actual 1-minute load value of each month of 2016 by the fraction  $(\text{Monthly}_{2017\_Peak\_Load\_Forecast} / \text{Monthly}_{2016\_Actual\_Peak\_Load})$

## ***2018 Load Growth Assumptions***

- Scale each 1-minute load data point of 2017 by the fraction  $(\text{Monthly}_{2018\_Peak\_Load\_Forecast} / \text{Monthly}_{2016\_Peak\_Load})$

## ***2019 Load Growth Assumptions***

- Scale each 1-minute load data point of 2018 by the fraction  $(\text{Monthly}_{2019\_Peak\_Load\_Forecast} / \text{Monthly}_{2016\_Peak\_Load})$

1-minute behind the meter solar PV data was developed using the methodology outlined below

**TRACK I DIRECT TESTIMONY OF MARK ROTHLEDER ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR CORPORATION (Rulemaking 10-05-006)**

**Located at:**

[https://www.caiso.com/Documents/2011-08-10\\_ErrataLTPPTestimony\\_R10-05-006.pdf](https://www.caiso.com/Documents/2011-08-10_ErrataLTPPTestimony_R10-05-006.pdf)

# Wind growth assumptions

- Use actual 1-minute wind production data for the most recent year e.g. 2017 wind forecast uses actual production data from 2016
- Projects installed in 2016 were modeled in 2017 for the months the projects were not yet in-service in 2016 (e.g. projects installed in May 2016 was included in January through April of 2017)
- Scale 1-minute data using expected capacity for the new plants scheduled to be operational in 2017
- Repeat the above steps for 2018, 2019 & 2020

$$2017 W_{\text{Mth\_Sim\_1-min}} = 2016W_{\text{Act\_1-min}} * 2017W_{\text{Mth Capacity}} / 2016W_{\text{Mth Capacity}}$$

$$2018 W_{\text{Mth\_Sim\_1-min}} = 2016W_{\text{Act\_1-min}} * 2018W_{\text{Mth Capacity}} / 2016W_{\text{Mth Capacity}}$$

$$2019 W_{\text{Mth\_Sim\_1-min}} = 2016W_{\text{Act\_1-min}} * 2019W_{\text{Mth Capacity}} / 2016W_{\text{Mth Capacity}}$$

$$2020 W_{\text{Mth\_Sim\_1-min}} = 2016W_{\text{Act\_1-min}} * 2020W_{\text{Mth Capacity}} / 2016W_{\text{Mth Capacity}}$$

# Solar growth assumptions

## ***Existing solar***

- Use the actual solar 1-minute production data for the most recent year  
e.g. 2017 forecast uses 2016 actual 1-minute data (**2016<sub>Act\_1-min</sub>**)

## ***New solar installation***

- Develop 1-minute solar production profiles by scaling actual 2016 1-minute data by the monthly installed capacity in 2017 divided by the monthly installed capacity in 2016
- Projects installed in 2016 were modeled in 2017 for the months the projects were not yet in-service

$$\text{Total solar } 2017_{1\text{-min}} = 2016_{\text{Act}_1\text{-min}} * 2017_{\text{Monthly}_1\text{-min}} / 2016_{\text{Installed\_Capacity}}$$

# Net-load is a NERC accepted metric<sup>1</sup> for evaluating additional flexibility needs to accommodate VERs

- Net load is the aggregate of customer demand reduced by variable generation power output
- Net-load is more variable than load itself and it increases as VER production increases
- The monthly three-hour flexible capacity need equates to the largest up-ward change in net-load when looking across a rolling three-hour evaluation window
- The ISO dispatches flexible resources to meet net-load

<sup>1</sup> NERC Special Report


Flexibility Report Requirements and metrics for Variable Generation: Implications for System Planning Studies, August 2010 . [http://www.nerc.com/files/IVGTF\\_Task\\_1\\_4\\_Final.pdf](http://www.nerc.com/files/IVGTF_Task_1_4_Final.pdf)

# The monthly 3-hour upward ramping need is calculated using the largest ramp in each 180 minute period

- The maximum monthly three-hour net load ramp within a three-hour period is the highest MW value reached within any three-hour moving window
- The maximum net-load change in three-hours can occur in less than three hours
- The maximum 3-hour upward ramp was calculated as:


$\text{Net Load}_{181} - \text{Net Load}_1, \text{Net Load}_{182} - \text{Net Load}_2, \dots, \text{Net Load}_{n+180} - \text{Net Load}_n$

# Maximum monthly three-hour upward net-load ramps for 2016 through 2019



# Actual net-load and 3-hour ramps are approximately 4 years ahead of the original estimate

## Typical Spring Day



# Contingency reserves is a NERC/WECC requirement

## BAs must have available in real-time

- Each Balancing Authority and each Reserve Sharing Group shall maintain a minimum amount of Contingency Reserve, except within the first sixty minutes following an event requiring the activation of Contingency Reserve
- To meet WECC and NERC reliability criteria, the ISO must have contingency reserves equal to the greater of:
  - 1) the most severe single contingency (“MSSC”)
  - 2) the sum of 3% of hourly integrated load plus 3% percent of hourly integrated generation
- 50% of the contingency reserve must be spinning reserve
- Contingencies can occur during ramps and the ISO must be prepared to dispatch contingency reserve to recover its Area Control Error (ACE) within 15-minutes following a disturbance
- Contingency reserves are held for contingency events and cannot be dispatched to meet day-to-day net-load ramps

For more information please refer to: WECC Standard BAL-002-WECC-2---Contingency Reserve

# Preliminary Results

Karl Meeusen, Ph.D.  
Senior Advisor – Infrastructure Policy

# The proposed interim flexible capacity methodology designed to provide the ISO with sufficient flexible capacity

- Methodology

$$\text{Flexibility Requirement}_{MTHy} = \text{Max}[(3RR_{HRx})_{MTHy}] + \text{Max}(\text{MSSC}, 3.5\% * E(\text{PL}_{MTHy})) + \varepsilon$$

Where:

$\text{Max}[(3RR_{HRx})_{MTHy}]$  = Largest three hour contiguous ramp starting in hour x for month y

$E(\text{PL})$  = Expected peak load

$MTHy$  = Month y

$\text{MSSC}$  = Most Severe Single Contingency

$\varepsilon$  = Annually adjustable error term to account for load forecast errors and variability

## Flexible capacity requirement is split into its two component parts to determine the allocation

- The largest 3-hour net-load ramp is decomposed into four components to determine the LRA's allocation

Three hour net load ramp =


$\Delta \text{Load} - \Delta \text{Wind Output} - \Delta \text{Solar PV} - \Delta \text{BTM Solar}$

- Maximum of the Most Severe Single Contingency or 3.5 percent of forecasted coincident peak
  - Allocated to LRA based on peak-load ratio share

# Contributions to the three hour net load ramp: Load, wind, grid scale solar, incremental behind the meter solar

	3-hour net load ramp 2018	3.5% expected peak load 2018	Flexible Capacity Requirement 2018	Average of Load contribution 2018	Average of solar PV contribution 2018	Average of BTM Solar contribution 2018	Average of Wind contribution 2018	Total percent 2018
January	12,282	1,133	13,415	40%	-56%	-5%	1%	100%
February	13,313	1,096	14,409	39%	-54%	-5%	-3%	100%
March	12,352	1,082	13,435	32%	-60%	-8%	-1%	100%
April	11,111	1,161	12,272	21%	-71%	-9%	1%	100%
May	11,803	1,292	13,095	15%	-72%	-7%	-6%	100%
June	10,039	1,458	11,497	9%	-80%	-10%	-1%	100%
July	9,326	1,582	10,908	6%	-83%	-12%	1%	100%
August	9,617	1,602	11,219	11%	-87%	-12%	10%	100%
September	12,660	1,588	14,248	16%	-73%	-10%	0%	100%
October	12,954	1,317	14,271	21%	-65%	-10%	-4%	100%
November	13,376	1,129	14,505	28%	-60%	-10%	-2%	100%
December	14,567	1,176	15,743	42%	-48%	-6%	-3%	100%

# Forecasted monthly 2018 ISO system-wide flexible capacity needs\*



$$*Flexibility Requirement_{MTHy} = \text{Max}[(3RR_{HRx})_{MTHy}] + \text{Max}(MSSC, 3.5\% * E(PL_{MTHy})) + \epsilon$$

$$\epsilon = 0$$

# Flexible capacity categories allow a wide variety of resources to provide flexible capacity


- Category 1 (Base Flexibility): Operational needs determined by the magnitude of the largest 3-hour secondary net-load ramp
- Category 2 (Peak Flexibility): Operational need determined by the difference between 95 percent of the maximum 3-hour net-load ramp and the largest 3-hour secondary net-load ramp
- Category 3 (Super-Peak Flexibility): Operational need determined by five percent of the maximum 3-hour net-load ramp of the month

# Seasonal breakout of flexible capacity needs


Month	Actual Contributions			Seasonal Contribution		
	Base Flexibility	Peak Flexibility	Super-Peak Flexibility	Base Flexibility	Peak Flexibility	Super-Peak Flexibility
January	48%	47%	5%	39%	56%	5%
February	23%	72%	5%	39%	56%	5%
March	31%	64%	5%	39%	56%	5%
April	42%	53%	5%	39%	56%	5%
May	37%	58%	5%	55%	40%	5%
June	52%	43%	5%	55%	40%	5%
July	65%	30%	5%	55%	40%	5%
August	63%	32%	5%	55%	40%	5%
September	56%	39%	5%	55%	40%	5%
October	53%	42%	5%	39%	56%	5%
November	35%	60%	5%	39%	56%	5%
December	39%	56%	5%	39%	56%	5%

# Flexible capacity needs by category

## Total Unadjusted Flexible Capacity MW Need by Category



## Total Seasonally Adjusted Flexible Capacity Needed in Each Category




# Flexible capacity needs are largely attributable to change in output from solar resources

Month	Average of Load contribution 2018	Average of solar PV contribution 2018	Average of BTM Solar contribution 2018	Average of Wind contribution 2018
January	93.34%	92.01%	99.01%	87.43%
February	89.64%	92.06%	99.01%	87.31%
March	101.99%	92.07%	99.01%	87.32%
April	114.01%	92.12%	99.01%	87.23%
May	105.85%	92.12%	99.01%	87.16%
June	98.70%	92.12%	99.01%	87.11%
July	102.03%	92.12%	99.01%	87.01%
August	124.09%	92.12%	99.01%	87.02%
September	104.70%	92.28%	99.01%	87.08%
October	95.07%	92.28%	99.01%	87.22%
November	95.58%	92.28%	99.01%	87.23%
December	93.28%	92.39%	99.01%	87.15%

# Three categories of flexibility allow a variety of resource types to help address flexible capacity need

## Draft CPUC Flexible Capacity Allocation by Category



# Seasonal must offer obligations for peak and super-peak flexible capacity

Month	Frequency of All Three Hour Net Load Ramp Start						
	11:00	12:00	13:00	14:00	15:00	16:00	17:00
January				28	3		
February				15	14		
March					12	19	
April					2	16	12
May			1		2	13	15
June			1		1	22	6
July	1	2			5	23	
August			1	1	21	7	
September	1		1	4	17	7	
October				6	23	2	
November				25	5		
December			1	29	1		

- Must-offer obligation hours
  - 3:00 p.m. to 8:00 p.m. for May through September
  - 2:00 p.m. to 7:00 p.m. for January through April and October through December

# Review of preliminary assessment results

- Flexible Capacity need is largest in the off-peak months
  - Flexible capacity makes up a greater percentage of resource adequacy needs during the off-peak months
  - Increase almost exclusively caused by 3-hour ramp, not increase in peak load
- Inclusion of incremental behind-the-meter solar PV contributes to the larger flexible capacity requirements
- Compared to last year's forecast flexible capacity needs are high in many months,
- Using the ISO flexible capacity contribution calculation majority of three-hour net-load ramps are attributable to CPUC jurisdictional LSEs
- The Peak and Super-Peak MOO hours have changed from the 2017 study
  - January through April and October through December: 2:00 p.m. to 7:00 p.m.
  - May through September: 3:00 p.m. to 8:00 p.m.

# Next steps

- Published Draft Flexible Capacity Needs Assessment for 2017 – April 12, 2016
  - Stakeholder call April 6, 2017
  - **Comments due April 16, 2016**
    - Please submit comments on the assumptions to [initiativecomments@caiso.com](mailto:initiativecomments@caiso.com)
- Publish Final Flexible Capacity Needs Assessment for 2018 – **May 1, 2017**