

Western Energy Imbalance Market Resource Sufficiency Evaluation Metrics Report covering Q2 2024

August 1, 2024

Prepared by: Department of Market Monitoring

California Independent System Operator

1 Report summary

As part of the Western Energy Imbalance Market (WEIM) design, each balancing area is subject to a *resource sufficiency evaluation*. The evaluation is performed prior to each hour to ensure that generation capacity and flexibility in each area is sufficient without relying on transfers from other WEIM balancing areas. In this report, DMM provides additional information and analysis about resource sufficiency evaluation performance, accuracy, and impacts during the second quarter of 2024.

Report highlights

Resource sufficiency evaluation failures

• The frequency of capacity and flexibility test failures remained very low across most balancing areas for the quarter. Public Service Company of New Mexico (PNM) failed the upward flexibility test in around 1.4 percent of intervals. For all other balancing areas, failures for each test type and direction occurred in less than 1 percent of intervals.

Assistance energy transfers

- Seven balancing areas were opted in to assistance energy transfers (AET) during the second quarter. Five of these areas (Avangrid, Idaho Power, NorthWestern Energy, NV Energy, and PacifiCorp West) failed the resource sufficiency evaluation during at least one interval while opted in to the program, gaining access to additional WEIM supply that would not have been available otherwise. The other two areas (PacifiCorp East and the California ISO) did not fail the resource sufficiency evaluation while participating in the program.
- On April 8, a partial solar eclipse over most of the western United States impacted grid-scale solar and behind-the-meter rooftop solar across a number of WEIM balancing areas for several hours. The California ISO opted in to receiving assistance energy transfers on April 8 in preparation for the event. Idaho Power also opted into AET program for this day. All balancing areas passed the upward resource sufficiency evaluation during the eclipse period such that assistance energy transfers had no impact on procuring additional WEIM supply during this period.

Quantile regression approach for calculating uncertainty

- On April 4, the ISO implemented an enhancement to the regression-based calculation of uncertainty that increased the sample size of the historical distributions. Prior to this change, only a subset of historical forecast observations from the previous 180 days were used, depending on whether the current day was either a weekday or a weekend. This distinction by day-type was removed on April 4, increasing the sample size of the distributions, particularly on weekends. This change appears to have resulted in a slight improvement of the uncertainty calculation for weekends across most balancing areas.
- For the first two intervals of each hour, the regressions for calculating the uncertainty requirement for the group of balancing areas that pass the resource sufficiency evaluation must be performed before the final composition of balancing areas in this group are known. When the final composition of balancing areas in the pass-group differs, this can create swings in the calculated flexible ramping product uncertainty target. DMM has suggested that the ISO consider options to resolve this timing issue.

CAISO non-participating pump load

This report also highlights non-participating pump loads in the ISO balancing area that are not included in the ISO area resource sufficiency evaluation.

- Non-participating pump load is included in the ISO area real-time market requirement, but is not included in the resource sufficiency evaluation. This can contribute to conditions in which the ISO passes the resource sufficiency evaluation while an Energy Emergency Alert is issued (such as during July 2023).
- DMM continues to recommend that the ISO and stakeholders consider whether non-participating pump load should be included in the resource sufficiency evaluation. This would better align the conditions in the real-time market with the conditions considered in the resource sufficiency evaluation.

Organization of report

- <u>Section 2</u> summarizes the frequency and size of resource sufficiency evaluation failures.
- <u>Section 3</u> summarizes the use Assistance Energy Transfers.
- <u>Section 4</u> summarizes uncertainty used in the flexible ramp sufficiency test.
- <u>Section 5</u> summarizes demand-respond-based load adjustments used in the resource sufficiency evaluation.
- <u>Section 6</u> provides an overview of demand differences that can exist between the real-time market and resource sufficiency evaluation. CAISO non-participating pump load is included in the real-time market but not in the resource sufficiency evaluation.
- <u>Section 7</u> summarizes WEIM import limits and transfers following a resource sufficiency evaluation failure.
- <u>Appendix A</u> provides a technical overview of the flexible ramp sufficiency and bid range capacity tests.
- <u>Appendix B</u> provides an overview of the mosaic quantile regression method for calculating uncertainty.

DMM welcomes feedback on existing or additional metrics and analysis that WEIM entities and other stakeholders would find most helpful. Comments and questions may be submitted to DMM via email at <u>DMM@caiso.com</u>.

2 Frequency of resource sufficiency evaluation failures

This section summarizes the frequency and shortfall amount for bid-range capacity test and flexible ramping sufficiency test failures.¹ If a balancing area fails either (or both) of these tests, then transfers between that and the rest of the WEIM areas are limited.

Figure 2.1 through Figure 2.4 show the percent of 15-minute intervals in which each WEIM area failed the upward capacity or the flexibility tests, as well as the average shortfall of those test failures.² Figure 2.5 through Figure 2.8 provide the same information for the downward direction. The dash indicates that the area did not fail the test during the month.

In the second quarter:

- Public Service Company of New Mexico (PNM) failed the upward flexibility test in around 1.4 percent of intervals.
- All other balancing areas failed each test type in less than one percent of intervals.

Figure 2.9 shows the change in the percent of intervals with an upward test failure from the second quarter of 2023 to the second quarter of 2024. Figure 2.10 shows the same information for downward test failures.

Figure 2.11 summarizes the overlap between failure of the upward capacity and the flexibility tests during the quarter. The black horizontal line (right axis) shows the number of 15-minute intervals with either a capacity or a flexibility test failure for each WEIM area. The areas are shown in descending number of failure intervals. The bars (left axis) show the percent of the failure intervals that meet the condition. Figure 2.12 shows the same information for the downward direction. Areas that did not fail either the capacity or the flexibility tests during this period were omitted from the figure. Across both directions, the flexibility test was more often the source of the resource sufficiency evaluation failure.

¹ Results in this section exclude known invalid test failures. These can occur because of a market disruption, software defect, or other errors.

² Results in these figures reflect the final resource sufficiency evaluation (40 minutes prior to the evaluation hour).

Arizona Publ. Serv.	0.2	0.0	0.1	_	_	_	0.0	_	0.1	_	_	_	_	_	_
Avangrid	0.0	_	_	_	_	0.8	_	—	_	_	—	_	_	_	_
Avista	0.1	0.0	_	_	_	_	0.0	0.1	_	0.3	0.1	_	_	_	_
BANC	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_
BPA	0.2	—	0.3	0.4	—	0.1	—	_	_	0.3	_	_	_	_	_
California ISO	_	—	_	_	_	_	_	_	—	—	_	_	_	_	_
El Paso Electric	0.0	0.1	0.3	0.8	0.0	0.1	0.1	—	—	—	_	0.1	0.2	0.6	0.1
Idaho Power	0.0	0.1	—	—	—	—	—	0.1	—	0.0	—	—	—	—	—
LADWP	—	—	—	0.1	0.0	—	_	—	0.0	0.1	0.0	_	0.0	0.0	—
NorthWestern En.	—		_	0.3				_	_	_	0.1	_			_
NV Energy	—	0.0	—	0.0	0.0	—	0.0	—	—	—	—	—	—	0.1	0.0
PacifiCorp East	—	—	—	0.0	—	—	—	—	—	—	—	—	—	—	—
PacifiCorp West	—	—	—	—	0.1	—	—	—	—	0.8	0.0	—	0.1	0.0	_
Portland Gen. Elec.	0.1	0.4	0.1	0.0	—	0.0	0.0	0.6	—	—	—	—	—	0.0	0.1
Powerex	—	0.1	—	—	—	0.1	0.0	0.0	—	—	—	—	—	—	—
PSC of New Mexico	0.3	0.2	0.0	—	0.0	0.1	0.1	—	0.1	—	—	—	0.1	0.1	0.1
Puget Sound En.	—	0.1	0.5	1.5	0.5	0.2	0.7	1.0	0.2	0.8	0.1	0.2	0.3	0.2	—
Salt River Proj.	0.9	0.2	0.0	2.8	1.2	0.0	0.8	0.2	0.1	0.1	0.1	0.2	0.1	—	0.2
Seattle City Light	—	—	—	0.1	0.9	—	0.1	0.6	—	0.5	—	—	0.4	—	0.0
Tacoma Power	—	0.1	—	—	0.1	—	0.1	0.0	—	—	—	0.3	—	0.0	—
Tucson Elec. Pow.	—	—	—	0.3	—	—	0.2	—	—	—	—	—	—	—	—
Turlock Irrig. Dist.	0.0	—	—	0.1	—	—	—	—	—	—	—	—	—	—	—
WAPA DSW	2.3	0.8	0.7	1.1	0.6	0.1	0.3	0.4	0.1	_	_	0.1	_	0.5	0.3
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
		2023										20	24		

Figure 2.1 Frequency of upward capacity test failures (percent of 15-minute intervals)

Figure 2.2 Average shortfall of upward capacity test failures (MW)

Animone Dubl Com.	C27	25	100				FO		100						
Arizona Publ. Serv.	63/	35	192	_	_	_	58	_	160	-	_	_	_	_	_
Avangrid	1	-	_			190	_	_	_	—	_		-	-	
Avista	20	1	-	-	-	-	2	13	-	31	9	-	-	-	-
BANC	-	-	—	-	—	_	-	-	-	-	_	_	-	-	—
BPA	55	-	238	118	-	73	-	-	-	176	_	-	-	-	-
California ISO	—	-	—	-	-	-	-	-	-	-	-	—	-	-	—
El Paso Electric	6	8	88	20	8	6	18	—	—	-	_	4	3	15	14
Idaho Power	23	12						58		4					
LADWP	—	_		10	18	—			10	71	1	—	19	6	
NorthWestern En.	—	-	-	70	—	-	-	-	-	-	12	—	-	-	—
NV Energy	—	53	—	3	41	—	12	—	—	—	_	—	—	39	38
PacifiCorp East	—	—	—	116	—	—	—	—	—	—	—	—	—	—	—
PacifiCorp West	—	—	_	_	26	—	-	-	—	51	8	—	25	8	—
Portland Gen. Elec.	1	19	12	24	_	0	17	228	_	_	_	_	_	9	12
Powerex	_	131	_	_	_	154	2	6	_	_	_	_	_	_	_
PSC of New Mexico	24	106	5	—	25	4	48	_	49	_	—	_	46	8	28
Puget Sound En.	—	26	45	29	28	48	48	89	41	78	15	52	53	18	_
Salt River Proj.	30	38	1	65	56	80	56	23	10	17	38	22	29	_	233
Seattle City Light	_	_	_	2	6	_	5	563	_	18	_	-	9	_	0
Tacoma Power	_	2	_	_	7	_	5	0	_	_	_	119	_	2	_
Tucson Elec. Pow.	_	_	_	54	_	_	12	_	_	_	_	_	_	_	_
Turlock Irrig. Dist.	2	-	_	8	_	_	_	-	_	_	-	_	_	_	_
WAPA DSW	133	74	5	18	4	13	7	282	78	_	_	1	_	5	6
-															
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
					2022							20	24		
	1	2023										20	24		

	4.4	0.0	0.4		0.0			0.0	0.4	0.0	0.4	0.5	0.4	0.0	
Arizona Publ. Serv.	1.1	0.2	0.1		0.0			0.2	0.1	0.2	0.1	0.5	0.1	0.3	
Avangrid _	1.0	0.7	0.1	0.2	0.0	0.9	0.1	0.1	0.2	0.2	0.1	0.1	0.0	0.2	0.5
Avista _	0.2	0.2	0.0		—	—	0.1	0.1	_	0.1	_	0.1		_	_
BANC _	—	0.1												_	
BPA	0.2	1.2	0.3	1.3	0.2	0.2	0.1	—	—	0.4	0.0	—	0.1	0.1	0.1
California ISO	—	—	—	—	—	—	—	—	—		—	_	—	—	_
El Paso Electric	0.8	0.7	0.3	2.1	0.5	0.6	0.4	0.2	0.1	0.3	0.0	1.0	0.9	1.0	0.9
Idaho Power	0.3	0.5	0.1	_	_	—	0.1	—	—	1.1	—	0.1	0.6	0.6	0.1
LADWP	0.1	0.0	0.1	0.0	0.2	0.0	—	—	0.1	0.1	—	0.1	0.4	0.1	0.0
NorthWestern En.	0.8	0.3	0.2	1.0	0.4	0.2	0.2	0.0	0.1	0.5	0.1	0.0	0.0	0.1	0.3
NV Energy	0.1	0.1	0.0	0.1	0.2	0.1	_	0.1	0.0	_	0.1	0.0	_	0.1	_
PacifiCorp East	0.1	_	0.0	0.2	_	_	_		_	_	_	_	0.0	0.0	_
PacifiCorp West	0.1	0.6	0.0	0.2	_	_	0.0	0.0	0.1	1.0	_	0.1	_	_	0.1
Portland Gen. Elec.	0.1	15	0.7	0.1	_	_	0.6	0.0	_	_	_	0.0	_	02	0.2
Powerex	_		_	_	_	_	_	_	_	0.2	_	_	_	_	_
PSC of New Mexico	51	09	0.6	07	05	03	19	19	03	2.0	23	04	18	11	12
Puget Sound En.	0.2	1.0	0.6	2.6	13	0.2	13	19	0.5	0.8	0.1	0.7	0.4	0.5	0.5
Salt River Proi.	2.0	0.6	0.0	2.0	1.5	0.2	0.6	0.4	0.5	0.0	0.1	0.2	0.4	0.5	0.3
Seattle City Light	2.0	0.0	0.2	5.7	0.5	0.0	0.0	0.4	0.2	0.2	0.1	0.7	0.4	0.1	0.5
Tacoma Power		0.1			0.5	0.0	0.0	0.0		0.5	0.0	0.1	0.1	0.1	
Tucson Elec. Pow.	0.1	0.1		0.2	0.2		0.2	0.0	0.1	0.1	0.0	0.4	0.0	0.0	
Turlock Irrig Dist	0.1	0.1		0.2	0.5		0.1	0.2	0.1	0.0	0.2		0.1	0.1	
WAPA DSW	0.0			0.1	_	-	-		-	1 1		2 5	-		-
-	2.1	0.7	0.8	0.3	0.6	0.2	0.3	0.5	0.1	1.1	2.5	3.5	0.3	0.8	0.2
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
		2023										20)24		

Figure 2.3 Frequency of upward flexibility test failures (percent of 15-minute intervals)

Figure 2.4 Average shortfall of upward flexibility test failures (MW)

Arizona Publ. Serv.	119	36	76	_	88	_	_	102	23	27	55	65	35	83	_
Avangrid	79	13	9	20	26	138	60	8	7	12	20	30	19	15	20
Avista	35	14	4	_	_	_	21	15	_	66	—	14	—	_	—
BANC	—	64	—	—	—	—	—	—	—	—	—	—	—	-	—
BPA	99	82	164	114	44	41	5	—	—	153	73	—	5	9	47
California ISO	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
El Paso Electric	24	15	123	19	34	9	17	10	13	9	24	23	17	17	14
Idaho Power	42	24	46	—	—	—	10	—	—	32	—	17	27	28	33
LADWP	21	30	56	51	102	14	—	—	69	26	—	52	200	50	48
NorthWestern En.	14	33	11	32	20	6	11	4	5	16	24	3	11	12	26
NV Energy	164	59	24	52	207	12	—	22	19	—	137	136	—	80	—
PacifiCorp East	47	—	18	36	—	—	—	—	—	—	—	—	27	44	—
PacifiCorp West	30	146	2	35	_	_	22	25	22	104	-	9	_	_	6
Portland Gen. Elec.	61	49	37	27	_	_	25	2	_	_	-	23	—	44	22
Powerex	_	—	_	_	_	_	_	_	_	106	—	_	_	_	—
PSC of New Mexico	47	26	21	35	56	20	56	38	39	52	50	37	48	43	83
Puget Sound En.	29	59	48	55	43	18	86	42	27	29	16	71	12	17	22
Salt River Proj.	54	72	53	77	50	90	43	63	151	66	50	44	76	92	209
Seattle City Light	—	—	—	—	16	29	6	—	—	22	—	16	19	6	—
Tacoma Power	—	21	—	—	—	—	9	2	—	6	7	73	2	13	—
Tucson Elec. Pow.	36	30	_	35	21	_	13	13	55	6	13	_	10	25	_
Turlock Irrig. Dist.	1	-	_	12	_	_	_	_	_	_	_	_	_	_	_
WAPA DSW	71	122	21	9	21	14	16	143	12	12	27	33	18	12	18
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
		2023										20	24		

Arizona Publ. Serv.	_	_	_	_	_	_	_	_	0.8	01	0.0	01	02	_	
Avangrid	_	_	_	_	_	_	_	03		_	_	_		_	_
Avista	0.0	_	_	_	_	_	_		_	_	_	01	_	_	
BANC	_	—	_	_	_	_	_	_	_	_	_	_	_	_	
BPA	0.2	0.1	_	_	_	_	_	_	_	_	_	_	—	_	
California ISO	_	_	_	_	_	_	_	-	-	_	—	—	_	_	_
El Paso Electric	0.2	0.1	0.3	0.2	0.1	0.2	_	_	_	0.2	_	0.4	0.2	0.4	0.3
Idaho Power	_	_	0.0	_	_	_	_	_	_	_	_	_	0.5	_	
LADWP	—	—	0.0	_	_	_	_			_	_	_	_	_	_
NorthWestern En.	—	_	_	_	_	_	_	_	_	_	_	_	_	—	_
NV Energy	0.1	0.1	0.6	0.1	_	_	_			_	_	_	_	—	
PacifiCorp East	—	_	_	_	_	_	_			_	_	_	_	—	
PacifiCorp West	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_
Portland Gen. Elec.	—	—	_	_	_	_	_		_	_	_	_	_	—	
Powerex	—	_	_	0.0	_			_	_	_	_	_	0.0	_	—
PSC of New Mexico	0.3	_	_	_	_	0.1		_	_	_	_	_	—	_	—
Puget Sound En.	—	0.1	_	_	_			_	_	_	_	_	—	_	—
Salt River Proj.	0.3	0.6	0.4	0.7	_	0.1	0.1	_	_	_	0.1	0.1	0.4	0.7	—
Seattle City Light	—	—	_	_	0.3	0.1		0.1	0.2	0.0	_	_	—	—	—
Tacoma Power	—	—	_	0.0	_	0.0	_	_	_	_	—	_	—	—	0.0
Tucson Elec. Pow.	—	—	_	_	_	_		_	_	—	—	_	—	—	—
Turlock Irrig. Dist.	—	—	_	_	_	—	_	_	_	—	—	_	—	—	—
WAPA DSW	0.2	_	0.8	0.1	0.4	0.5	0.2	0.2	—	_	_	_	_	—	_
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
		2023										20	24		

Figure 2.5 Frequency of downward capacity test failures (percent of 15-minute intervals)

Figure 2.6 Average shortfall of downward capacity test failures (MW)

Arizona Publ Serv	_	_	_	_	_	_	_	_	176	18	16	9	100	_	_
Avangrid	_	_	_	_	_	_	_	93			- 10		- 100	_	_
Avista	2	-	_	_	_	_	_		_	_	_	264	_	_	_
BANC		-	_	_	_	_	_	_	_	_	_		_	_	_
BPA	12	99	_	_	_	_	_	_	_	_	_	_	_	_	_
California ISO		_	_	_	_	_	_	-	_	_	_	-	_		_
El Paso Electric	91	8	11	15	2	18	-	-	-	4	_	7	6	10	20
Idaho Power	_	-	4	_	_	_	_	-	-	_	_	_	12	_	_
LADWP	-	-	19	_	_	_	_	-	-	_	_	-	_	_	_
NorthWestern En.	—	-	_	_	_	_	-	-	-	_	_	-	_	_	_
NV Energy	14	42	124	51	_	_	_	_	_	_	_	_	_	_	_
PacifiCorp East	-	-	_	_	_	_	-	-	_	_	_	_	_	_	_
PacifiCorp West	—	_	_	—	_	_	—	_	—	_	—	—	—	_	_
Portland Gen. Elec.	—	_	_	—	_	_	_	—	—	_	_	—	_	_	_
Powerex	—	-	_	15	_	_	_	_	-	_	-	_	25	_	_
PSC of New Mexico	233	-	_	_	_	72	_	_	-	_	_	-	_	_	_
Puget Sound En.	—	26	—	_	—	—	—	—	—	—	-	—	_	—	_
Salt River Proj.	79	27	35	39	—	13	46	—	—	—	20	2	21	33	—
Seattle City Light	—	—	_	—	12	15	—	15	3	1	—	—	—	—	—
Tacoma Power	—	—	_	1	—	4	—	—	—	—	—	—	—	—	2
Tucson Elec. Pow.	—	—	_	—	—	—	—	—	—	—	—	—	—	—	—
Turlock Irrig. Dist.	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
WAPA DSW	9	—	12	13	11	7	6	2	—	—	—	—	_	_	—
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
		2023										20	24		

Arizona Publ. Serv.	0.7	1.2	0.1	_	_	—	_	_	0.3	0.1	0.1	0.2	0.1	_	_
Avangrid	0.1	—	_	_	_	0.1	_	_		0.1	_	_	_		_
Avista	0.1	0.1	_	_	_	—	_	0.1	_	_	0.0	_	_	_	_
BANC	_	—	_	_	_	—	_	_	_	_	_	—	_	_	_
BPA	0.6	5.5	0.0	0.4	_	0.0	0.2	_	_	0.4	0.1	_	0.0	0.1	0.1
California ISO	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
El Paso Electric	0.2	0.9	1.9	0.5	—	0.3	—	0.2	0.3	0.3	0.2	0.4	0.8	0.7	0.1
Idaho Power	0.2	—	—	—	—	0.0	—	0.1	—	—	—	0.0	1.0	—	—
LADWP	—	—	—	_	_	—	—	—	_	—	—	—	—	—	—
NorthWestern En.	—	0.2	0.2	—	0.1	0.0	—	—	_	0.2	—	0.1	—	0.3	0.2
NV Energy	0.0	0.1	0.4	0.1	0.1	0.0	0.1	0.1	_	_	_	0.1	0.0	_	0.1
PacifiCorp East	_	_	_	_	_	0.0	0.1	_	_	_	0.2	0.0	0.5	0.2	0.0
PacifiCorp West	0.0	0.2	0.0	_	_	1.1	_	0.1	_	_	_	0.2	_	_	_
Portland Gen. Elec.	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_
Powerex	0.2	—	_	0.0	_	0.2	0.1	_	0.1	_	0.1	0.4	0.0	_	_
PSC of New Mexico	1.6	2.1	_	0.1	0.4	1.1	0.4	0.2	0.2	0.9	0.9	0.4	0.0	0.6	0.1
Puget Sound En.	_	0.8	_	_	_	_	_	_	_	_	_	_	_	_	_
Salt River Proj.	0.3	0.1	0.1	0.1	_	_	_	0.1	0.0	0.1	0.1	0.7	0.7	0.7	0.0
Seattle City Light	0.3	0.0	0.3	0.4	1.1	0.2	_	0.8	0.2	0.2	0.1	0.1	0.2	_	0.1
Tacoma Power	—	—	—	0.0	_	0.1	_	0.0	_	_	0.0	_	_		
Tucson Elec. Pow.	—	—	—	—	_		_	_	_	_	0.1	—	_	—	_
Turlock Irrig. Dist.	0.1	0.4	—	—	_	—	_	0.1	_	_	0.0	—	_	0.2	0.0
WAPA DSW	2.7	0.5	0.7	0.1	0.2	0.6	0.8	0.2	0.1	0.3	0.1	0.0	0.0	_	_
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
		2023										20	24		

Figure 2.7 Frequency of downward flexibility test failures (percent of 15-minute intervals)

Figure 2.8 Average shortfall of downward flexibility test failures (MW)

Arizona Publ. Serv.	33	64	14	_	_	_	_	_	84	72	53	116	94	_	_
Avangrid	13	-	_	_	_	11	-	-	_	18	_	-	_	_	_
Avista	12	29	_	_	_	_	_	27	_	_	1	-	_	_	_
BANC	-	-	_	_	_	_	_	-	_	_	_	-	_	_	_
BPA	102	741	27	62	_	13	192	_	-	243	104	-	36	190	125
California ISO	-	_	_	_	_	_	_	-	-	-	-	-	_	_	_
El Paso Electric	8	15	30	36	_	21	—	7	8	7	7	10	31	11	9
Idaho Power	11	—	—	—	—	17	—	4	—	—	—	3	89	—	_
LADWP	—	—	_	—	—	-	-	-	—	—	—	—	—	_	_
NorthWestern En.	—	39	16	—	15	2	—	—	—	22	—	31	—	21	8
NV Energy	22	13	96	120	10	75	59	156	—	—	—	94	23	—	279
PacifiCorp East	—	—	—	—	—	25	8	—	—	—	36	35	68	76	125
PacifiCorp West	6	44	7	—	—	51	—	6	—	—	—	30	—	_	—
Portland Gen. Elec.	_	_	_	_	_	_	_	_	_	_	_	-	_	_	_
Powerex	48	—	—	85	—	67	421	—	160	—	84	2528	5	—	—
PSC of New Mexico	112	75	—	15	123	72	36	20	44	55	37	21	42	59	9
Puget Sound En.	—	38	—	—	—	—	—	—	—	—	—	—	—	—	—
Salt River Proj.	45	49	23	172	—	—	—	41	1	44	27	62	36	59	23
Seattle City Light	6	30	15	7	10	21	_	45	8	64	4	9	37	_	5
Tacoma Power	—	—	—	2	—	5	—	2	—	—	2	—	—	—	—
Tucson Elec. Pow.	—	—	—	—	—	—	—	—	—	—	94	—	—	—	—
Turlock Irrig. Dist.	8	4	—	—	—	—	—	39	—	—	1	—	—	5	2
WAPA DSW	55	8	16	12	14	11	14	8	8	66	22	16	3	—	—
	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
		2023										20	24		

	F	lexibility te	st	(Capacity test	t ,
WEIM entity	Q2 2023	Q2 2024	Difference	Q2 2023	Q2 2024	Difference
Arizona Publ. Serv.	0.5%	0.1%	-0.4%	0.1%	0%	-0.1%
Avangrid	0.6%	0.2%	-0.4%	0.0%	0%	0.0%
Avista	0.2%	0%	-0.2%	0.0%	0%	0.0%
BANC	0.0%	0%	0.0%	0%	0%	0%
BPA	0.6%	0.1%	-0.5%	0.2%	0%	-0.2%
California ISO	0%	0%	0%	0%	0%	0%
El Paso Electric	0.6%	0.9%	0.3%	0.2%	0.3%	0.2%
Idaho Power	0.3%	0.4%	0.1%	0.0%	0%	0.0%
LADWP	0.1%	0.2%	0.1%	0%	0.0%	0.0%
NorthWestern En.	0.4%	0.1%	-0.3%	0%	0%	0%
NV Energy	0.1%	0.0%	0.0%	0.0%	0.1%	0.0%
PacifiCorp East	0.0%	0.0%	0.0%	0%	0%	0%
PacifiCorp West	0.2%	0.0%	-0.2%	0%	0.0%	0.0%
Portland Gen. Elec.	0.8%	0.1%	-0.6%	0.2%	0.0%	-0.2%
Powerex	0%	0%	0%	0.0%	0%	0.0%
PSC of New Mexico	2.2%	1.4%	-0.8%	0.2%	0.1%	-0.1%
Puget Sound En.	0.6%	0.4%	-0.2%	0.2%	0.2%	0.0%
Salt River Proj.	1.0%	0.3%	-0.7%	0.4%	0.1%	-0.3%
Seattle City Light	0%	0.1%	0.1%	0%	0.1%	0.1%
Tacoma Power	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Tucson Elec. Pow.	0.1%	0.0%	0.0%	0%	0%	0%
Turlock Irrig. Dist.	0.0%	0%	0.0%	0.0%	0%	0.0%
WAPA DSW	1.4%	0.5%	-0.9%	1.3%	0.3%	-1.0%

Figure 2.9 Change in percent of intervals with an upward resource sufficiency evaluation failure (Q2 2023 to Q2 2024)

	F	lexibility te	st	(Capacity test	t
WEIM entity	Q2 2023	Q2 2024	Difference	Q2 2023	Q2 2024	Difference
Arizona Publ. Serv.	0.7%	0.0%	-0.7%	0%	0.1%	0.1%
Avangrid	0.0%	0%	0.0%	0%	0%	0%
Avista	0.1%	0%	-0.1%	0.0%	0%	0.0%
BANC	0%	0%	0%	0%	0%	0%
BPA	2.0%	0.1%	-1.9%	0.1%	0%	-0.1%
California ISO	0%	0%	0%	0%	0%	0%
El Paso Electric	1.0%	0.5%	-0.5%	0.2%	0.3%	0.1%
Idaho Power	0.1%	0.3%	0.3%	0.0%	0.2%	0.1%
LADWP	0%	0%	0%	0.0%	0%	0.0%
NorthWestern En.	0.1%	0.2%	0.0%	0%	0%	0%
NV Energy	0.2%	0.0%	-0.1%	0.3%	0%	-0.3%
PacifiCorp East	0%	0.3%	0.3%	0%	0%	0%
PacifiCorp West	0.1%	0%	-0.1%	0%	0%	0%
Portland Gen. Elec.	0%	0%	0%	0%	0%	0%
Powerex	0.1%	0.0%	-0.1%	0%	0.0%	0.0%
PSC of New Mexico	1.2%	0.3%	-0.9%	0.1%	0%	-0.1%
Puget Sound En.	0.3%	0%	-0.3%	0.0%	0%	0.0%
Salt River Proj.	0.2%	0.5%	0.3%	0.4%	0.4%	-0.1%
Seattle City Light	0.2%	0.1%	-0.1%	0%	0%	0%
Tacoma Power	0%	0%	0%	0%	0.0%	0.0%
Tucson Elec. Pow.	0%	0%	0%	0%	0%	0%
Turlock Irrig. Dist.	0.2%	0.1%	-0.1%	0%	0%	0%
WAPA DSW	1.3%	0.0%	-1.3%	0.4%	0%	-0.4%

Figure 2.10 Change in percent of intervals with a downward resource sufficiency evaluation failure (Q2 2023 to Q2 2024)



Figure 2.11 Upward capacity/flexibility test failure intervals by concurrence (April–June 2024)

Figure 2.12 Downward capacity/flexibility test failure intervals by concurrence (April–June 2024)



Impact of earlier runs of the resource sufficiency evaluation on market results

There are three runs of the resource sufficiency evaluation, at 75 minutes (first run), 55 minutes (second run), and 40 minutes (final run) prior to each evaluation hour. The first and second runs are sometimes considered the *advisory runs*, with the results of the final evaluation at 40 minutes prior considered the *binding run*. The previous section summarized the frequency of resource sufficiency evaluation failures in the final run. However, the results in the earlier runs of the resource sufficiency evaluation can also impact binding market results in several key ways. These are discussed below.

Nodal flexible ramping capacity procurement in the first 15-minute interval of each hour

Flexible ramping product nodal procurement in the *first* 15-minute market interval of each hour is dependent on the second run of the resource sufficiency evaluation at 55 minutes prior to the evaluation hour.

The results of the resource sufficiency evaluation are used as an input for the flexible ramping product. As part of the enhancements implemented on February 1, the real-time market will enforce an area-specific uncertainty target for balancing areas that fail the resource sufficiency evaluation. This target can only be met by flexible capacity within that area. In contrast, flexible capacity for the group of balancing areas that pass the resource sufficiency evaluation are pooled together to meet the uncertainty target for the system.

Deliverable flexible capacity awards are produced through two deployment scenarios that adjust the expected net load forecast in the *following* interval by the lower and upper ends of uncertainty that might materialize. This ensures that upward and downward flexible capacity awards do not violate transmission or transfer constraints. A consequence of this is that binding flex ramp awards in the first 15-minute market interval of each hour are now dependent on the second run of the resource sufficiency evaluation at 55 minutes prior to the evaluation hour — based on the latest information available at the time of this market run.

Figure 2.13 and Figure 2.14 summarize the *first* interval of each evaluation hour during the quarter and the frequency of a failure in the second (T-55) or final (T-40) resource sufficiency evaluation.³ This reflects failure of *either* the flexibility or capacity test in the second or final run. The red and yellow bars show instances with a failure in the second evaluation (T-55), and whether the balancing area ultimately failed or passed in that interval based on the final evaluation results at 40 minutes prior to the hour. The dashed blue region instead shows cases in the first interval of the hour when the balancing area passed the second evaluation (T-55) but failed the final evaluation (T-40). In these intervals, the balancing area would have been included in the pass-group for the purpose of procuring flexible ramping capacity. The pass-group uncertainty requirement includes any diversity benefit of reduced uncertainty over a larger footprint.

³ Areas that did not fail in the first interval of a resource sufficiency evaluation at T-55 or T-40 during this period were omitted from these figures.





Figure 2.14 Downward resource sufficiency evaluation failures in first 15-minute interval of hour (April–June 2024)



Calculating uncertainty for balancing areas passing the resource sufficiency evaluation

Uncertainty estimates created for the group of balancing areas that pass the resource sufficiency evaluation in the *first and second* interval of each hour are based on earlier test results.

As part of the enhancements implemented on February 1, uncertainty is now calculated based on regression results that use historical data to predict uncertainty relative to load, solar, and wind forecasts.⁴ Once all of the regressions are complete, the regression outputs can be combined with current forecast information to calculate uncertainty for each interval.

For a single balancing area that failed the resource sufficiency evaluation, these regressions can be performed in advance and local uncertainty targets can be readily determined based on current forecast information. However, for instead the group of balancing areas that pass the resource sufficiency evaluation (known as the pass-group), the regression procedure needs to first determine which balancing areas make up this group so that it can perform the regression using historical data accordingly for that group.

To perform the regressions to estimate the pass-group uncertainty, the composition of balancing areas in this group is based on earlier test results for the first and second 15-minute market interval of each hour. In the first interval, the results from the earliest resource sufficiency evaluation (T-75) is used to define the pass-group. In the second interval, the results from the second resource sufficiency evaluation (T-55) is used to define the pass-group. This is based on the latest information available at the time of this process.

However, the current weather information that is ultimately combined with the regression results to calculate uncertainty are instead consistent with the group of balancing areas in the pass-group for flexible ramping capacity procurement. This is based on the second run of the resource sufficiency evaluation (T-55) for interval 1, and the final resource sufficiency evaluation (T-40) for intervals 2 through 4. Table 2.1 summarizes this inconsistency by showing which resource sufficiency evaluation run is used for each interval and process.

15-minute market interval	Current weather information for calculating uncertainty and flex ramp procurement	Regression inputs and outputs
1	Second run (T-55)	Firstrun(T-75)
2	Finalrun(T-40)	Second run (T-55)
3	Finalrun(T-40)	Final run (T-40)
4	Finalrun(T-40)	Final run (T-40)

Table 2.1 Source of pass-group for calculating uncertainty and procuring flexible ramping capacity

Using an inconsistent composition of balancing areas in the pass-group between the forecast and regression information can create significant swings in the calculated uncertainty for this group. For example, if you have a model to predict uncertainty based on forecast information of all but one balancing area passing the test (based on earlier test results), but then combine this with current forecast information of all balancing areas (based on later test results), then the calculated uncertainty can be disconnected from forecasted conditions in the system. DMM has requested that the ISO consider options to resolve inconsistencies in the composition of balancing areas in the pass-group.

⁴ The calculation of uncertainty is described in more depth in the following section.

During about 17 percent of intervals during the quarter, the composition of balancing areas in the passgroup between the current forecast information and regression information were inconsistent for either upward or downward uncertainty. Figure 2.15 summarizes the impact of this inconsistency on passgroup uncertainty requirements in cases when the composition of balancing areas differed between the two sets of data. Figure 2.15 shows the percent of intervals in which the market uncertainty requirements (with inconsistent balancing areas in the pass-group) were higher or lower than counterfactual uncertainty requirements with a consistent composition of balancing areas in the pass-group.⁵ These results are shown separately for the following categories to highlight the impact of this inconsistency on uncertainty requirements.

- **Decreased requirements** indicate that market uncertainty requirements for the pass-group were lower as a result of inconsistent balancing areas in the pass-group.
- **Increased requirements** indicate that market uncertainty requirements for the pass-group were higher as a result of inconsistent balancing areas in the pass-group.
- **No impact** indicates that uncertainty requirements were capped by thresholds in a way that resulted in the same uncertainty requirements.
- **Unknown impact** indicates that there was an inconsistent composition of balancing areas in the pass-group but data was not available to calculate the impact.



Figure 2.15 Impact of pass-group inconsistency on uncertainty requirements (April–June 2024)

⁵ This analysis accounts for any thresholds that capped or would have capped calculated uncertainty requirements.

Additional impacts of earlier resource sufficiency evaluation failures on market results

Each real-time market run will use the latest resource sufficiency evaluation results available to optimize resources and energy transfers in the WEIM accordingly. This includes future advisory intervals that can be impacted by earlier runs of the resource sufficiency evaluation. In particular, the hour-ahead market includes resources and transfers in the WEIM footprint with transfer limits potentially impacted from test failures from the first run of the resource sufficiency evaluation at 75 minutes prior to the evaluation hour.

3 Assistance energy transfers

Assistance energy transfers (AET) give balancing areas access to excess WEIM supply that may not have been available otherwise following an upward resource sufficiency evaluation failure. Without AET, a balancing area failing either the upward flexibility or upward capacity test would have net WEIM imports limited to the greater of either the base transfer or the optimal transfer from the last 15-minute market interval. Balancing areas can voluntarily opt in to the AET program to prevent their WEIM transfers from being limited during an upward resource sufficiency evaluation failure, but will be subject to an ex-post surcharge. Balancing areas must opt in or opt out of the program in advance of the trade date.⁶

The assistance energy transfer surcharge is applied during any interval in which an opt-in balancing area fails the upward flexibility or capacity test. The surcharge is calculated as the *applicable real-time assistance energy transfer* times the real-time bid cap.⁷ The applicable AET quantity is based on the lesser of either (1) the tagged dynamic WEIM transfers or (2) the amount by which the balancing area failed the resource sufficiency evaluation. If the tagged dynamic WEIM transfers are less than the amount by which the balancing area failed the resource sufficiency evaluation. If the resource sufficiency evaluation, then the applicable AET quantity is also reduced by a credit. The credit is either upward available balancing capacity for WEIM entities or cleared regulation up for the ISO balancing area.

Opting in to the assistance energy transfer program does not guarantee that the balancing area will achieve additional WEIM supply following a resource sufficiency evaluation failure (compared to opting out of the program). It only removes the import limit that would have been in place following a test failure, allowing the market to freely and optimally schedule WEIM transfers based on supply and demand conditions in the system. If the import limit following a test failure was set high such that it is not restricting the optimal solution, then opting in or opting out of the program will have no effect on WEIM import supply in that interval.

Table 3.1 shows the days in which a balancing area was opted in to receiving assistance energy transfers during the quarter. Seven balancing areas were opted in to the program on at least one day during this period: Avangrid, CAISO, Idaho Power, NorthWestern Energy, NV Energy, PacifiCorp East and PacifiCorp West.⁸ Avangrid and NV Energy were opted in to AET during all days during the quarter and NorthWestern Energy was opted in to AET during most of the quarter (82 days).

On April 8, 2024, a partial solar eclipse occurred over most of the western United States.⁹ This primarily impacted grid-scale solar and behind-the-meter rooftop solar across a number of WEIM balancing areas between hours-ending 11 and 13. The California ISO opted in to receiving assistance energy transfers on April 8 as a mitigation measure in preparation for the event. Idaho Power also opted in to AET for this day. All balancing areas passed the *upward* resource sufficiency evaluation during the eclipse period

⁶ Assistance Energy Transfer designation requests are submitted to Master File as *opt-in* or *opt-out* and include both a start and end date. The standard timeline to implement an opt-in or opt-out request is at least five business days in advance of the start date. An *emergency* opt-in request is also available, should reliability necessitate this, for two business days in advance of the start date. For more information, see: <u>https://bpmcm.caiso.com/Pages/ViewPRR.aspx?PRRID=1525&IsDlg=0</u>

⁷ The soft bid cap is \$1,000/MWh and can increase to the hard bid cap of \$2,000/MWh under certain conditions.

⁸ The CAISO balancing area can opt in to assistance energy transfers based on upcoming system conditions and operator experience. For more information, see the Business Practice Manual for the Western Energy Imbalance Market, section 11.3.2: <u>https://bpmcm.caiso.com/Pages/BPMDetails.aspx?BPM=Energy%20Imbalance%20Market</u> The CAISO area did not fail the resource sufficiency evaluation during the quarter.

⁹ California ISO, Solar Eclipse Technical Bulletin, March 6, 2024: <u>https://www.caiso.com/documents/april-8-solar-eclipse-technical-bulletin-march-11-2024.pdf</u>

such that assistance energy transfers had no impact on procuring additional WEIM supply during the eclipse.¹⁰ Idaho Power, El Paso Electric, and Arizona Public Service failed the *downward* flexibility test in at least one interval during the eclipse.

Table 3.2 summarizes all balancing areas that were opted in to assistance energy transfers on at least one day during the quarter and the subsequent impact following a resource sufficiency evaluation failure. First, the table shows the number of 15-minute intervals in which a balancing area failed the resource sufficiency evaluation after opting in to AET. These are the intervals in which the WEIM import limit following the test failure was removed — giving the WEIM entity access to WEIM supply that may not have been available otherwise. Table 3.2 also shows the percent of failure intervals in the 5-minute market in which the balancing area achieved additional WEIM imports due to opting in to AET. The table also shows the average and maximum WEIM imports added in the 5-minute market because of AET.

	Period opted in to receiving	
Balancing area	assistance energy transfers	Days opted in to AET
Avangrid	Apr. 1 - Jun. 30	91
California ISO	Apr. 8	1
Idaho Power	Apr. 8, Jun. 1 - Jun 30	31
NorthWestern Energy	Apr. 10 - Jun. 30	82
NV Energy	Apr. 1 - Jun. 30	91
PacifiCorp East	May 31 - Jun. 30	31
PacifiCorp West	May 31 - Jun. 30	31

Table 3.1Assistance energy transfer opt-in designations by balancing area
(April–June 2024)

¹⁰ The Assistance energy transfer functionality only removes the import limit after failing the *upward* resource sufficiency evaluation. This functionality does not address oversupply conditions that can occur following a downward resource sufficiency evaluation failure (and imposed export limit).

	RSE failures under AET	Percent of failure intervals with additional WEIM	Average WEIM imports	Max WEIM imports
Balancing area	(15-min. intervals)	imports due to AET	added (MW)	added (MW)
Avangrid	20	38%	38	198
California ISO	0	N/A	N/A	N/A
Idaho Power	2	100%	184	278
NorthWestern Energy	12	39%	16	101
NV Energy	7	67%	195	626
PacifiCorp East	0	N/A	N/A	N/A
PacifiCorp West	2	50%	40	99

Table 3.2Resources sufficiency evaluation failures during assistance energy transfer opt-in
(April–June 2024)

4 Net load uncertainty in the resource sufficiency evaluation

Net load uncertainty is included in the requirement of the flexible ramp sufficiency test (flexibility test) to capture additional flexibility needs that may be required in the evaluation hour due to variation in either load, solar, or wind forecasts. This calculation was adjusted on February 1 using a method called *mosaic quantile regression*. Details on the calculation are included in Appendix B. This section summarizes the results of the uncertainty calculation, and how it compares with actual error between forecasts used in the tests and in the real-time market.

Change to historical distributions used to calculate uncertainty

The uncertainty regressions use a distribution of historical forecast observations from the previous 180 days—separate for each balancing area and hour. Prior to April 4, 2024, the distributions were also *separate for each day-type*, either weekday or weekend.¹¹ Here, the process initially selected data from the previous 180 days for the same hour and balancing area. Then, a subset of this data was selected depending on whether the current day was a weekday or a weekend. Given that each hour contains four 15-minute intervals, this resulted in roughly 514 observations in the weekday distributions ($180 \times 4 \times \frac{2}{7}$). Further, the quantile regression assigns weight to a subset of these observations based on the 2.5th or 97.5th percentile of these observations. This gives substantial weight to a limited number of extreme observations for estimating uncertainty. The result was an effective sample size of about 13 observations for weekdays and 5 observations for weekends. As a result of the limited sample size, the forecasting outcome (particularly on weekends) may not have been very reliable.

¹¹ Weekend observations include holidays.

On April 4, 2024, the ISO changed the calculation to *not* make any distinction between weekday or weekend in the historical distributions. The goal of this change was to increase the sample size, particularly on the weekends. Each historical distribution, regardless of day type, now has 720 observations (180 × 4), or an effective sample size of 18 based on the significant weighting toward the extreme observations. Increasing the sample size may allow the regression to better identify patterns and improve the performance. However, if the underlying relationship between uncertainty and the forecast information is weak, including more samples in the regression may not have the desired result.¹²

The change had the greatest impact on calculating weekend uncertainty, by greatly increasing the sample size. Table 4.1 estimates the impact of removing the distinction by day type by summarizing average requirements and coverage on weekends, both before and after the change on April 4, 2024. The period prior to the change covers weekends between February 1 to April 3 (18 days) while the period following the change covers weekends between April 4 and May 31 (16 days). Here, coverage is the frequency in which actual net load error—as measured by the difference between binding 5-minute market net load forecasts and *net load forecasts in the resource sufficiency evaluation*—fell within the downward and upward regression-based uncertainty requirements for the same interval.¹³ The period following the change showed greater requirements and coverage on the weekends across most balancing areas. However, underlying forecasting conditions also differed between these two periods. Additional analysis is needed to assess the impact of the change over the same period.

¹² For more information on the relationship between the extremes of net load uncertainty and the forecast information, see DMM's *Review of mosaic quantile regression for estimating net load uncertainty*, November 20, 2023: <u>http://www.caiso.com/Documents/Review-of-the-Mosaic-Quantile-Regression-Nov-20-2023.pdf</u>

¹³ In comparing the 15-minute resource sufficiency evaluation forecasts to the three corresponding 5-minute forecasts, all three observations of error were used as a separate observation for calculating coverage.

	Upward uncertainty		Downward	uncertainty	Uncertainty coverage		
	requireme	nt (MW)	requirem	ent (MW)	Uncertainty coverage		
Balancing area	Pre-change P	ost-change	Pre-change	Post-change	Pre-change	Post-change	
Arizona Public Service	190.21	228.22	-206.00	-248.98	82%	86%	
Avangrid	151.33	212.68	-135.41	-203.87	87%	89%	
Avista	40.10	51.04	-48.73	-49.83	86%	88%	
BANC	39.54	38.30	-33.82	-30.77	83%	82%	
Bonneville Power Admin.	178.97	249.34	-208.91	-264.77	84%	92%	
California ISO	1087.76	1081.47	-710.43	-684.69	83%	88%	
El Paso Electric	27.93	30.57	-22.75	-26.94	80%	85%	
Idaho Power	94.67	128.58	-104.90	-145.18	82%	82%	
LADWP	131.32	145.90	-135.41	-140.77	82%	89%	
NorthWestern Energy	62.46	68.60	-60.21	-69.51	88%	90%	
NV Energy	176.18	189.52	-145.24	-157.78	74%	79%	
PacifiCorp East	335.91	299.42	-369.24	-402.42	87%	86%	
PacifiCorp West	80.05	99.35	-113.83	-117.20	84%	90%	
Portland General Electric	98.61	135.21	-116.68	-136.62	83%	88%	
Powerex	140.57	138.38	-137.49	-130.25	85%	91%	
PNM	97.67	135.32	-95.38	-147.16	81%	91%	
Puget Sound Energy	119.86	131.14	-115.00	-117.73	85%	84%	
Salt River Project	93.18	120.80	-83.61	-110.15	84%	90%	
Seattle City Light	17.94	17.10	-20.69	-15.42	81%	84%	
Tacoma Power	11.10	10.90	-12.15	-8.88	82%	86%	
Tucson Electric Power	84.83	101.30	-50.53	-65.67	82%	91%	
Turlock Irrigation District	7.41	7.91	-5.16	-6.70	84%	89%	
WAPA Desert Southwest	20.31	21.75	-23.39	-23.68	83%	90%	

Table 4.1Average weekend uncertainty requirement and coverage prior to and after change
(February 1 to April 3 prior to change; April 4 to May 31 after change)

Thresholds for capping uncertainty

Uncertainty calculated from the quantile regressions is capped by the lesser of two thresholds. The thresholds are designed to help prevent extreme outlier results from impacting the final uncertainty. The *histogram* threshold is updated each day and pulled for each hour from the 1st and 99th percentile of net load error observations from the previous 180 days. The seasonal threshold is updated each quarter and is calculated based on the 1st and 99th percentile using observations over the previous 90 days. Here, each hour is calculated separately, and the greatest upward and downward uncertainty across all hours sets the seasonal threshold for each hour of the same direction.

Figure 4.1 shows the percent of test intervals in which the upward or downward uncertainty calculated by the quantile regression was capped by either the seasonal or histogram threshold during the quarter. Averaging across all balancing areas, the thresholds capped the calculated upward uncertainty in around 17 percent of intervals and the calculated downward uncertainty in around 13 percent of intervals. In the large majority of cases, the *histogram* threshold capped the uncertainty.

A threshold is also in place that sets the *floor* for uncertainty at 0.1 MW in both directions. The upward and downward uncertainty is therefore set near zero when the uncertainty calculated from the quantile

regression would be negative. Figure 4.2 shows the percent of test intervals in which the quantile regression uncertainty was set near zero by this threshold during the quarter.

Figure 4.1 Quantile regression uncertainty capped by mosaic or histogram thresholds (April–June 2024)





Figure 4.2 Quantile regression uncertainty set near zero by mosaic threshold (April–June 2024)

Using uncertainty from the flexible ramping product in the resource sufficiency evaluation

The calculation of uncertainty in the flexibility test continues to be measured similarly to the 15-minute market flexible ramping product—based on the difference between binding 5-minute market forecasts and corresponding advisory 15-minute market forecasts. The quantile regression uses the historical sample of 5-minute and 15-minute market observations to create hourly coefficients that define the relationship between the forecasts and uncertainty. The resource sufficiency evaluation and flexible ramping product uncertainty calculations for a single balancing area use the same hourly coefficients, but are combined with the current forecast information for each time horizon.¹⁴

The calculated uncertainty is based on the 2.5th and 97.5th percentile for downward and upward uncertainty, respectively. The 95 percent confidence interval for the uncertainty requirement in the flexible ramping product was designed to capture the upper end of uncertainty needs, such that it could be optimally relaxed based on the trade-off between the cost of procuring additional flexible ramping capacity and the expected cost of a power balance constraint relaxation. In the resource sufficiency evaluation, this trade-off is not considered, and the upper end of uncertainty is instead required in full to pass both tests. DMM has asked the ISO and stakeholders to consider whether the 95 percent confidence interval, or another, is most appropriate for the tests.¹⁵

¹⁴ A balancing-area-specific flexible ramping product uncertainty requirement will be enforced for any balancing area that failed the resource sufficiency evaluation.

¹⁵ Department of Market Monitoring, Comments on EIM Resource Sufficiency Evaluation Enhancements Issue Paper, September 8, 2021: <u>http://www.caiso.com/Documents/DMM-Comments-on-EIM-Resource-Sufficiency-Evaluation-Enhancements-Issue-Paper-Sep-8-2021.pdf</u>

Further, the resource sufficiency evaluation occurs in a different timeframe than the 15-minute market. Figure 4.3 illustrates the current uncertainty calculation—based on net load error between an advisory 15-minute market interval and corresponding binding 5-minute market intervals—as well as how it compares with the timeframe of the resource sufficiency evaluation. The current uncertainty calculation captures 45 to 55 minutes of potential uncertainty from the 15-minute market run to three corresponding 5-minute market runs. In contrast, when comparing the variable energy resource (VER) and load forecast values used in each interval of the resource sufficiency evaluation to corresponding 5-minute intervals, there exists a larger gap for uncertainty to materialize.¹⁶

In comparing the first 15-minute test interval to corresponding 5-minute market intervals, the timeframe and potential for net load uncertainty is similar to the timeframe of the 15-minute market flexible ramping product uncertainty calculation. In the later test intervals, the gap between the predicted forecasts at the time of the resource sufficiency evaluation and the real-time forecasts widens, reaching above 100 minutes.



Figure 4.3 Comparison of current uncertainty calculation to the timeframe of the RSE

¹⁶ The figure shows the resource sufficiency evaluation run time at 55 minutes prior to the hour. While the financially binding test is run at 40 minutes prior to the hour, the VER and load forecasts used in the final test are pulled from the advisory test performed at T-55.

Results of quantile regression uncertainty in the resource sufficiency evaluation

Figure 4.4 summarizes the histogram uncertainty (pulled from the 2.5th and 97.5th percentile of observations in the hour from the previous 180 days) and the final uncertainty from the mosaic quantile regression for the CAISO balancing area between April 4 and June 30, 2024.¹⁷ The green and blue lines show the *average* upward and downward uncertainty from each method, while the areas around the lines show the minimum and maximum amount over the quarter (range of uncertainty in each interval). The dashed red and yellow lines in Figure 4.4 show the average histogram and seasonal thresholds, respectively, during the quarter.

Figures covering the same information for all WEIM entities are provided further below.

Overall, the uncertainty outcomes from the mosaic quantile regression approach were often comparable to those calculated with the prior histogram approach. The mosaic quantile regression approach tends to be somewhat lower on average across most hours and balancing areas. However, results of the mosaic quantile regression approach vary more widely, including periods with zero uncertainty.

Figure 4.4 California ISO resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)



¹⁷ The methodology to calculate the uncertainty was changed slightly on April 4, 2024. The weekday or weekend distinction in the historical distributions were dropped.





Figure 4.6 Avangrid resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)





Figure 4.7 Avista resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)

Figure 4.8 BANC resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)

Time







Figure 4.10 El Paso Electric resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)







Figure 4.12 LADWP resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)







Figure 4.14 NV Energy resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)







Figure 4.16 PacifiCorp West resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)







Figure 4.18 Powerex resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)





Figure 4.19 PNM resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)

Figure 4.20 Puget Sound Energy resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)







Figure 4.22 Seattle City Light resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)







Figure 4.24 Tucson Electric Power resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)







Figure 4.26 WAPA Desert Southwest resource sufficiency evaluation uncertainty requirements (April 4–June 30, 2024)



Performance measurements of quantile regression uncertainty

Table 4.2 summarizes the average requirements calculated using both the histogram and mosaic quantile regression methods. The blue cells highlight balancing areas and directions in which the calculated uncertainty from the regression method was less than the histogram method, while the orange regions highlight that the regression method had greater calculated uncertainty. On average across all hours, the uncertainty calculated from the regression method was less than the histogram the histogram method for most of the WEIM entities.

Table 4.3 summarizes the *actual net load error*—as measured by the difference between binding 5-minute market net load forecasts and *net load forecasts in the resource sufficiency evaluation*—and how that compares to the mosaic regression uncertainty requirements for the same interval.¹⁸ The left side of the table summarizes the closeness of the actual net load error to the uncertainty requirements.¹⁹ The calculated uncertainty from the mosaic regression covered between 82 and 94 percent of actual net load errors across all balancing areas. The right side of the table summarizes when the actual net load error downward uncertainty requirements.

Table 4.4 shows the same information as Table 4.3, except with requirements calculated from the histogram method. Coverage from the histogram method was more than the regression method for most balancing areas.

¹⁸ In comparing the 15-minute resource sufficiency evaluation forecasts to the three corresponding 5-minute forecasts, all three observations of error were used as a separate observation for calculating coverage, closeness, and exceedance.

¹⁹ To the extent that the actual net load error averages around zero MW, this measurement largely matches the upward and downward uncertainty requirements.

	Upward uncertainty			Downward uncertainty			
Balancing area	Histogram	Mosaic	Difference	Histogram	Mosaic	Difference	
Arizona Public Service	220.2	226.3	6.1	-256.4	-249.5	6.9	
Avangrid	203.6	202.5	-1.1	-193.6	-182.3	11.3	
Avista	55.4	48.7	-6.8	-62.4	-54.9	7.5	
BANC	43.8	40.9	-2.9	-42.8	-34.8	8.0	
Bonneville Power Admin.	233.8	232.4	-1.4	-268.0	-254.0	14.0	
California ISO	1,199.4	1,065.6	-133.7	-917.7	-678.6	239.1	
El Paso Electric	35.9	35.0	-0.9	-32.7	-30.8	1.9	
Idaho Power	120.1	125.4	5.4	-149.7	-141.4	8.3	
LADWP	147.3	138.2	-9.1	-161.6	-144.3	17.2	
NorthWestern Energy	75.9	69.1	-6.8	-76.5	-69.1	7.4	
NV Energy	232.8	196.3	-36.5	-214.5	-169.5	44.9	
PacifiCorp East	329.9	313.7	-16.2	-475.5	-446.3	29.2	
PacifiCorp West	95.1	96.3	1.1	-133.8	-115.9	18.0	
Portland General Electric	123.6	130.2	6.6	-131.6	-136.1	-4.6	
Powerex	145.9	134.5	-11.5	-152.3	-131.2	21.1	
PNM	136.1	137.0	0.9	-151.4	-152.9	-1.5	
Puget Sound Energy	138.2	131.2	-7.0	-132.7	-125.1	7.6	
Salt River Project	127.1	124.9	-2.1	-124.0	-121.8	2.2	
Seattle City Light	22.4	17.1	-5.3	-22.2	-16.5	5.8	
Tacoma Power	13.0	11.0	-2.0	-13.1	-9.7	3.5	
Tucson Electric Power	99.8	102.1	2.3	-76.8	-73.1	3.7	
Turlock Irrigation District	8.3	7.4	-0.9	-7.6	-7.4	0.2	
WAPA Desert Southwest	23.1	21.0	-2.1	-23.5	-22.6	0.9	

Table 4.2 Average uncertainty requirements in the resource sufficiency evaluation(April–June 2024)

	Actual	net load error falls w	Actual net load error exceeds				
	uncertainty requirements			upward requirement downward requirer			equirement
	Percent of	Distance to up	Distance to down	Percent of	Amount	Percent of	Amount
Balancing area	intervals	requirement (MW)	requirement (MW)	intervals	(MW)	intervals	(MW)
Arizona Public Service	88%	193.6	287.0	10%	78.4	1%	68.3
Avangrid	91%	185.1	199.5	6%	68.8	3%	41.1
Avista	90%	50.2	54.7	5%	17.5	6%	19.4
BANC	84%	40.7	36.1	10%	52.7	6%	15.2
Bonneville Power Admin.	92%	229.5	260.8	5%	63.0	3%	54.7
California ISO	88%	826.2	939.4	9%	231.7	3%	310.0
El Paso Electric	82%	35.6	33.0	9%	14.2	9%	14.7
Idaho Power	86%	146.2	121.2	6%	45.0	8%	46.4
LADWP	91%	139.9	145.0	4%	37.6	5%	52.6
NorthWestern Energy	89%	68.3	70.5	4%	20.6	7%	23.0
NV Energy	80%	174.5	210.6	16%	71.6	5%	108.1
PacifiCorp East	86%	336.0	431.1	10%	121.0	4%	136.5
PacifiCorp West	90%	108.6	105.6	5%	29.9	5%	24.9
Portland General Electric	90%	133.1	135.8	5%	34.6	6%	47.3
Powerex	91%	134.9	132.2	4%	45.6	5%	38.3
PNM	90%	141.1	153.7	5%	57.8	5%	45.6
Puget Sound Energy	87%	124.4	133.6	6%	52.6	7%	48.6
Salt River Project	89%	131.0	117.2	6%	43.2	6%	68.1
Seattle City Light	86%	17.8	15.9	5%	6.8	8%	6.5
Tacoma Power	87%	10.7	10.0	5%	3.7	8%	3.8
Tucson Electric Power	90%	94.2	82.4	4%	30.7	6%	32.5
Turlock Irrigation District	84%	7.8	7.6	9%	3.0	7%	3.8
WAPA Desert Southwest	83%	23.0	22.1	8%	9.7	9%	11.1

Table 4.3 Actual net load error versus regression uncertainty requirements (April–June 2024)

Table 4.4 Actual net load error versus histogram uncertainty requirements (April–June 2024)

	Actual net load error falls within calculated			Actual net load error exceeds				
	uncertainty requirements			upward requirement downward requirement				
	Percent of	Distance to up	Distance to down	Percent of	Amount	Percent of	Amount	
Balancing area	intervals	requirement (MW)	requirement (MW)	intervals	(MW)	intervals	(MW)	
Arizona Public Service	88%	189.7	290.3	11%	79.0	1%	89.1	
Avangrid	90%	189.6	208.1	7%	83.8	3%	65.6	
Avista	91%	57.6	61.5	4%	23.0	4%	21.1	
BANC	86%	44.7	43.3	10%	45.6	4%	16.3	
Bonneville Power Admin.	92%	229.3	273.6	5%	80.7	4%	76.3	
California ISO	90%	989.0	1,175.5	8%	227.7	2%	334.1	
El Paso Electric	82%	36.8	35.4	9%	13.9	9%	15.3	
Idaho Power	85%	139.2	131.1	6%	56.6	9%	52.6	
LADWP	91%	151.0	162.6	4%	39.1	4%	51.3	
NorthWestern Energy	91%	75.7	76.7	4%	26.7	5%	26.7	
NV Energy	85%	209.0	260.4	12%	70.2	3%	114.8	
PacifiCorp East	88%	347.1	460.9	8%	130.5	4%	151.9	
PacifiCorp West	91%	106.7	122.5	5%	35.7	4%	32.4	
Portland General Electric	89%	125.6	130.2	5%	43.2	6%	50.4	
Powerex	94%	148.0	150.9	4%	48.7	3%	38.6	
PNM	89%	139.7	152.2	5%	57.1	5%	50.2	
Puget Sound Energy	88%	131.3	140.1	6%	63.2	6%	49.2	
Salt River Project	89%	132.2	120.0	5%	42.4	6%	69.3	
Seattle City Light	94%	23.2	21.4	2%	6.5	4%	6.8	
Tacoma Power	94%	12.9	13.3	3%	3.7	4%	4.0	
Tucson Electric Power	91%	92.3	85.0	5%	31.7	5%	34.0	
Turlock Irrigation District	87%	8.6	7.7	7%	2.7	6%	3.2	
WAPA Desert Southwest	87%	24.6	22.8	6%	9.5	8%	10.8	

Variability of quantile regression uncertainty

Prior to February 2023, uncertainty used in the resource sufficiency evaluation was known in advance of the trade date based on the lower and upper percentiles of observations over the historical period for the same hour (*histogram approach*). Under this approach, the uncertainty was also the same in each interval for the evaluation hour. The *mosaic quantile regression* approach combines regression results with current load, solar, and wind forecast information to calculate uncertainty in each 15-minute interval of the evaluation hour. With this approach, the regression coefficients for individual balancing areas are known in advance, but the exact uncertainty is dependent on current forecast information. A natural consequence of this is that calculated uncertainty has greater variability and is more difficult to predict in advance.

Changes in uncertainty between resource sufficiency evaluation runs

Figure 4.27 shows the difference in the calculated upward uncertainty from the first run of the resource sufficiency evaluation at 75 minutes prior to the evaluation hour, to the second run of the resource sufficiency evaluation at 55 minutes prior to the evaluation hour. Figure 4.28 shows the same information for downward uncertainty. Load and renewable forecasts are held fixed between the second (T-55) and final (T-40) resource sufficiency evaluations such that uncertainty is also unchanged between these runs. Therefore, these figures summarize how effective the T-75 uncertainty is in predicting the final uncertainty used in the resource sufficiency evaluation. The dashed gray region shows effectively no difference from the first resource sufficiency evaluation (less than one MW change). The regions above or below this show increased or decreased uncertainty relative to the T-75 results. The uncertainty difference from the first run of the resource sufficiency evaluation was typically less than 10 MW. More significant increases in the uncertainty requirement also occurred in rare instances and may lead to unexpected resource sufficiency evaluation failures.

Figure 4.27 Megawatt change in upward quantile regression uncertainty between T-75 and T-55 resource sufficiency evaluation runs (April–June 2024)



Figure 4.28Megawatt change in downward quantile regression uncertainty between T-75 and
T-55 resource sufficiency evaluation runs (April–June 2024)



5 Demand-response-based load adjustments in the resource sufficiency evaluation

WEIM entities are able to submit load forecast adjustments in the resource sufficiency evaluation to reflect demand response programs which could not be accounted for otherwise in the real-time market. This adjustment is included in both the capacity and flexibility tests, and impacts the load used in the requirements of both tests.

The adjustments can be entered as positive or negative. A negative adjustment reflects a lower load forecast as a result of a demand response program. This will decrease the requirement for the upward capacity and flexibility tests, but will increase the requirement for the downward tests. The adjustments can also be entered as a positive load adjustment. This can reflect additional demand because of expected pre-cooling or post-demand-response-event increases (sometimes referred to as snapback).

Figure 5.1 shows all hourly demand-response-based load adjustments that occurred during the second quarter. Each of these occurred during June between hours 18 and 23. The feature to adjust the load forecast in the tests based on a demand-response program was used by two balancing areas during the quarter: NV Energy and PacifiCorp East. NV Energy used this feature to apply negative adjustments to load during 19 hours, at an average of -66 MW (or -136 at its lowest). NV Energy also submitted positive adjustments following the demand-response events, during 16 hours at 22 MW on average. PacifiCorp East submitted a demand-response-based load adjustment of -100 MW during one hour.

During this period, these adjustments had no impact on any balancing area passing or failing the resource sufficiency evaluation.



Figure 5.1 Demand-response-based load adjustments included in the resource sufficiency evaluation (April–June 2024)

6 Additional demand in the real-time market compared to the resource sufficiency evaluation

The real-time market and resource sufficiency evaluation use different measurements for the total load. The resource sufficiency evaluation uses the raw (or initial) real-time load forecast directly in the requirement for both the capacity and the flexibility test. However, in the real-time market, the software adds operator load conformance, adds non-participating pump load, removes the portion that is estimated to be from losses, and finally recalculates the losses in the market.²⁰

This is illustrated below in Figure 6.1 for the ISO area during an example interval. The example compares the total load and losses between the resource sufficiency evaluation with a corresponding advisory interval from the latest 15-minute market run.²¹ In this example, the raw load forecast used in both cases (35,010 MW) was identical based on the timing of when the two market processes were run.

Figure 6.1Example — difference between load used in the real-time market and in the resource
sufficiency evaluation (CAISO, July 20, 2023. Hour-ending 23. Interval 1.)



The potential inclusion of load conformance was discussed as part of a resource sufficiency evaluation enhancements stakeholder process. In this process, the ISO confirmed no changes in the tests to account for load conformance, following findings that the use of load conformance does not regularly benefit any balancing area from passing the resource sufficiency evaluation.²²

²⁰ The total load also adjusts for a few other miscellaneous components that cannot be accounted for elsewhere. The amounts here are typically small.

²¹ Load and renewable forecasts are held fixed between the second run of the resource sufficiency evaluation (T-55) and final run (T-40).

²² California ISO, *EIM Resource Sufficiency Evaluation Enhancements Phase 2 Straw Proposal*, July 1, 2022: <u>http://www.caiso.com/InitiativeDocuments/StrawProposal-WEIMResourceSufficiencyEvaluationEnhancementsPhase2.pdf</u>

Non-participating pump load within the ISO balancing area is not counted in the resource sufficiency evaluation. This is pumping load that is bid and scheduled as non-participating load in the day-ahead market and included as a component of the total load in the real-time market optimization. This pumping load can be significant (above 1,000 MW).

Non-participating pump load is included in the real-time market but not in the resource sufficiency evaluation. This can create differences in the conditions observed between both processes. This can also be a factor in hours during which the ISO passes the resource sufficiency evaluation while an Energy Emergency Alert (EEA) is issued.

Other factors can also contribute to this outcome. First, rapidly evolving and declining conditions might prompt an EEA, but may not be observed by the resource sufficiency evaluation based on the latest information in advance of the evaluation hour. Also, real-time low priority and economic exports that clear the hour-ahead scheduling process would be included in the real-time market as additional demand, but are no longer counted as such in the resource sufficiency evaluation because of enhancements implemented on July 1, 2023.

DMM recommends that the ISO and stakeholders consider whether non-participating pump load should be included in the resource sufficiency evaluation. This would better align the conditions in the real-time market with the conditions considered in the resource sufficiency evaluation.

7 WEIM import limits following test failure

This section summarizes the import limits that are imposed when a WEIM entity fails either the bid-range capacity or the flexible ramping sufficiency test in the upward direction.

Balancing areas can voluntarily opt in to receiving assistance energy transfers. When a balancing area opts in to the program, their WEIM transfers will not be affected by any limits that would exist following an upward resource sufficiency evaluation failure—allowing the market to freely and optimally schedule WEIM transfers based on supply and demand conditions in the system. The import limits summarized in this section cover both balancing areas that opted out or opted in to the assistance energy transfer program. For balancing areas that opted in to the program, these limits reflect what would have been in place had the balancing area not opted in.

When either test fails in the upward direction, imports will be capped at the greater of (1) the base transfer or (2) the transfer from the last 15-minute market interval. Figure 7.1 summarizes the import limits after failing either test by the source of the limit. The black horizontal line (right axis) shows the number of 15-minute intervals with either a capacity or a flexibility test failure, while the bars (left axis) show the percent of failure intervals in which the WEIM import limit was capped by either the base transfer or the last 15-minute market transfer. In some cases, the import limit after failing the test (i.e., the greater of the base transfer or last 15-minute interval transfer) is at or above the unconstrained total import capacity. In these cases, the import limit imposed after failing the test has no impact.





Figure 7.2 summarizes dynamic WEIM import limits above base transfers after failing either test in the upward direction.²³ From this perspective, the incremental WEIM import limit after a test failure is set by the greater of (1) zero or (2) the transfer from the last 15-minute market interval minus the current base transfer. Therefore, the dynamic import limits show the incremental flexibility available through the WEIM after a resource sufficiency evaluation failure. The black horizontal line (right axis) shows the number of 15-minute intervals with an import limit imposed after a test failure. Areas without any upward test failures during the quarter were excluded.





Figure 7.3 summarizes whether the import limit that was imposed after failing either test in the upward direction impacted market transfers (or would have impacted market transfers had the balancing area not opted in to the assistance energy transfer program).²⁴ The black horizontal line (right axis) shows the number of 15-minute market intervals with either a capacity or flexibility test failure. The blue bars (left axis) show the percent of failure intervals in which the resulting transfers—after failing the resource sufficiency evaluation—were *below* the import limit that was imposed (or would have been imposed for opt-in balancing areas). In all other failure intervals (red bars), the resulting transfers were either constrained to the limit imposed after failing the test or would have been constrained by the limit without an opt-in designation. These results are shown separately for the 15-minute (FMM) and 5-minute (RTD) markets.

²³ Test failure intervals in which an import limit was not imposed because it was at or above the unconstrained total import capacity were excluded from this summary.

²⁴ Test failure intervals in which an import limit was not imposed because it was at or above the unconstrained total import capacity were excluded from this summary.





Appendix A – Overview of the flexible ramp sufficiency and capacity tests

As part of the Western Energy Imbalance Market (WEIM) design, each balancing area (including the California ISO) is subject to a resource sufficiency evaluation. The evaluation is performed prior to each hour to ensure that generation in each area is sufficient without relying on transfers from other balancing areas. The evaluation is made up of four tests: the power flow feasibility test, the balancing test, the bid range capacity test, and the flexible ramp sufficiency test.

The market software automatically limits transfers into a balancing area from other WEIM areas if a balancing area fails either of the following two tests:

- The bid range capacity test (capacity test) requires that each area provide incremental bid-in capacity to meet the imbalance between load, intertie, and generation base schedules.
- **The flexible ramp sufficiency test (flexibility test)** requires that each balancing area has enough ramping flexibility over an hour to meet the forecasted change in demand as well as uncertainty.

If an area fails either the flexible ramp sufficiency test or bid range capacity test in the *upward* direction, WEIM transfers into that area cannot be *increased*.²⁵ Similarly, if an area fails either test in the *downward* direction, transfers out of that area cannot be *increased*.

Bid range capacity test

The *bid range capacity test* requires that each area provide incremental (or decremental) bid-in capacity to meet the imbalance between load, intertie, and generation base schedules. Equation A.1 shows the different components and mathematical formulation of the bid range capacity test. As shown in Equation A.1, the requirement for the bid range capacity test is calculated as the *load forecast* plus *export base schedules* minus *import and generation base schedules*. Intertie uncertainty was removed on June 1, 2022.

Equation A.1 Bid range capacity test requirement



If the requirement is positive, then the area must show sufficient incremental bid range capacity to meet the requirement, and if the requirement is negative, then sufficient decremental bid range capacity must be shown.

The bid range capacity used to the meet the requirement is calculated relative to the base schedules. For the California ISO balancing area, the "base" schedules used in the requirement are the advisory schedules from the last binding 15-minute market run. For all other WEIM areas, the export, import, and generation schedules used in the requirement are the base schedules submitted as part of the hourly

²⁵ If an area fails either test in the upward direction, net WEIM imports during the interval cannot exceed the greater of either the base transfer or optimal transfer from the last 15-minute market interval.

resource plan. Since the bid range capacity is calculated relative to the base schedules, the upward capacity test can generally be expressed as shown in Equation A.2.²⁶

Equation A.2 Bid range capacity test reformulation



Incremental bid-in generation capacity is calculated as the range between the generation base schedule and the economic maximum, accounting for upward ancillary services and any de-rates (outages). Other resource constraints including start-times and ramp rates are not considered in the capacity test; 15-minute dispatchable imports and exports are included as bid range capacity.

Flexible ramp sufficiency test

The *flexible ramp sufficiency test* requires that each balancing area has enough ramping resources to meet expected upward and downward ramping needs in the real-time market without relying on transfers from other balancing areas. Each area must show sufficient ramping capability from the start of the hour to each of the four 15-minute intervals within the hour.

Equation A.3 shows the different components and formulation of the flexible ramp sufficiency test requirement. The requirement for the flexible ramp sufficiency test is calculated as the *forecasted change in load* plus the *uncertainty component* minus two components: (1) the *diversity benefit* and (2) *flexible ramping credits.* Any undersupply infeasibility in the last 15-minute market interval is also accounted for in the flexibility test requirement since June 1, 2022.



Equation A.3 Flexible ramp sufficiency test requirement

The diversity benefit reflects that system-level flexible ramping needs are typically smaller than the sum of the needs of individual balancing areas because of reduced uncertainty across a larger footprint. As a result, balancing areas receive a prorated diversity benefit discount based on this proportion.

²⁶ DMM has identified cases when the existing incremental approach for the capacity test relative to base schedules does not equal maximum capacity expected under a total approach. The incremental bid-range capacity can be positive only. If maximum capacity at the time of the test run is below base schedules, this difference will not be accounted for in the test. For more information, see DMM's *Comments on EIM Resource Sufficiency Evaluation Enhancements Issue Paper*, September 8, 2021: <u>https://stakeholdercenter.caiso.com/Common/DownloadFile/25df1561-236b-4a47-9b1c-717b4a9cf9f0</u>

The flexible ramping credits reflect the ability to reduce exports from a balancing area to increase upward ramping capability, or to reduce imports to increase downward ramping capability.

As shown in Equation A.3 above, the reduction in the flexibility test requirement because of any diversity benefit or flexible ramping credit is capped by the area's net import capability for the upward direction, or net export capability for the downward direction.

Last, as part of phase 1 of *resource sufficiency evaluation enhancements*, the flexibility test requirement now includes any undersupply infeasibility (power balance constraint relaxation) from the 15-minute market solution immediately prior to the resource sufficiency evaluation hour. This amount excludes any operator imbalance conformance.

Since February 1, 2023, the uncertainty component used in the flexible ramp sufficiency test is calculated using a regression method which considers forecasted net load currently on the system.²⁷ The measured uncertainty reflects extreme historical net load errors (95 percent confidence interval) adjusted to reflect forecasted conditions. The net load error observations used to calculate uncertainty in the resource sufficiency evaluation are measured from the difference between (1) binding 5-minute market net load forecasts and (2) the corresponding advisory 15-minute market net load forecast.

²⁷ California ISO, Flexible Ramping Product Refinements Final Proposal, August 31, 2020: <u>http://www.caiso.com/InitiativeDocuments/FinalProposal-FlexibleRampingProductRefinements.pdf</u>

Appendix B – Calculating net load uncertainty in the tests

Histogram method

Uncertainty used in the resource sufficiency evaluation was previously calculated by selecting the 2.5th and 97.5th percentile of observations from a distribution of historical net load forecast errors. This is known as the *histogram method*. The historical error observations in the distribution were the difference between binding 5-minute market net load forecasts and corresponding advisory 15-minute market net load forecasts. ²⁸ Prior to February 1, 2023, the weekday distributions used data for the same hour from the previous 40 weekdays, while weekend distributions instead used same-hour observations from the previous 20 weekend days. The histogram approach did not factor in any current load, solar, or wind forecast information. Under this approach, uncertainty could have been set by historical outlier observations uncorrelated with current market conditions, such as an extreme historical observation in which wind forecasts were significant while wind forecasts in the evaluation hour were minimal.

Mosaic quantile regression method

The calculation for net load uncertainty was adjusted on February 1, 2023 as part of flexible ramping enhancements. The uncertainty was adjusted to incorporate current load, solar, and wind forecast information using a method called *mosaic quantile regression*.

Regression is a statistical method used to study the relationship between two or more variables, such as the relationship between the load or renewable forecasts (independent variables) and uncertainty (dependent variable). Ordinary Least Squares is widely used to estimate the *mean* relationship between these variables (i.e., the average value of the dependent variable as a function of the independent variable). In contrast, quantile regression is a variation of regression that is useful when interested in the relationship between the independent variable(s) and different *percentiles* of the dependent variable. For example, the relationship between the load or renewable forecasts, and the 97.5th percentile of uncertainty.

The chosen regression method is a two-step procedure to forecast the lower and upper extremes of net load uncertainty that might materialize. The initial quantile regressions determine the relationship between the forecasts (load, solar, and wind) and the extremes of each type of uncertainty (load, solar, and wind). In a simple linear regression, the relationship between the dependent variable Y and the independent variable X takes the basic form of Y = bX where the outcome of the regression, b, explains how much Y changes for every one unit increase in X (e.g., if b is two, then Y is predicted to be twice X). For calculating uncertainty as a function of the forecast, the quantile regressions are instead defined in the quadratic form $(Y = aX^2 + bX + c)$. The initial regressions are shown below in

Equation B.1 for upward net load uncertainty.²⁹

²⁸ In comparing the 15-minute observation to the three corresponding 5-minute observations, the minimum and maximum net load errors were used as a separate observation in the distribution.

²⁹ Equations 1 to 5 are for calculating *upward* net load uncertainty. *Downward* net load uncertainty is instead based on the lower end of load uncertainty, and upper end of solar and wind uncertainty that might materialize.

Equation B.1 Initial quantile regressions for upward net load uncertainty

$$\begin{aligned} & \text{Load uncertainty}^{max} = a_l^{97.5}(load)^2 + b_l^{97.5}(load) + c_l^{97.5} + \varepsilon & (\tau = 0.975) \\ & \text{Solar uncertainty}^{min} = a_s^{2.5}(solar)^2 + b_s^{2.5}(solar) + c_s^{2.5} + \varepsilon & (\tau = 0.025) \\ & \text{Wind uncertainty}^{min} = a_w^{2.5}(wind)^2 + b_w^{2.5}(wind) + c_w^{2.5} + \varepsilon & (\tau = 0.025) \\ & \text{Wind uncertainty} = a_w^{2.5}(wind)^2 + b_w^{2.5}(wind) + c_w^{2.5} + \varepsilon & (\tau = 0.025) \\ & \text{Dependent variable: load, solar, } & \text{Independent variable: } & \text{Error term}(\varepsilon): \text{ variation} \\ & \text{and wind uncertainty} - \text{minimum} & \text{advisory 15-minute} & \text{in dependent variable} \\ & \text{or maximum difference between} & \text{market forecasts for load, } & \text{that is not explained by} \\ & \text{binding 5-minute market forecasts} & \text{solar, and wind in each} & \text{interval} \\ & \text{forecasts in each 15-minute} \\ & \text{market interval} \end{aligned}$$

The uncertainty regressions use a distribution of historical forecast observations from the previous 180 days—separate for each balancing area and hour. For the resource sufficiency evaluation, uncertainty in the distributions is the difference between binding 5-minute market forecasts and corresponding advisory 15-minute market forecasts. ³⁰ The outcome of these regressions are the coefficients a, b, and c, that define the relationships between the forecasts and the extreme end of uncertainty that might materialize.³¹ These coefficients can then be combined with the historical 15-minute forecast data to create a distribution of predicted values for load, solar, and wind uncertainty, which is needed for the second step of the calculation. This is shown below in Equation B.2 for upward net load uncertainty.

Equation B.2 Predicted values for upward net load uncertainty

$$\hat{L}_Q^{97.5} = a_l^{97.5} (load)^2 + b_l^{97.5} (load) + c_l^{97.5} \\ \hat{S}_Q^{2.5} = a_s^{2.5} (solar)^2 + b_s^{2.5} (solar) + c_s^{2.5} \\ \hat{W}_Q^{2.5} = a_w^{2.5} (wind)^2 + b_w^{2.5} (wind) + c_w^{2.5} \\ \hline$$

Predicted values: predicted 97.5th percentile of Regression coefficients: parameters "a", load uncertainty and 2.5th percentile of solar and wind uncertainty based on regression coefficients and historical distribution

"b", and "c" that define the relationship between the forecasts and the extreme end of uncertainty that might materialize

The *mosaic* element of the regression combines the predicted forecasts above with the histogram method. For the histogram estimates, the 180-day distributions are again used to calculate the lower and upper ends of uncertainty, based on the 2.5th and 97.5th percentiles in the distribution. The combination of the predicted values and the histogram extremes in the mosaic variable are intended to

³⁰ In comparing the 15-minute observation to the three corresponding 5-minute observations, the maximum load errors and minimum wind and solar errors are used to calculate upward net load uncertainty. Or, minimum load errors, and maximum wind and solar errors for downward net load uncertainty.

³¹ The coefficient *c* is also known as the intercept. It shows the value of the dependent variable when all independent variables are equal to zero.

capture the incremental weather effect of using predicted information relative to the histogram approach. Here, the calculation modifies the histogram net load by adding the predicted values and subtracting the histogram outcomes for each uncertainty type individually.³² This is shown below in Equation B.3 for upward net load uncertainty:



Equation B.3 Mosaic variable for upward net load uncertainty

Once the mosaic variable is calculated for each interval in the distribution, the software runs a final regression to predict net load uncertainty. Again, the quantile regression method looks for the extreme values of the data (at the 2.5th and 97.5th percentiles) such that the output reflects the upper and lower boundaries of the future uncertainty. Therefore, the predicted values obtained from the quantile regression models are expected to estimate the range in which net load uncertainty is likely to materialize. The final regression is shown in Equation B.4 below:

Equation B.4 Mosaic regression for upward net load uncertainty



Once all of the regressions are complete, the regression output coefficients can be combined with current forecast information to calculate uncertainty for each interval. For the flexibility test, this forecast information is the same load, solar, and wind forecasts which are considered in the resource sufficiency evaluation for calculating ramping capacity and test requirements. The latest forecasts at the time of the second pass of the resource sufficiency evaluation at 55 minutes prior to the evaluation hour are held constant for the final test at 40 minutes prior to the hour. The final equations for combining the current forecast information with the regression coefficients and histogram extremes to calculate upward uncertainty for each interval are shown in Equation B.5 below.

³² The mosaic variable can be thought of as the modified net load.

Equation B.5 Calculation of upward uncertainty from current forecast information

$$\begin{aligned} \hat{L}_{current}^{97.5} &= a_l^{97.5} (load_{current})^2 + b_l^{97.5} (load_{current}) + c_l^{97.5} \\ \hat{S}_{current}^{2.5} &= a_s^{2.5} (solar_{current})^2 + b_s^{2.5} (solar_{current}) + c_s^{2.5} \\ \widehat{W}_{current}^{2.5} &= a_w^{2.5} (wind_{current})^2 + b_w^{2.5} (wind_{current}) + c_w^{2.5} \\ \end{aligned}$$

$$mosaic_{current}^{97.5} &= NL_H^{97.5} + \left(\left(\hat{L}_{current}^{97.5} - L_H^{97.5} \right) - \left(\hat{S}_{current}^{2.5} - S_H^{2.5} \right) - \left(\widehat{W}_{current}^{2.5} - W_H^{2.5} \right) \right) \\ Net \ load \ uncertainty_{current}^{97.5} &= a_m^{97.5} (mosaic_{current}^{97.5})^2 + b_m^{97.5} (mosaic_{current}^{97.5}) + c_m^{97.5} \end{aligned}$$

The performance of the mosaic quantile regression method depends on whether there is a meaningful relationship between net load uncertainty, and the mosaic variables created from historical and predicted values. DMM has published a more detailed review of the mosaic quantile regression approach.³³ DMM finds that the regression model has limited predictive capability for forecasting net load uncertainty.

³³ Department of Market Monitoring, Review of mosaic quantile regression for estimating net load uncertainty, November 20, 2023: <u>http://www.caiso.com/Documents/Review-of-the-Mosaic-Quantile-Regression-Nov-20-2023.pdf</u>