

Recreating Quarterly FRP Thresholds

With Data Available in OASIS

Short-Term Forecasting

Outline

- FRP thresholds overview
 - Thresholds report in OASIS
- Static threshold
 - Example calculation for AVRN BAA
- Dynamic threshold
- Summary and additional references



FRP thresholds overview

Threshold	Granularity	Update frequency	OASIS report label	Value *
Floor	Constant	None	Mosaic	0.1 MW
Dynamic	Hourly	Daily	Histogram	1 st and 99 th percentile from a sample that mirrors the mosaic calculation sample
Static	Constant	Quarterly	Mosaic	1 st and 99 th percentile from 90-day rolling sample

The raw mosaic results in FRU and FRD are compared to and constrained by static and dynamic thresholds. At an absolute minimum, flex ramp requirements are 0.1 MW. Assuming down requirements and thresholds are expressed as negative values, thresholds are applied as follows:

Flex ramp up (FRU) requirement = $max(min(FRU_{raw_mosaic}, threshold_{dynamic}, threshold_{static}), 0.1)$

Flex ramp down (FRD) requirements = $min(max(FRD_{raw_mosaic}, threshold_{dynamic}, threshold_{static}), 0.1)$

^{*} As of September 2024, the dynamic threshold is a 180-day day symmetric sample and the static threshold is a 90-day rolling sample. A rolling sample includes N days preceding the trade date. A symmetric sample is composed of an N/2 days preceding the trade date and N/2 days succeeding the trade date from one year prior.



Page 3

FRP threshold report on OASIS

[Top Right] Navigate to FRP Ramp Requirement Thresholds report

[Below] View of threshold report Select desired trade date, market, and BAA



Date: 08/20/20)24 31 Ma	arket/Process: RT	TPD ✓ BAA ID: CISO	✓ Apply	Reset														
Download XI	VIL	Download CSV																	
Flexible R	Flexible Ramp Requirement Thresholds																		
¢	- 8 of ???	2 ▶ ▶ I	0																7
Market Opr Date		Ramp Type	- Percentile	축 Data Type	→ HE01	HE02	HE03	HE04	HE05	HE06	HE07	HE08	HE09	HE10	HE11	HE12	HE13	HE14	HE15
	Authority Area ID																		,
RTPD 08/20/202	24 CISO	DOWN	HIGH	Histogram	768.93	599.95	575.82	609.06	645.81	796.25	2,165.25	3,334.45	2,283.72	1,677.02	1,790.15	1,294.40	1,501.49	9 1,421.00	1,78
RTPD 08/20/202	24 CISO	DOWN	HIGH	Mosaic	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,642.00	1,64
RTPD 08/20/202	24 CISO	DOWN	LOW	Histogram	-458.67	-500.80	-493.29	-541.56	-386.19	-519.61	-405.31	-819.83	-870.52	-1,049.24	-841.46	-841.47	-1,085.63	3 -1,022.13	-1,22
RTPD 08/20/202	24 CISO	DOWN	LOW	Mosaic	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	4/
RTPD 08/20/202	24 CISO	UP	HIGH	Histogram	768.93	599.95	575.82	609.06	645.81	796.25	2,165.25	3,334.45	2,283.72	1,677.02	1,790.15	1,294.40	1,501.49	9 1,421.00	1,78
RTPD 08/20/202	24 CISO	UP	HIGH	Mosaic	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,365.00	2,36
RTPD 08/20/202	24 CISO	UP	LOW	Histogram	-458.67	-500.80	-493.29	-541.56	-386.19	-519.61	-405.31	-819.83	-870.52	-1,049.24	-841.46	-841.47	-1,085.63	3 -1,022.13	-1,22
RTPD 08/20/202	24 CISO	UP	LOW	Mosaic	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	

Report Generated: 08/19/2024 21:01:44

Threshold	Ramp Type	Percentile	Data Type
Floor	Down/Up	Low	Mosaic
Dimonia	Down	Low	Histogram
Dynamic	Up	High	Histogram
Static	Down/Up	High	Mosaic



STATIC THRESHOLD



Summary of steps

- Create historical sample of realized uncertainty
 - Calculate net demand forecasts
 - Calculate realized uncertainty from difference in advisory to binding net demand forecasts
 - 90 day sample
 - For RTPD, keep only minimum and maximum sample per FMM interval (this will eliminate ~1/3 of data)
- Group uncertainty samples by hour and calculate 1st and 99th percentile
 - Take the min and max to get static thresholds



Example calculation

Static threshold for Avangrid (AVRN) updated in July 2024 to 463 MW up in FRU RTPD

- Gen-only BA
- Threshold calculated on 7/8/24
 - Historical 90-day sample used (4/9/24 to 7/7/24)
- No change to installed solar or wind capacity for AVRN BAA in that time period
- Focus on recreating the RTPD FRU static threshold (there are four static thresholds to calculate, FRU and FRD thresholds in RTD and RTPD)




Navigate to OASIS report on historical forecasts





FRP forecasts report - RTPD



Report Generated: 08/30/2024 18:50:52



FRP forecasts report - RTD

Date F	rom: 07/07	/2024 31	Market/Process:	RTD V BAA ID:	AVRN 🗸	Apply	=	Reset								
Do	wnload XML		Download CSV													
Elos	Flexible Ramp Forecasts															
rie	Cible Kai	iih Loiec		_												
*	◀ ◀ 21 -	40 of 72	• • • • • • • • • • • • • • • • • • •	•												
Market	Opr Date	 Balancing Authority Area ID 	Run Type	Data Type	Interval	HE01	HE02	HE03	HE04	HE05	HE06	HE07	HE08	HE09	HE10	HE
RTD	07/07/2024	AVRN	Advisory	Solar	4	0.00	0.00	0.00	0.00	0.00	6.63	83.53	283.12	337.46	359.78	365
RTD	07/07/2024	AVRN	Binding	Solar	4	0.00	0.00	0.00	0.00	0.00	6.63	93.75	287.05	340.40	359.97	365
RTD	07/07/2024	AVRN	Advisory	Wind	4	467.12	474.10	341.14	306.14	187.59	78.09	26.46	10.45	4.11	2.04	(
RTD	07/07/2024	AVRN	Binding	Wind	4	486.35	466.85	324.85	298.98	177.58	70.80	24.64	9.15	4.37	1.55	(
RTD	07/07/2024	AVRN	Advisory	Demand	5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(
RTD	07/07/2024	AVRN	Binding	Demand	5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(
RTD	07/07/2024	AVRN	Advisory	Solar	5	0.00	0.00	0.00	0.00	0.00	8.80	106.91	291.89	340.90	359.93	365
RTD	07/07/2024	AVRN	Binding	Solar	5	0.00	0.00	0.00	0.00	0.00	0.30	112.10	294.28	343.63	360.03	366
RTD	07/07/2024	AVRN	Advisory	Wind	5	486.35	466.85	324.85	298.98	177.58	70.80	24.64	9.15	4.37	1.55	(
RTD	07/07/2024	AVRN	Binding	Wind	5	493.56	459.41	319.16	297.42	170.62	63.74	21.34	7.48	3.88	1.49	(
RTD	07/07/2024	AVRN	Advisory	Demand	6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(
RTD	07/07/2024	AVRN	Binding	Demand	6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(
RTD	07/07/2024	AVRN	Advisory	Solar	6	0.00	0.00	0.00	0.00	0.00	0.72	121.49	298.33	344.04	359.99	366
RTD	07/07/2024	AVRN	Binding	Solar	6	0.00	0.00	0.00	0.00	0.00	0.69	132.79	300.22	346.38	360.15	367
RTD	07/07/2024	AVRN	Advisory	Wind	6	493.56	459.41	319.16	297.42	170.62	63.74	21.34	7.48	3.88	1.49	(
RTD	07/07/2024	AVRN	Binding	Wind	6	501.17	454.08	315.54	287.89	166.74	56.70	19.76	6.28	3.71	1.40	(
RTD	07/07/2024	AVRN	Advisory	Demand	7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(
RTD	07/07/2024	AVRN	Binding	Demand	7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(
RTD	07/07/2024	AVRN	Advisory	Solar	7	0.00	0.00	0.00	0.00	0.00	1.51	146.73	303.48	346.75	360.11	367
RTD	07/07/2024	AVRN	Binding	Solar	7	0.00	0.00	0.00	0.00	0.00	1.56	150.65	305.44	348.89	361.21	368

Report Generated: 08/30/2024 19:53:21



Calculate realized uncertainty in RTPD for period 08:20 – 08:25 on 7/7/24

See yellow highlighted values from two previous slides

RTPD advisory net demand forecast

$$-335.64 = 0 - 314.05 - 21.59$$

RTD binding net demand forecast

$$-347.51 = 0 - 343.63 - 3.88$$

Realized uncertainty in RTPD net demand for 08:20 to 08:25 on 7/7/24

$$-347.51 - (-335.64) = -11.87$$



Calculate realized uncertainty in RTD for period 08:20 - 08:25 on 7/7/24

See yellow and purple highlighted values from RTD forecast report

RTD advisory net demand forecast

$$-345.27 = 0 - 340.90 - 4.37$$

RTD binding net demand forecast

$$-347.51 = 0 - 343.63 - 3.88$$

Realized uncertainty in RTD net demand for 08:20 to 08:25 on 7/7/24

$$-347.51 - (-345.27) = -2.24$$



Page 12

Helpful definitions for reference

Net demand forecast =

Demand forecast - Solar forecast - Wind forecast

Realized uncertainty

RTPD uncertainty = RTD binding forecast – RTPD advisory forecast RTD uncertainty = RTD binding forecast – RTD advisory forecast

RTPD advisory forecasts have one value per 15-minute interval (4 values per hour). RTD binding and advisory forecasts have one value per 5-minute interval (12 values per hour). Because realized uncertainty in both RTD and RTPD are dependent on RTD binding forecasts, both RTD and RTPD realized uncertainty samples have 12 values per hour.



For RTPD uncertainty, only the minimum and maximum uncertainty is kept per RTPD interval

For the 15min market (FMM), the ISO will construct uncertainty based on the following measurements.

- The difference of the forecast the market used in the FMM for the first advisory RTUC interval and the maximum forecast the market used for the three corresponding RTD intervals.
- The difference of the forecast the market used in the FMM for the first advisory RTUC interval and the minimum forecast the market used for the three corresponding RTD intervals.

Screenshot from Market Operations BPM Appendix N

This describes the adjustment for RTPD uncertainty calculations (this does not apply to RTD realized uncertainty). This adjustment is made for the mosaic calculation and mirrored in the static and dynamic threshold calculations for RTPD thresholds.

RTPD uncertainty from the forecast for the period 08:15 - 08:30 on 7/7/24 has three uncertainty values coming from three RTD binding forecasts. These are calculated numerically on the next slide.

RTPD advisory (HE9, INT2) 08:15 – 08:30

VS.

RTD binding (HE9, INT4) 08:15 – 08:20

RTD binding (HE9, INT5) 08:20 – 08:25

RTD binding (HE9, INT6) 08:25 – 08:30



RTPD uncertainty (RTD binding – RTPD advisory)

RTD binding (HE9, INT4)

$$0 - 340.4 - 4.37 = -344.77$$

RTD binding (HE9, INT5) 0 - 343.63 - 3.88 = -347.51

RTD binding (HE9, INT6) 0 - 346.38 - 3.71 = -350.09

RTPD advisory (HE9, INT2)

$$0 - 314.05 - 21.59 = -335.64$$

RTPD uncertainty (HE9, INT2)
$$-344.77 - (-335.64) = -9.13$$

RTPD uncertainty (HE9, INT2) -347.51 - (-335.64) = -11.87

RTPD uncertainty (HE9, INT2) -350.09 - (-335.64) = -14.45

RTPD uncertainty samples in **red**, the minimum and maximum for this RTPD interval (HE9, INT2), are preserved and used in the historical sample.

RTD uncertainty (RTD binding - RTD advisory)

RTD binding (HE9, INT4)

$$0 - 340.4 - 4.37 = -344.77$$

RTD binding (HE9, INT5)

0 - 343.63 - 3.88 = -347.51

RTD binding (HE9, INT6) 0 - 346.38 - 3.71 = -350.09

0 - 337.46 - 4.11 = -341.57

RTD advisory (HE9, INT5)

0 - 340.90 - 4.37 = -345.27

RTD advisory (HE9, INT6)

$$0 - 344.04 - 3.88 = -347.92$$

RTD advisory (HE9, INT4) -344.77 - (-341.57) = -3.20

RTD advisory (HE9, INT4) -347.51 - (-345.27) = -2.24

RTD advisory (HE9, INT4) -350.09 - (-347.92) = -2.17

All RTD uncertainty samples in **red** are used in the historical sample.



Assemble 90-day sample for static threshold calculation

Per 90-day sample

90 days x 24 hours/day x 12 samples/hour x 2/3 for min/max uncertainty filter = 17,280 expected samples

Per hour bin

90 days x 1 hour/day x 12 samples/hour x 2/3 for min/max uncertainty filter = 720 expected samples



Calculate 1st and 99th percentile per hour interval over historical sample. Results below calculated for AVRN on RTPD realized uncertainty sample from 4/9/24 to 7/7/24

HE	1st	99th
1	-267.76	201.61
2	-263.54	281.28
3	-303.97	242.60
4	-212.07	247.62
5	-252.83	250.72
6	-245.88	263.55
7	-217.26	307.88
8	-265.00	314.73
9	-225.56	326.68
10	-242.47	344.20
11	-218.22	282.35
12	-216.40	302.92

HE	1st	99th
13	-217.07	312.58
14	-171.27	262.43
15	-170.71	348.32
16	-213.05	288.32
17	-231.77	300.58
18	-174.42	463.33
19	-210.17	326.16
20	-288.34	342.98
21	-237.60	336.04
22	-312.82	374.93
23	-173.25	380.56
24	-196.10	253.24

Percentiles are calculated per hour. **Maximum** and **minimum** values are taken as new static thresholds.

By modifying sample period, static thresholds can be estimated over time. Looking at realized uncertainty by forecast component (demand, solar, wind) can help identify causes of threshold movement.



Page 17

DYNAMIC THRESHOLD



Summary of steps

Differences from static threshold calculation in blue

- Create historical sample of realized uncertainty
 - Calculate net demand forecasts
 - Calculate realized uncertainty from difference in advisory to binding net demand forecasts
 - 180 day symmetric sample
 - For RTPD, keep only minimum and maximum sample per FMM interval (this will eliminate ~1/3 of data)
- Group uncertainty samples by hour and calculate 1st and 99th percentile
 - Hourly percentiles used as histogram thresholds



SUMMARY



Results

- For AVRN example in the presentation, construction of the historical sample from data in OASIS recreates the exact static thresholds for RTPD implemented in July 2024 (-313 MW and 463 MW).
- Threshold calculations can be conducted on a rolling basis to monitor requirements and historical samples.
- There are two more factors that may cause actual thresholds to deviate from this calculation:
 - Capacity factor adjustment
 - If the installed capacity of solar or wind has changed within the historical sample, historical solar and wind forecasts are scaled proportional to the change in capacity (Appendix N, Market Operations BPM) before uncertainty is calculated.
 - Use of the discard range utility
 - For anomalous issues (e.g. solar eclipse, IT incidents), forecast samples may be removed from historical training.



Page 21

Additional references on FRP thresholds

- BPM Market Operations
 - Appendix N
- WEIM Quarterly Meeting December 2022
- FRP Deliverability Refresher Training
 - Navigate to Home > Stakeholder center > Training center > Releases, initiatives and readiness notes
 - Scroll to Training modules (2023)
 - Deliverability training plus MOSAIC calculation example

Flexible ramping product refinements - deliverability refresher

- Flexible ramping product refinements deliverability refresher 🗹 05/18/2024, 7:41 PM
- Flexible Ramping Product Refinements OASIS Mosaic Calculation Companion Spreadsheet 🖭 01/31/2023, 8:13 AM
- Presentation Flexible Ramping Product Refinements Deliverability Refresher Training 01/26/2023, 9:18 AM



For questions, please reach out to Short-Term Forecasting via CIDI

Recommended ticket details

Subject: FRP Thresholds Training

Category: Forecasts

