

## **Tab 4: Security Constrained Unit Commitment (SCUC) Application not yet effective**

### **IMPORTANT NOTICE:**

The Security Constrained Unit Commitment (SCUC) Application section includes, in clean copy, new Section 5.11.6.2, providing for the use of a SCUC computer application for determining must-offer waivers. In its Order on Amendment 60, FERC accepted this provision to become effective ten days after notice by the ISO that the SCUC application was ready for implementation. (See 108 FERC ¶ 61,022 at PP 71-76). On August 23, 2004, the ISO issued a market notice stating that the SCUC application would be implemented (and thus that Section 5.11.6.2 would become effective) on September 2, 2004.

defined in Section 5.11.6.1.1, that the unit generated above minimum load in compliance with ISO Dispatch Instructions.

**5.11.6.2 Criteria for Issuing Must-Offer Waivers**

The ISO shall grant waivers so as to: 1) provide sufficient on-line generating capacity to meet operating reserve requirements; and 2) account for other physical operating constraints, including Generating Unit minimum up and down times. The ISO shall grant, deny or revoke waivers using a security-constrained unit commitment software application to minimize start-up and Minimum Load Costs.