

Transmission Constraint Relaxation Parameter Change
Analysis Results

Constraint	Original Shadow Price (Pricing Run)	Transmission Constraint Parameter			
		\$ 5,000	\$ 2,500	\$ 1,500	\$ 1,000
Congestion Relief Reduction (MW)					
TD 8/18/2012 HE12 Interval 6: 22342_HDWSH _500_22536_N.GILA _500_BR_1_1	\$ 4,475	N/A	7.50	7.70	8.20
TD 10/13/2012 HE5 Interval 7 SCE_PCT_IMP_BG	\$ 2,351	N/A	N/A	86.30	87.50
TD 8/14/2012 HE17 Interval 9 6110_TM_BNK_FLO_TMS_DLO_NG	\$ 4,113	N/A	2.00	2.00	3.00
Real-Time Congestion Offset	Original Congestion Offset (Millions)	% Reduction in Congestion Offset			
(Based on Aug 1, 2012-October 22, 2012)	\$ 71.6	N/A	-18%	-36%	-50.20%

